

```
2012-02-01 12:01:35.58 OPR S2 L6 La Porte Unit U-4 is no longer Hot
2012-02-01 11:54:50.60 OPR S7 L6 M.P. 743.17 STOPPING LINE from Stockbridge to Leonard - Sect Valve 743.17-6-V Closed
2012-02-01 11:54:46.61 : pcLPMActions : Unable to scan station 6MV, see log for details
2012-02-01 11:54:46.59 OPR S6 L6 M.P. 743.17 Scanning to Confirm that Sect. Valve 743.17-6-V is Closed
2012-02-01 11:52:49.85 OPR S7 L6 M.P. 743.17 STOPPING LINE from Stockbridge to Leonard - Sect Valve 743.17-6-V over 60 seconds in T
2012-02-01 11:52:45.86 : pcLPMActions : Unable to scan station 6MV, see log for details
2012-02-01 11:52:45.84 OPR S6 L6 M.P. 743.17 Scanning to Confirm that Sect. Valve 743.17-6-V is still in Travel
2012-02-01 11:51:45.82 OPR S7 L6 M.P. 743.17 Sectionalizing Valve 743.17-6-V is now in Travel to CLOSE
2012-02-01 11:43:39.1.. SYS S4 Process pcControlPlot #0 has died unexpectedly and may not have finished its processing
2012-02-01 11:43:13.5.. SYS S4 Process pcControlPlot #0 has died unexpectedly and may not have finished its processing
2012-02-01 11:42:48.9.. SYS S4 Process pcControlPlot #0 has died unexpectedly and may not have finished its processing
2012-02-01 11:31:35.57 OPR S2 L6 La Porte Unit U-4 is now OFF (Hot Unit)
2012-02-01 11:28:35.42 OPR S4 L6 La Porte Unit U-4 is in sequence OFF
2012-02-01 11:25:16.58 OPR S4 L6 Naperville Low Suction Pressure alarm CLEARED
2012-02-01 11:22:05.87 OPR S4 L6 Naperville Low Suction Pressure
2012-02-01 10:28:37.64 OPR S2 L6 Lockport Unit U-2 is no longer Hot
2012-02-01 10:00:26.75 OPR S2 L6 Mokena Unit U-2 is ON
2012-02-01 09:58:46.93 OPR S2 L6 Walworth Unit U-3 is no longer Hot
2012-02-01 09:58:37.63 OPR S2 L6 Lockport Unit U-2 is now OFF (Hot Unit)
2012-02-01 09:58:31.28 OPR S2 L6 Waterloo Unit U-2 is no longer Hot
2012-02-01 09:58:31.27 OPR S2 L6 Vesper Unit U-4 is no longer Hot
2012-02-01 09:58:31.27 OPR S2 L6 Vesper Unit U-3 is no longer Hot
2012-02-01 09:58:31.22 OPR S2 L6 Stone Lake Unit U-2 is no longer Hot
2012-02-01 09:58:31.22 OPR S2 L6 Stockbridge Unit U-4 is no longer Hot
2012-02-01 09:58:31.22 OPR S2 L6 Stockbridge Unit U-3 is no longer Hot
2012-02-01 09:58:31.22 OPR S2 L6 Stockbridge Unit U-2 is no longer Hot
2012-02-01 09:58:31.22 OPR S2 L6 Stockbridge Unit U-1 is no longer Hot
2012-02-01 09:58:31.20 OPR S2 L6 Sheldon Unit U-3 is no longer Hot
2012-02-01 09:58:31.20 OPR S2 L6 Sheldon Unit U-2 is no longer Hot
2012-02-01 09:58:31.16 OPR S2 L6 Rio Unit U-3 is no longer Hot
2012-02-01 09:58:31.16 OPR S2 L6 Rio Unit U-2 is no longer Hot
2012-02-01 09:58:31.16 OPR S2 L6 Portage Unit U-2 is no longer Hot
2012-02-01 09:58:31.13 OPR S2 L6 East Superior Unit U-2 is no longer Hot
2012-02-01 09:58:31.13 OPR S2 L6 East Superior Unit U-1 is no longer Hot
```