

Geschäftsbereich  
Montage

**BABCOCK**

DEUTSCHE BABCOCK  
WERKE  
AKTIENGESELLSCHAFT

NTSB D09

Dokumentation

Kennwort SS Norway

Kom.-Nr. 94-8351-998

CERTIFIED TO BE A TRUE COPY

*Ja 50, 10 1 of 69*

Code

Kom.-Nr.

94 - 8351 - 998

SS Norway

Component

Boiler 21, 22 and 23

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

	Page
<input checked="" type="checkbox"/> Welder's list	1
<input checked="" type="checkbox"/> Welding code	2
<input checked="" type="checkbox"/> Repair produce plan	3
<input checked="" type="checkbox"/> Test-report temperature recorder	4-5
<input checked="" type="checkbox"/> Boiler 21:	6-23
<input type="checkbox"/> Upper drum, lower drum, lateral drum:	
<input type="checkbox"/> space for sketch, surface crack test, preheating	
<input checked="" type="checkbox"/> Boiler 22:	24-41
<input type="checkbox"/> Upper drum, lower drum, lateral drum:	
<input type="checkbox"/> space for sketch, surface crack test, preheating	
<input checked="" type="checkbox"/> Boiler 23:	42-63
<input type="checkbox"/> Upper drum, lower drum, lateral drum:	
<input type="checkbox"/> space for sketch, surface crack test, preheating	
<input type="checkbox"/>	
<input type="checkbox"/>	
<input type="checkbox"/>	
<input type="checkbox"/>	
<input type="checkbox"/>	
<input type="checkbox"/>	
<input type="checkbox"/>	

CERTIFIED TO BE A TRUE COPY  
 L.T.S.G. 0566  
 P. 26669

# WELDER'S LIST

Code

Job No.

94-8351-998

*55 Norway*

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Serial No.	Welder check No.	Name	Examination	Valid till
1	4	<i>Kreuzenbeck, Rolf</i>	<i>E-R III g</i>	
2	34	<i>Sprengart, Heinz</i>	<i>F-B III g</i>	

CERTIFIED TO BE A TRUE COPY  
 Date 15.12.69

Code \_\_\_\_\_ Job No. **94-8351-998**

*SS Norway*

Component  
*Upper, lower and lateral drum, boiler 21, 22, 23*

part 1 | part 2

Dimensions: *Wall thickness 24-56 mm*

Material: *NF A36-205 A52  $\cong$  19115*

root bead | between-bead

Welding process: *SAW*

Welding filler metal: *SA Schwarz 311A  $\cong$  E 7018-A1*

Form of weld: *see sketch*  
 Preheating: *temperature 120-150 °C*

*Ground-out weld areas*

- Process:
- gas annealing
  - resistive annealing
  - induction annealing

Heat treatment after welding

Heating up period: \_\_\_\_\_ h

Holding time: \_\_\_\_\_ h

Anneal. temper.: \_\_\_\_\_ °C

Recooling time: \_\_\_\_\_ h

- process:
- gas annealing
  - resistive annealing
  - induction annealing

- Test:
- ultrasonic
  - magnetic particle
  - radiographic
  - dye penetration
  - hardness

Peculiarities: *Quenched and tempered pieces are to be produced which are to be ground subsequently.*

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

CERTIFIED TO BE A TRUE COPY  
 JAW L756, USC  
 p. 4 of 69

# REPAIR PRODUCE PLAN

Page

3

Code

Job No.

94-8351-998

*SS Norway*

Component

*Upper, lower and lateral drum, Boiler 21, 22, 23*

Inspection of the deficient area

- ultrasonic
- magnetic particle
- radiographic
- dye penetrant

Removal of the deficient area

- grinding
- milling
- drilling

Inspection for crack absence before welding

- magnetic particle
- dye penetrant

Preheating of deficient area

- welding procedure sheet

Execution of weld

- welding procedure sheet

Machining of weld

- grinding, etc.

Heat treatment

- annealing plan

Test

- ultrasonic
- magnetic particle
- hardness
- radiographic
- dye penetrant

Pressure test

- flue gas
- hydrostatic

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

CERTIFIED TO BE A TRUE COPY

*Handwritten signature and date: 1.5.2006*

Date

Signature

Date

Signature

Kennwort  
 Code Word

Kom.-Nr.  
 Job No.

94-8357-999

SS-Norway - Bremerhaven

Bauteil Component

12 KW Nr. 12

Geräte-Nr.  
 Equipment

307 00 497

Hersteller  
 Manufacturer

Hartmann + Braun

Meßbereich  
 Measuring range

20 - 1200 °C

Güteklasse

1

Quality Class

584

Prüfgerät Nr.

Test Unit No.

Hersteller

Manufacturer

Thermoprozess

Meßgröße Measured quantity °C	Anzeigewerte Reading values °C	Anzeigefehler Indication error K
20°	-	-
100°	100	-
200°	200	-
300°	300	-
400°	400	-
500°	500	-
600°	600	-
700°	703	3
800°	800	-
900°	900	-
1000°	998	2

- Die festgestellten Abweichungen liegen im Toleranzbereich des Prüflings.  
 The found deviations are within the tolerance range of the test object.
- Die festgestellten Abweichungen liegen nicht im Toleranzbereich des Prüflings.  
 Justierung erforderlich durch Fachbetrieb. The found deviations are not within the tolerance range of the test object.  
 Adjustment by specialist company necessary.

Bemerkungen:  
 Notes:

CERTIFIED TO BE A TRUE COPY


da 20.11.95 6 WSCG  
p. 6 of 9

Kennwort - *SS Norway*


Kom. Nr. 

9	4	-	8	3	5	1	-	9	9	8
---	---	---	---	---	---	---	---	---	---	---

*Kalibrierung 12 KW Anlage*



*17 Kalibrierung: 20.09.90 12KW Nr. 12*  
*11 H+D Nr. 307 00 497*  
*Kalibrierzeit: Thermop. Nr. 584*



Nachdruck ist auch untersagt, ist nur mit Genehmigung der "Deutsche Babcock Werke AG", 47 Oberhausen, gestattet

CERTIFIED TO BE A TRUE COPY  
 70869  
 vordr. 7a

Datum	Unterschrift	Datum	Unterschrift
		<i>30-09-96</i>	<i>H. G. Koochka</i>



Code

Job No.




94 - 8351 - 998

SS Norway

Component

Boiler 21

Reproduction, even in an abridged form, only permitted with the approval of DBW AG



CERTIFIED TO BE A TRUE COPY  
Date 14.1.71  
Vordruck  
Ausgabe

Erection division

Date

14.1.71

Signature

L. Becken

Date

Signature



Code

Job No.



94-8351-998

SS Norway

Component

Boiler 21 Upper drum

Inspection result before repair



RN1  
 o →

RN2

Distance from o → [mm]	Wall thickness [mm]	
	LN 1	LN 2
	> 54,1	> 54,9

Longitudinal welds 1 and 2 exhibit coarse corrosion pits, but no indications subject to registration.

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

CERTIFIED TO BE A TRUE COPY

62450, P. 9 of 69

Vordruck  
 Ausgabe

Erection division

Date

14.1.91

Signature

*P. G. ...*

Date

Signature

Code

Job No.


94-8351-998

SS Norway


Component

Boiler 21 Upper drum

Inspection result before repair



RN1



RN2

Distance from $\rightarrow$	Wall thickness [mm]	
	RN1	RN2
3 o'clock	> 53,7	56,5
4 o'clock		57,4

RN1 : no crack indications

RN2 : 2 indications in the 3 o'clock sector about 45 mm long on the left and right of the weld metal in HAZ; several smaller indications 5-6 mm in length in the weld metal in the half-past-three sector

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

CERTIFIED TO BE A TRUE COPY

10/29, p. 10068

Erection division

Date

14.1.91

Signature

*E. P. ...*

Date

Signature

Ausgabe

Vordruck

Code

Job No.


94 - 8351 - 998

SS Norway

Component


Boiler 21 Upper drum

Inspection result after repair



RN1  
←

RN2



Distance from ←  
[mm]

Wall thickness [mm]

	Wall thickness [mm]	
	LN1	LN2
	> 54,1	> 54,9

No rework was performed.

Vordruck  
Ausgabe

Erection division

Date

14.1.91

Signature

*J. Becker*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*100 P. 11 OF 69*

Code

Job No.


94 - 8351 - 998

SS Norway


Component

Boiler 21 Upper drum

Inspection result after repair



RN1



RN2

Distance from $\rightarrow$	Wall thickness [mm]	
	RN1	RN2
3 o'clock	> 53,7	55,0

RN1 + RN2 : No crack indications.

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Vordruck  
Ausgabe

Erection division

Date  
14. 1. 91

Signature

*J. Ecker*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*Edes*, p. 12 of 69

**BABCOCK**

**OBERFLÄCHENRISSPRÜFUNG  
SURFACE CRACK TEST**

Besch.-Nr.:  
Certif.-No.: 11  
Blatt: 1 von  
Sheet: 1 of

Kennwort :  
Code word : *SS Norway*  
Kom. : *94-8351-998* Blatt :  
Job. : *94-8351-998* Sheet : Pos. :  
Item :

AK-Nr.:  
Plant identification No.:

Gegenstand : *Upper drum Boiler*  
Subject : *Obertrommel Kessel 21*

System:  
System:

Bauteil :  
Component : Abmessung :  
Dimension :

Fabr.-Nr.:  
Fabrication No.:

Zeichn.-Nr. :  
Drawg.-No. : *S. Kesselübersicht* Schweißverfahren : *E*  
Welding process : *SMFW*

KE-Nr.:  
Bgr.: TE:  
Ass: Term unit:

Prüflächenzustand / Nahtoberfläche : *geschliffen* Prüfung nach : *HP5/3*  
Surface condition of test area / Surface of seam : *gründl* Test according to

Wärmebehandlung : vor  nach  keine   
Heat treatment : before after no Beurteilung durch : *DB*  
Evaluation by :

Prüfung an : Grundwerkstoff  Schweißkante  Schweißnaht   
Test on : Base material Weld edge Weld seam

MAGNETPULVERPRÜFUNG nach: *Din 54130* Testkörper:  
MAGNETIC particel test acc. to Testbody: *Berthold*  
Prüfgerät: Stromstärke:  
Test equipment: *Tiede TMH 42 V* Current intensity:  
Prüfmittel: Magnetisierungsart:  
Medium for testing: *Peters MP205* Kind of magnetization: *JEW*  
*näß / trocken* Kontrastmittel:  
*wet / dry* Medium of contrast: *Peters MP204*  
fluoreszierend: ja / nein Tangentialfeldstärke:  
fluorescent: *yes / no* Tangential field intensity: *4.0* KA/m

Pos. / Item or Naht-Nr. Weld-No.	Gesamtstückzahl Total Quantity	Prüfmfang Test volume %	geprüfte Stückzahl tested quantity	Abmessung Dimension [ mm ]	Werkstoff Material	Beurteilung / evaluation		
						erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory
<i>RN1</i>	<i>1</i>	<i>100</i>	<i>1</i>	<i>Lip 1614 x 104 / 156</i>	<i>~ AMn5</i>		<input checked="" type="checkbox"/>	
<i>RN2</i>	<i>*</i>	<i>*</i>	<i>*</i>	<i>"</i>	<i>"</i>		<input checked="" type="checkbox"/>	
<i>LN1</i>	<i>*</i>	<i>*</i>	<i>*</i>	<i>"</i>	<i>"</i>		<input checked="" type="checkbox"/>	
<i>LN2</i>	<i>*</i>	<i>*</i>	<i>*</i>	<i>"</i>	<i>"</i>		<input checked="" type="checkbox"/>	

Bemerkungen : *Endprüfung* Test after repair

Ort : *Bremerhaven* den : *30.09.90* Sachverständiger :  
Place : *Bremerhaven* dated : *30.09.90* Expert :

Prüfer : *i.v. Schiller* Prüfaufsicht : *[Signature]*  
Operator : *i.v. Schiller* Test Supervision : *[Signature]* ZF

CERTIFIED TO BE A TRUE COPY

*[Handwritten signature]* P. 130 F 68

Code

Job No.



94-8351-998

SS Norway

Component

Boiler 21 Lower drum

Inspection result before repair



RN1  
o→

RN2

Distance from o→ [mm]	Wall thickness [mm]	
	LN1	LN2
0	38,6	34,0
2000	37,5	36,2
4000	36,0	38,7

LN1 + LN2: Severe corrosion pitting in the entire weld area.

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Vordruck  
Ausgabe

Erection division

Date

14. 1. 71

Signature

J. Eichen

Date

Signature

CERTIFIED TO BE A TRUE COPY

*[Handwritten signature]*, p. 14 of 69



Code Job No. 94 - 8351 - 998

SS Norway

Component  
Boiler 21 Lower drum

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Inspection result before repair



Distance from $\rightarrow$	Wall Thickness [mm]	
	RN1	RN2
1 o'clock	35,2	35,7

RN1: 1 o'clock 30mm crack  
 2 o'clock - half past two } severe corrosion pitting with  
 3 o'clock - 9 o'clock } crack-like connections  
 11 o'clock - half past eleven

RN2: 1 o'clock 25mm crack  
 half past two - half past eight } severe corrosion pitting with  
 11 o'clock - 12 o'clock } crack-like connections

Vordruck  
Ausgabe

Erection division	Date 15.1.91	Signature J. Fischer	Date	Signature
-------------------	-----------------	-------------------------	------	-----------

CERTIFIED TO BE A TRUE COPY

*[Handwritten signature]* 15 of 69

Code

Job No.


94-8351-998

SS Norway

Component


Boiler 2-1 lower drum

Inspection result after repair



RN1  
a →

RN2



Distance from a →  
[mm]

Wall thickness [mm]

	LN1	LN2
	> 35,3	> 33,8

LN1 + LN2 : No crack indications.

Vordruck  
Ausgabe

Erection division

Date

15.1.91

Signature

J. Pocher

Date

Signature

CERTIFIED TO BE A TRUE COPY

100 p. 16 of 69



Code

Job No.

94-8351-998


SS Norway

Component


Boiler 21 Lower drum

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Inspection result after repair



RN1



RN2

Distance from  $\rightarrow$

Wall thickness [mm]

	RN1	RN2
six o'clock	33,8	
seven o'clock	33,2	> 37,8
nine o'clock	33,5	

RN1 + RN2 : No crack indications

Vordruck

Ausgabe

Erection division

Date

15.1.91

Signature

J. Bøker

Date

Signature

CERTIFIED TO BE A TRUE COPY

17 of 69

**BABCOCK**

**OBERFLÄCHENRISSPRÜFUNG  
SURFACE CRACK TEST**

Besch.-Nr.:  
Certif.-No.: *16*  
Blatt: 1 von  
Sheet: 1 of

Kennwort :  
Code word : *SS Norway*  
Kom. : *94-8351-998* Blatt : Pos. :  
Job. : *94-8351-998* Sheet : Item :

AK-Nr.:  
Plant identification No.:

Gegenstand : *Lower drum Boiler*  
Subject : *Untertrommel Kessel 21*

System:  
System:

Bauteil :  
Component :

Abmessung :  
Dimension :

Fabr.-Nr.:  
Fabrication No.:

Zeichn.-Nr. :  
Drawg.-No. : *S. Kesselübersicht*

Schweißverfahren : *E*  
Welding process : *SMHW*

KE-Nr.:  
Bgr.: TE:  
Ass: Term unit:

Prüflächenzustand / Nahtoberfläche  
Surface condition of test area / Surface of seam  
*geschliffen*  
*gründl.*

Prüfung nach  
Test according to  
*HP 5/3*

Wärmebehandlung :  
Heat treatment : vor  nach  keine   
before after no

Beurteilung durch :  
Evaluation by : *DB*

Prüfung an :  
Test on : Grundwerkstoff  Schweißkante   
Base material Weld edge

Schweißnaht   
Weld seam

MAGNETPULVERPRÜFUNG nach: *Din 54130*  
MAGNETIC partical test acc. to

Testkörper:  
Testbody: *Berthold*

Prüfgerät:  
Test equipment: *Tiede TWM 42V*

Stromstärke:  
Current intensity:

Prüfmittel:  
Medium for testing: *Peters MP205*

Magnetisierungsart:  
Kind of magnetization: *JEW*

naß / trocken  
wet / dry

Kontrastmittel:  
Medium of contrast: *Peters MP204*

fluoreszierend: *ja / nein*  
fluorescent: *yes / no*

Tangentialfeldstärke:  
Tangential field intensity: .....KA/m

Pos. / Item or Naht-Nr. Weld-No.	Gesamtstückzahl Total Quantity	Prüfmfang Test volume %	geprüfte Stückzahl tested quantity	Abmessung Dimension [ mm ]	Werkstoff Material	Beurteilung / -evaluation			
						erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory
						anzeigenfrei no indication	keine unzul. Anzeigen no indic. to be recorded	erfüllt satisfactory	nicht erfüllt not satisfactory
<i>RN1</i>	<i>1</i>	<i>100</i>	<i>1</i>	<i>Lip 1030 x 79/36</i>	<i>~ 19 Mn 4</i>		<i>X</i>		
<i>RN2</i>	<i>*</i>	<i>*</i>	<i>*</i>	<i>"</i>	<i>"</i>		<i>X</i>		
<i>LN1</i>	<i>*</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>		<i>X</i>		
<i>LN2</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>		<i>X</i>		

Bemerkungen :  
Remarks : *Endprüfung Test after repair*

Ort : *Bremerhaven* den : *30.09.90* Sachverständiger :  
Place : *Bremerhaven* dated : *30.09.90* Expert :

Prüfer : *Schiller* Prüfaufsicht :  
Operator : *Schiller* Test Supervision : *[Signature]*

CERTIFIED TO BE A TRUE COPY

*[Signature]* P. 180 of 69

Code

Job No.



94 - 8351 - 998

SS Norway

Component

Boiler 21 lateral drum

Inspection result before repair



RN1  
→

RN2

Distance from → [mm]	Wall thickness [mm]	
	LN1	LN2
0	23,1	24,6
2000	23,0	25,8
4000	25,5	24,5

LN1 : 0 - 1400 coarse corrosion pits with crack connections  
 2000 - 3000 7 cracks, 15-20 mm long  
 3000 - 4000 4 cracks, 20-25 mm long  
 4000 - 4350 severely pitted crack indications

LN2 : 0 - 2000 continuously small crack indications  
 2000 - 3000 6 cracks, 15-20 mm long  
 3000 - 4000 2 cracks 10 mm long

Vordruck  
Ausgabe

Erection division

Date

15.1.91

Signature

J. Cocherus

Date

Signature

CERTIFIED TO BE A TRUE COPY

19 of 69

Code

Job No.


94-8351-998

SS Norway


Component

Boiler 21 Lateral Drum

Inspection result before repair



RN1



RN2

Distance from 0 →

Wall thickness [mm]

	RN1	RN2
0 o'clock	25,1	24,2
half past one	24,6	25,3
3 o'clock	23,7	27,5
half past four	23,6	28,9
6 o'clock	22,9	23,0
half past seven	24,0	22,3
9 o'clock	24,5	24,0
half past ten	24,2	25,2

RN1: 3 o'clock crack 20mm long; severe corrosion pitting in the entire weld area.

RN2: 3 o'clock - 9 o'clock 6 cracks, 10-20mm long; severe corrosion pitting in the entire weld area.

Vordruck  
Ausgabe

Erection division

Date

15.1.91

Signature

J. Eickhaus

Date

Signature

CERTIFIED TO BE A TRUE COPY

Handwritten signature and number: 20 of 69

Kennwort-


*SS Norway*

Kom Nr

94-8351-998

*Boiler 21 Lateral drum LN2*

*Kessel 21 Seitentrommel LN2*



*Boiler 21 Lateral drum  
Kessel 21 Seitentrommel*

*5 untere Längsnaht  
Lower Long seam*

Ni Cr-Ni DIN  
**BABCOCK**  
Montage-Schweißtechnik

4  
3  
2  
1  
20

94-8351-998  
*SS-Norway Kessel 21  
Seitentrommel*  
Schweißlin.-Pos.:  
Anfertiger:  
verstellt: *19.11.5*  
Vorschub d. Temp. voranschreiten: *20* mm/h  
Datum: *30.09.90* Güter: *Rösner*  
*H. J. Kocourek*



Vordr. 7a

*H. J. Kocourek*  
Datum Unterschrift Datum Unterschrift Datum Unterschrift

CERTIFIED TO BE A TRUE COPY

*Jan P. 21 9 F 69*

Code

Job No.

94 - 8351 - 998



SS Norway

Component

Boiler 21, Lateral drum

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

*Inspection result after repair*



RN1  
→

RN2

Distance from →  
[mm]

Wall thickness [mm]

	Wall thickness [mm]	
	LN1	LN2
1200	21,7	
2000	22,4	
3000	21,7	
3500	22,2	
4000	22,6	
4500	24,7	

LN1: No crack indications

Vordruck  
Ausgabe

Erection division

Date

15.1.91

Signature

*f. Behaus*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*200569*

Code

Job No.



94 - 8351 - 998

SS Norway

Component

Boiler 21, Lateral drum

Inspection result after repair



RN1  
o →

RN2

Distance from o →  
[mm]

Wall thickness [mm]

	Wall thickness [mm]	
	LN1	LN2
300		26,2
450		27,2
1000		22,7
1500		21,3
2000		22,7
3500		22,7
4000		22,5
4500		24,1

In the area of 300 - 450mm the drum was weld-faced.  
LN2 : No crack indications.

Vordruck  
Ausgabe

Erection division

Date

15.1.91

Signature

J. Behrens

Date

Signature

CERTIFIED TO BE A TRUE COPY

class, p.23 of 69

Code

Job No.

94-8351-998


SS Norway

Component


Boiler 21, Lateral drum

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

*Inspection result after repair*



RN1



RN2

Distance from  $\rightarrow$

Wall thickness [mm]

	RN1	RN2
3 o'clock	$\geq 21,8$	$\geq 21,3$
6 o'clock		
9 o'clock		
12 o'clock		

RN1 + RN2 : No crack indications

Vordruck  
Ausgabe

Erection division

Date  
15.1.91

Signature

*J. Becker*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*Page 24 of 69*



Kennwort : *SS Norway*  
Code word :  
Kom. : *94-8351-98* Blatt : Pos. :  
Job. : *94-8351-98* Sheet : Item :

AK-Nr.:  
Plant identification No.:

Gegenstand : *Boiler 21*  
Subject : *Seitentrommel Kessel 21*  
*lateral drum*

System:  
System:

Bauteil :  
Component :  
Abmessung :  
Dimension :

Fabr.-Nr.:  
Fabrication No.:

Zeichn.-Nr. :  
Drawg.-No. : *S.Kesselübersicht*  
Schweißverfahren : *E*  
Welding process : *SMW*

KE-Nr.:  
Bgr.: TE:  
Ass: Term unit:

Prüfflächenzustand / Nahtoberfläche *geschliffen*  
Surface condition of test area / Surface of seam *grund*  
Prüfung nach *HP5/3*  
Test according to

Wärmebehandlung : vor  nach  keine   
Heat treatment : before after no  
Beurteilung durch : *DB*  
Evaluation by :

Prüfung an : Grundwerkstoff  Schweißkante  Schweißnaht   
Test on : Base material Weld edge Weld seam

MAGNETPULVERPRÜFUNG nach: *DIN 54130* Testkörper: *Beithold*  
MAGNETIC partical test acc. to  
Prüfgerät: *Tiede TWM 42 V* Current intensity:  
Test equipment: *Peters MP 205* Magnetisierungsart: *J.E.W.*  
Prüfmittel: *Peters MP 204* Kind of magnetization:  
Medium for testing: *naß / trocken* Kontrastmittel:  
Medium of contrast: *fluoreszierend: ja / nein* Tangentialfeldstärke:  
Tangential field intensity: *4.0* KA/m  
fluorescent: *yes / no*

Pos. / Item or Naht-Nr. Weld-No.	Gesamtstückzahl Total Quantity	Prüfmfang Test volume %	geprüfte Stückzahl tested quantity	Abmessung Dimension [ mm ]	Werkstoff Material	Beurteilung / evaluation		
						erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory
						anzeigefrei no indication	keine unzul. Anzeigen no indic. to be recorded	nicht erfüllt not satisfactory
<i>RN1</i>	<i>1</i>	<i>100</i>	<i>1</i>	<i>Lip 694 x 50/24</i>	<i>~ 19 Mn 4</i>		<i>X</i>	
<i>RN2</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>		<i>X</i>	
<i>LN1</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>		<i>X</i>	
<i>LN2</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>		<i>X</i>	
				<i>Test after repair</i>				

Bemerkungen :  
Remarks : *Endprüfung n. d. Schweißnaht*

Ort : *Bremerhaven* den : *30.09.90* Sachverständiger :  
Place : *Bremerhaven* dated : *30.09.90* Expert :

Prüfer : *Hohendorf* Prüfaufsicht : *[Signature]*  
Operator : *Hohendorf* Test Supervision : *[Signature]*

Code

Job No.

94-8351-998

SS Norway


Component

Boiler 22

Reproduction, even in an abridged form, only permitted with the approval of DBW AG


Upper drum

LN2



LN1


LN2



LN1

Lateral drum

LN2



LN1

Lower drum

Vordruck

Ausgabe

Erection division

Date

11.1.91

Signature

*J. Pöschel*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*100* p. 26 of 69

Code

Job No.



94 - 8351 - 998

SS Norway

Component

Boiler 22, Upper drum

Inspection result before repair



RN1  
o →

RN2

Distance from o → [mm]	Wall thickness [mm]	
	LN1	LN2
0	54,2	55,2
Center	55,4	
End	55,2	54,7

LN1: Severe corrosion pitting with crack connection

LN2: Severe corrosion pitting without crack connection

Vordruck  
Ausgabe

Erection division

Date  
18.1.71

Signature

J. Becker

Date

Signature

CERTIFIED TO BE A TRUE COPY

date 22 p. 27 of 69

Code

Job No.


94 - 8351 - 998

SS Norway


Component

Boiler 22, Upper drum

Inspection result before repair



RN1



RN2

Distance from  $\rightarrow$

Wall thickness [mm]

	RN1	RN2
0 o'clock	55,1	55,3
3 o'clock	57,1	54,9
6 o'clock	60,2	57,8
9 o'clock	60,3	55,3

RN1: 2 o'clock crack 10 mm long

RN2: 3 o'clock - 9 o'clock severe corrosion pitting with crack connections

11 o'clock - half past eleven small crack indications

Vordruck  
Ausgabe

Erection division

Date

7.1.91

Signature

*J. Pöcher*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*6/250 p. 28 of 69*

Code

Job No.



94 - 8351 - 998

SS Norway

Component

Boiler 22, Upper drum

Inspection result after repair



RN1  
0 →

RN2

Distance from 0 →  
[mm]

Wall thickness [mm]

	Wall thickness [mm]	
	LN 1	LN 2
0	52,3	55,2
2500	50,9	
4800	53,4	54,7

LN1 : No crack indications  
LN2 : No crack indications

Vordruck  
Ausgabe

Erection division

Date

18.1.91

Signature

J. Eichen

Date

Signature

CERTIFIED TO BE A TRUE COPY

29 of 69

Code

Job No.

94-8351-998


SS Norway

Component


Boiler 22, Upper drum

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Inspection result after repair



RN1



RN2

Distance from $\rightarrow$	Wall thickness [mm]	
	RN1	RN2
0 o'clock	54,7	54,6
3 o'clock	56,3	54,5
6 o'clock	59,4	55,3
9 o'clock	59,4	54,9

RN1 : No crack indications

RN2 : No crack indications

Vordruck  
Ausgabe

Erection division

Date

11.1.91

Signature

J. Ecker

Date

Signature

CERTIFIED TO BE A TRUE COPY

*[Handwritten signature]* 30.01.69

<b>BABCOCK</b>		<b>OBERFLÄCHENRISSPRÜFUNG SURFACE CRACK TEST</b>		Besch.-Nr.: Certif.-No.: 29				
Kennwort : Code word : <i>SS Norway</i>		Blatt : Pos. :		Blatt: 1 von Sheet: 1 of				
Kom. : Job. : <i>94-8351-998</i>		Blatt : Sheet :		AK-Nr.: Plant identification No.:				
Gegenstand : Subject : <i>Wasser drum Obertrommel</i>		Pos. : Item :		System: System:				
BauTeil : Component :		Abmessung : Dimension :		Fabr.-Nr.: Fabrication No.:				
Zeichn.-Nr. : Drawg.-No. : <i>s. Kesselübersicht</i>		Schweißverfahren : Welding process : <i>E SIFAW</i>		KE-Nr.: Bgr.: TE: Ass: Term unit:				
Prüflflächenzustand / Nahtoberfläche Surface condition of test area / Surface of seam		<i>geschliffen grund</i>		Prüfung nach Test according to <i>HP5/3</i>				
Wärmebehandlung : Heat treatment :		vor <input type="radio"/> nach <input type="radio"/> keine <input checked="" type="radio"/> before after no		Beurteilung durch : Evaluation by : <i>DB</i>				
Prüfung an : Test on :		Grundwerkstoff <input type="radio"/> Schweißkante <input type="radio"/> Base material Weld edge		Schweißnaht <input checked="" type="radio"/> Weld seam				
MAGNETPULVERPRÜFUNG nach: MAGNETIC partical test acc. to		<i>DIN 54130</i>		Testkörper: Testbody: <i>Berthold</i>				
Prüfgerät: Test equipment:		<i>Tiede TWM 42 V</i>		Stromstärke: Current intensity:				
Prüfmittel: Medium for testing:		<i>Peters MP205</i>		Magnetisierungsart: Kind of magnetization: <i>JEW</i>				
naß / trocken wet / dry				Kontrastmittel: Medium of contrast: <i>Peters MP204</i>				
fluoreszierend: ja / nein fluorescent: yes / no				Tangentialfeldstärke: Tangential field intensity: <i>4.0</i> KA/m				
Pos. / Item or Naht-Nr. Weld-No.	Gesamtstückzahl Total Quantity	Prüfmfang Test volume %	geprüfte Stückzahl tested quantity	Abmessung Dimension [ mm ]	Werkstoff Material	Beurteilung / evaluation		
						anzeigenfrei no indication	keine unzul. Anzeigen no indic. to be recorded	erfüllt satisfactory
<i>RN1</i>	<i>1</i>	<i>100</i>	<i>1</i>	<i>Lip 1614 x 104 / 156</i>	<i>~ 19Mn5</i>		<i>X</i>	
<i>RN2</i>	<i>*</i>	<i>*</i>	<i>*</i>	<i>*</i>	<i>*</i>		<i>X</i>	
<i>LN1</i>	<i>*</i>	<i>*</i>	<i>*</i>	<i>*</i>	<i>*</i>		<i>X</i>	
<i>LN2</i>	<i>*</i>	<i>*</i>	<i>*</i>	<i>*</i>	<i>*</i>		<i>X</i>	
Bemerkungen : Remarks : <i>Endprüfung Test after repair</i>								
Ort : Place : <i>Bremerhaven</i>		den : dated : <i>30.09.90</i>		Sachverständiger : Expert :				
Prüfer : Operator : <i>Schiller</i>		Prüfaufsicht : Test Supervision : <i>Schiller</i>						

91-2072 5 07

CERTIFIED TO BE A TRUE COPY

*31 of 69*

Code

Job No.

94-8351-998



SS Norway

Component

Boiler 22, lower drums

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Inspection result before repair



RN1  
o→

RN2

Distance from o→ [mm]	Wall thickness [mm]	
	LN1	LN2
0	34,6	35,5
1500	33,6	34,3
3000	34,5	34,5
4500	34,7	34,9

LN1: 0-500 small crack indications  
2500 interrupted crack indications about 150mm long, followed by 2 cracks about 15 to 20 mm long

LN2: 0-1500 small crack indications

Vordruck  
Ausgabe

Erection division

Date

27.1.91

Signature

J. Eichen

Date

Signature

CERTIFIED TO BE A TRUE COPY

*[Signature]* P. 320 F 69



Code

Job No.


94 - 8351 - 998

SS Norway


Component

Boiler 22, lower drum

Inspection result before repair



RN1



RN2

Distance from  $\rightarrow$  | Wall thickness [mm]

	RN1	RN2
0 o'clock	36,1	38,0
3 o'clock	34,0	36,0
6 o'clock	36,7	34,0
9 o'clock	35,6	35,5

RN1: 0 o'clock - 3 o'clock } severe corrosion pitting with  
5 o'clock - 7 o'clock } crack-like connections.  
8 o'clock - 0 o'clock

RN2: severe corrosion pitting with  
crack-like connections

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Vordruck  
Ausgabe

Erection division

Date

21. 1. 91

Signature

J. Eichen

Date

Signature

CERTIFIED TO BE A TRUE COPY

6/20 p. 33 of 69

Code

Job No.



94 - 8351 - 998

SS Norway

Component

Boiler 22, lower drums

*Inspection result after repair*



RN1  
→

RN2

Distance from [mm]	Wall thickness [mm]	
	LN1	LN2
500		> 32,8
900		> 34,6
1800	> 32,6	
2500	> 33,0	

LN1 : No crack indications

LN2 : No crack indications

Vordruck  
Ausgabe

Erection division

Date  
23.1.71

Signature

*J. Becker*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*Handwritten signature* p. 34 of 69

Code

Job No.


94 - 8351 - 998

SS Norway


Component

Böiler 22, Lower drum

Inspection result after repair



RN1



RN2

Distance from  $\rightarrow$

Wall thickness [mm]

	RN1	RN2
3 o'clock	> 31,5	
6 o'clock	> 33,4	
8 o'clock	> 32,8	
6 o'clock		> 32,8
9 o'clock		> 34,8

RN1: No crack indications

RN2: No crack indications

Vordruck

Ausgabe

Erection division

Date

23.1.91

Signature

*J. Eckert*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*W. J. ...* p. 350 69

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

**BABCOCK**

**OBERFLÄCHENRISSPRÜFUNG  
SURFACE CRACK TEST**

Besch.-Nr.:  
Certif.-No.: **74**  
Blatt: 1 von  
Sheet: 1 of

Kennwort :  
Code word : **S.S Norway**  
Kom. : **94-8351-998** Blatt : Pos. :  
Job. : Sheet : Item :

AK-Nr.:  
Plant identification No.:

Gegenstand : **Untertrommel Boiler 22**  
Subject : **Kessel 22**

System:  
System:

Bauteil :  
Component : Abmessung :  
Dimension :

Fabr.-Nr.:  
Fabrication No.:

Zeichn.-Nr. :  
Drawg.-No. : **S. Kesselübersicht** Schweißverfahren : **E**  
Welding process : **SITAN**

KE-Nr.:  
Bgr.: TE:  
Ass: Term unit:

Prüflächenzustand / Nahtoberfläche : **geschliffen** Prüfung nach : **HP 5/3**  
Surface condition of test area / Surface of seam : **geschliffen** Test according to

Wärmebehandlung : vor  nach  keine   
Heat treatment : before after no  
Beurteilung durch : **DB**  
Evaluation by :

Prüfung an : Grundwerkstoff  Schweißkante  Schweißnaht   
Test on : Base material Weld edge Weld seam

MAGNETPULVERPRÜFUNG nach: **Din 54130** Testkörper: **Berthold**  
MAGNETIC particle test acc. to Testbody:  
Prüfgerät: **Tiede TWM 42V** Stromstärke:  
Test equipment: Current intensity:  
Prüfmittel: **Peters MP205** Magnetisierungsart:  
Medium for testing: Kind of magnetization: **JEW**  
naß / trocken **ja / nein** Kontrastmittel:  
wet / dry **Peters MP204**  
fluoreszierend: **ja / nein** Tangentialfeldstärke:  
fluorescent: **yes / no** Tangential field intensity: **KV/m**

Pos. / Item or Naht-Nr. Weld-No.	Gesamtstückzahl Total Quantity	Prüfmeng. Testvolume %	geprüfte Stückzahl tested quantity	Abmessung Dimension [ mm ]	Werkstoff Material	Beurteilung / evaluation			
						erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory
<b>RN1</b>	<b>1</b>	<b>100</b>	<b>1</b>	<b>Lip 1030 x 79/36</b>	<b>~ 19Mn4</b>				
<b>RN2</b>	"	"	"	"	"				
<b>LN1</b>	"	"	"	"	"				
<b>LN2</b>	"	"	"	"	"				

Bemerkungen : **Endprüfung Test after repair**  
Remarks :

Ort : **Bremerhaven** den : **30.09.90** Sachverständiger :  
Place : dated : Expert :

Prüfer : **Schiller** Prüfaufsicht : **[Signature]**  
Operator : Test Supervision : **[Signature]**

CERTIFIED TO BE A TRUE COPY  
**[Signature]** p. 360 F369

Code

Job No.



94-8351-998

SS Norway

Component

Boiler 22, lateral drum

Inspection result before repair



RN1  
o→

RN2

Distance from o→  
[mm]

Wall thickness [mm]

	LN1	LN2
	20,3 - 22,8	21,2 - 22,8

LN1 + LN2 : continuously crack-like indications

Vordruck  
Ausgabe

Erection division

Date

22.1.91

Signature

*J. Pedersen*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*J. Pedersen*, p. 37 of 69

Code

Job No.


94 - 8351 - 998

SS Norway


Component

Boiler 22, Lateral drum

Inspection result before repair



RN1



RN2

Distance from 0 →

Wall thickness [mm]

	RN1	RN2
	> 22,8	21,4 - 23,8

RN1: 4 o'clock - 8 o'clock Pits with indications

RN2: 4 o'clock - 7 o'clock Crack-like indications

Vordruck  
Ausgabe

Erection division

Date

23. 4. 77

Signature

*P. Pöschel*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*See 22 p 38 of 69*

Kennwort -


SS Norway

Kom. Nr.

94-8351-998

Boiler 22 Lateral drum

Kessel 22 Seitentrommel LN 1



18 28.09.90 Boiler 22 Lateral drum

Kessel 22 Seitentrommel

Lower long seam

untere Langsnaht / 2 Schweißnaht

Ni-Cr-Ni DIN

**BABCOCK**  
Montage-Schweißtechnik

17 1100 - 1350 mm weld area

16

94-8351-998

Objekt: SS-Norway Kessel 22  
Seitentrommel

Schweißplan Pos. ...

Arbeitsgr.

14

Werkstoff: A 19 H 5

Vorschub d. Temp. aufschweissen: 20

13

Datum: 30.09.90

Glüh: Rosner, A

7.9. Kocor



Vordr. 7a

<p>7.9. Kocor</p> <p>Datum: Unterschrift</p>		<p>Datum: Unterschrift</p>	

CERTIFIED TO BE A TRUE COPY

Handwritten signature and date: 2. Dec 90, p. 39 of 69

Kennwort-


SS Norway

Kom. Nr.

94-8351-998

Boiler 22 Lateral drum

Kessel 22 Seitentrommel LN 4



32m-a-18 86.560



6 Boiler 22, Lateral drum Ni Cr-Ni DIN

28.09.90 Kessel 22, Seitentrommel Montage-Schweißtechnik

5 untere Längsnaht / 1 Schweißnaht 3400-3500 mm  
 lower long seam weld area 3400-3500 mm

4 BABCOCK - ...

94-8351-998

3 SS-Norway Kessel 22  
 Seitentrommel

Schweißplan - Pos. ...

Alt ...

2 ... 19.11.5

Vorschuss-Temperatur ... 20 ...

30.03.90

Rösner

H. Kocoula



Vordr. 7a

78.9. ...  
 Datum Unterschrift

Datum Unterschrift

Datum Unterschrift

CERTIFIED TO BE A TRUE COPY

See 30, p 20 of 69



Code

Job No.

94-8351-998



SS Norway

Component

Boiler 22, Lateral drum

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

*Inspection result after repair*



RN1  
o→

RN2

Distance from o→ [mm]	Wall thickness [mm]	
	LN1	LN2
1100	21,5	> 20,7
1150	24,1	
1380	21,1	
3000	20,8	> 20,7
3250	26,8	
3500	20,8	

LN1: Areas of 1100 to 1350 and 3100 to 3500 were welded. No crack indications.

LN2: No crack indications.

Vordruck  
Ausgabe

Erection division

Date  
23.1.91

Signature

*J. Escher*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*See p. 41 of 68*

Code

Job No.


94-8351-998

SS Norway


Component

Boiler 22, Lateral drum

Inspection result after repair



RN1



RN2

Distance from $\rightarrow$	Wall Thickness [mm]	
	RN1	RN2
6 o'clock	> 21,5	> 20,5

RN1 : No crack indications

RN2 : No crack indications

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Vordruck  
Ausgabe

Erection division

Date  
27.1.71

Signature

*J. Boles*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*200* p. 42 of 69

**BABCOCK**

**OBERFLÄCHENRISSPRÜFUNG  
SURFACE CRACK TEST**

Besch.-Nr.:  
Certif.-No.: 44  
Blatt: 1 von  
Sheet: 1 of

Kennwort :  
Code word : S.S Norway  
Kom. : 94-8351-998 Blatt : Pos. :  
Job. : Sheet : Item :

AK-Nr.:  
Plant identification No.:  
System:  
System:

Gegenstand :  
Subject : Seiptrommel Boiler 22  
lateral drum  
Kessel 22

Fabr.-Nr.:  
Fabrication No.:

Bauteil :  
Component : Abmessung :  
Dimension :

KE-Nr.:  
Bgr.: TE:  
Ass: Term unit:

Zeichn.-Nr. :  
Drawg.-No. : S. Kesselübersicht Schweißverfahren : E  
Welding process : SITAW

Prüflflächenzustand / Nahtoberfläche geschliffen Prüfung nach HP 5/3  
Surface condition of test area / Surface of seam ground Test according to

Wärmebehandlung : vor  nach  keine  Beurteilung durch : DB  
Heat treatment : before after no Evaluation by

Prüfung an : Grundwerkstoff  Schweißkante  Schweißnaht   
Test on : Base material Weld edge Weld seam

MAGNETPULVERPRÜFUNG nach: Din 54130 Testkörper:  
MAGNETIC particle test acc. to Testbody: Berthold  
Prüfgerät: Stromstärke:  
Test equipment: Tiede TWM 42 V Current intensity:  
Prüfmittel: Magnetisierungsart:  
Medium for testing: Peters MP205 Kind of magnetization: J.E.W.  
naß / trocken Kontrastmittel:  
~~wet / dry~~ Medium of contrast: Peters MP204  
fluoreszierend: ja / nein Tangentialfeldstärke:  
fluorescent: yes / no Tangential field intensity: 4.0 KA/m

Pos. / Item or Naht-Nr. Weld-No.	Gesamtstückzahl Total Quantity	Prüflänge % Testvolume	geprüfte Stückzahl tested quantity	Abmessung Dimension [ mm ]	Werkstoff Material	Beurteilung / evaluation			
						erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory
<u>RNA</u>	<u>1</u>	<u>100</u>	<u>1</u>	<u>Lip 694 x 50/24</u>	<u>~ 19Mn4</u>		<u>X</u>		
<u>RN2</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>		<u>X</u>		
<u>LN1</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>		<u>X</u>		
<u>LN2</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>	<u>"</u>		<u>X</u>		

Bemerkungen : Endprüfung n. d. Schweißern  
Remarks :

Ort : Bremerhaven den : 30.09.90 Sachverständiger :  
Place : dated : Expert :

Prüfer : Schiller Prüfaufsicht : [Signature]  
Operator : Test Supervision : [Signature]

91-2972 5.87

CERTIFIED TO BE A TRUE COPY

Handwritten Signature p. 43 of 69

Code

Job No.


94-8351-998

SS Norway


Component

Boiler 23


Reproduction, even in an abridged form, only permitted with the approval of DBW AG



Upper drum



Lower drum



Lateral drum

Vordruck  
Ausgabe

Erection division

Date  
24.1.91

Signature

J. Becken

Date

Signature

CERTIFIED TO BE A TRUE COPY

Lee R. P. 44 of 69

Code

Job No.



94-8351-998

SS Norway

Component

Boiler 23, Upper drum

Inspection result before repair



RN1  
o→

RN2

Distance from o→  
[mm]

Wall thickness [mm]

	Wall thickness [mm]	
	LN 1	LN 2
500	57,0	56,8
2500	53,6	56,7
4500	54,8	56,6

Severe corrosion in the entire drum area.

LN 1: Appreciable indications in the area of 2600 to 2900mm

LN 2: Indication in the root over the full length.

Vordruck  
Ausgabe

Erection division

Date  
24.7.97

Signature

J. Eschen

Date

Signature

CERTIFIED TO BE A TRUE COPY

Dec 22 p. 215 of 69

Code

Job No.


94-8351-998

SS Norway


Component

Boiler 23, Upper drum

Inspection result before repair



RN1



RN2

Distance from 0 →	Wall thickness [mm]	
	RN1	RN2
0 o'clock	55,5	56,4
3 o'clock	55,6	55,6
6 o'clock	55,6	54,6
9 o'clock	55,5	53,2

RN1 : Severe corrosion pitting in the ground area  
crack-like indications in the area of 4-8 o'clock

RN2 : Severe corrosion pitting in the ground area  
crack-like indications in the area of 4-8 o'clock

Vordruck  
Ausgabe

Erection division

Date

14.1.97

Signature

J. Bohm

Date

Signature

CERTIFIED TO BE A TRUE COPY

See 22 p. 46 of 68

Code

Job No.



94-8351-998

SS Norway

Component

Boiler 23, Upper drum

Inspection result after repair



RN1  
o→

RN2

Distance from o→  
[mm]

Wall thickness [mm]

	Wall thickness [mm]	
	LN1	LN2
	> 52,8	> 49,9

LN1 : No crack indications

LN2 : No crack indications

Vordruck  
Ausgabe

Erection division

Date  
14.7.91

Signature

J. Ecker

Date

Signature

CERTIFIED TO BE A TRUE COPY

Page 45 of 69

Code

Job No.


94 - 8351 - 998

SS Norway


Component

Boiler 23, Upper drum

Inspection result after repair



RN1



RN2

Distance from →

Wall thickness [mm]

	RN-1	RN2
0 o'clock	54,9	56,0
3 o'clock	52,5	53,6
6 o'clock	55,2	52,3
9 o'clock	54,5	52,7

RN1: No crack indications

RN2: No crack indications

Vordruck  
Ausgabe

Erection division

Date

24.1.91

Signature

J. E. Schen

Date

Signature

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

CERTIFIED TO BE A TRUE COPY

*[Signature]* p. 480 f. 69



Kennwort :  
Code word : **SS Norway**  
Kom. : Blatt : Pos. :  
Job. : **94-8351-998** Sheet : Item :

AK-Nr.:  
Plant identification No.:

Gegenstand : **Wasser drum Boiler 23**  
Subject : **Obertrommel Kessel 23**

System:  
System:

Bauteil :  
Component :

Abmessung :  
Dimension :

Fabr.-Nr.:  
Fabrication No.:

Zeichn.-Nr. :  
Drawg.-No. : **s. Kesselübersicht**

Schweißverfahren : **E**  
Welding process : **STAW**

KE-Nr.:  
Bgr.: TE:  
Ass: Term unit:

Prüflflächenzustand / Nahtoberfläche : **geschliffen**  
Surface condition of test area / Surface of seam : **ground**

Prüfung nach :  
Test according to : **HP5/3**

Wärmebehandlung :  
Heat treatment : vor  nach  keine   
before after no

Beurteilung durch :  
Evaluation by : **DB**

Prüfung an :  
Test on : Grundwerkstoff  Schweißkante  Schweißnaht   
Base material Weld edge Weld seam

MAGNETPULVERPRÜFUNG nach : **DIN 54130**  
MAGNETIC particel test acc. to

Testkörper:  
Testbody : **Beithold**

Prüfgerät:  
Test equipment : **Tiede TWM 42 V**

Stromstärke:  
Current intensity:

Prüfmittel:  
Medium for testing : **Peters MP205**

Magnetisierungsart:  
Kind of magnetization : **JEW**

naß / trocken  
wet / dry  
fluoreszierend: ja / nein  
fluorescent: **yes / no**

Kontrastmittel:  
Medium of contrast : **Peters MP204**  
Tangentialfeldstärke:  
Tangential field intensity: **4.0** KA/m

Pos. / Item or Naht-Nr. Weld-No.	Gesamstückzahl Total Quantity	Prüfmenge % Testvolume	geprüfte Stückzahl tested quantity	Abmessung Dimension [ mm ]	Werkstoff Material	Beurteilung / evaluation		
						erfüllt satisfactory	erfüllt satisfactory	nicht erfüllt not satisfactory
RN1	1	100	1	Lip 1614 x 104 / 156	~ 19Mn5		X	
RN2	*	*	*	*	*		X	
LN1	*	*	*	*	*		X	
LN2	*	*	*	*	*		X	

Bemerkungen :  
Remarks : **Endprüfung test after repair**

Ort : **Bremerhaven** den. : **30.09.90** Sachverständiger :  
Place : dated : Expert :

Prüfer : **Schiller** Prüfaufsicht : **S.L. (ZF)**  
Operator : Test Supervision :

Code

Job No.



94-8351-998

SS Norway

Component

Boiler 23, lower drum

Inspection result before repair



RN1

RN2

o →

Distance from o →  
[mm]

Wall thickness [mm]

	Wall thickness [mm]	
	LN 1	LN 2
0 o'clock	35,4	35,2
2500 o'clock	36,5	36,5
4800 o'clock	35,1	34,5

LN1: 0-2250 mm

2250-4090 mm

4090 - RN 2

LN2: 17 areas with crack-like indications, distributed over the full length. The areas are 20-100 mm long.

4 crack areas 30 to 50 mm long

Continuously small crack-like indications.

1 point with crack-like indication

Vordruck  
Ausgabe

Erection division

Date  
24.1.91

Signature

J. Bohau

Date

Signature

CERTIFIED TO BE A TRUE COPY

of ce 27 p 50 of 69

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Code

Job No.


94-8351-998

SS Norway


Component

Boiler 23, lower drum

Inspection result before repair



RN1



RN2

Distance from  $\rightarrow$

Wall thickness [mm]

	RN1	RN2
0 o'clock	37,2	38,9
3 o'clock	36,4	37,1
6 o'clock	38,0	34,5
9 o'clock	38,0	35,4

RN1: 11 o'clock } Pits with indications  
7 to 9 o'clock }

RN2: 6 to 7 o'clock } Pits with indications  
11 to 5 o'clock }

Verdruck  
Ausgabe

Erection division

Date

24.1.77

Signature

*F. Zocher*

Date

Signature

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

CERTIFIED TO BE A TRUE COPY

*[Signature]* P. 51 OF 69

Code

Job No.



94 - 8351 - 998

SS Norway

Component

Boiler 23, lower drum

Inspection result after repair



RN1  
 0 →

RN2

Distance from 0 →  
 [mm]

Wall thickness [mm]

Distance from 0 → [mm]	Wall thickness [mm]	
	LN1	LN2
2500	> 34,1	
3500		> 32,0

LN1: No crack indications

LN2: No crack indications

Vordruck  
 Ausgabe

Erection division

Date

24. 1. 91

Signature

J. Böhm

Date

Signature

CERTIFIED TO BE A TRUE COPY

*[Handwritten signature]* p. 520 F 69

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Code

Job No.


94-8351-998

SS Norway


Component

Boiler 23, Lower Drum

Inspection result after repair



RN1



RN2

Distance from $\rightarrow$	Wall thickness [mm]	
	RN-1	RN2
4 o'clock		> 32,0
7 o'clock	> 31,7	> 31,8

RN1: No crack indications

RN2: No crack indications

Vordruck  
Ausgabe

Erection division

Date

24.1.91

Signature

J. Petersen

Date

Signature

CERTIFIED TO BE A TRUE COPY

253 p. 53 of 69

**BABCOCK**

**OBERFLÄCHENRISSPRÜFUNG  
SURFACE CRACK TEST**

Besch.-Nr.:  
Certif.-No.: **52**  
Blatt: 1 von  
Sheet: 1 of

Kennwort :  
Code word : **SS Norway**  
Korn. : Blatt  
Job. : **94-8351-998** Sheet :

AK-Nr.:  
Plant identification No.:

Gegenstand : **lower drum Boiler 23**  
Subject : **Untertrommel Kessel 23**

System:  
System:

Bauteil :  
Component :  
Abmessung :  
Dimension :

Fabr.-Nr.:  
Fabrication No.:

Zeichn.-Nr. :  
Drawg.-No. : **5. Kesselübersicht**  
Schweißverfahren : **E**  
Welding process : **SMAW**

KE-Nr.:  
Bgr.: TE:  
Ass.: Term unit:

Prüfflächenzustand / Nahtoberfläche : **geschliffen**  
Surface condition of test area / Surface of beam : **ground**  
Prüfung nach : **HP 5/3**  
Test according to

Wärmebehandlung : vor  nach  keine   
Heat treatment : before after no  
Beurteilung durch : **DB**  
Evaluation by

Prüfung an : Grundwerkstoff  Schweißkante  Schweißnaht   
Test on : Base material Weld edge Weld seam

MAGNETPULVERPRÜFUNG nach: **Din. 54130** Testkörper:  
MAGNETIC particle test acc. to Testbody: **Berthold**

Prüfgerät: **Tiede TWM 42V** Stromstärke:  
Test equipment: Current intensity:  
Prüfmittel: **Peters MP205** Magnetisierungsart:  
Medium for testing: Kind of magnetization: **JEW**  
naß / trocken Kontrastmittel:  
wet / dry Medium of contrast: **Peters MP204**  
fluoreszierend: ja / nein Tangentialfeldstärke:  
fluorescent: yes / no Tangential field intensity: **KA/m**

Pos. / Item or Naht-Nr. Weld-No.	Gesamtstückzahl Total Quantity	Prüflänge Test volume %	geprüfte Stückzahl tested quantity	Abmessung Dimension [ mm ]	Werkstoff Material	Beurteilung / evaluation			
						erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory
<b>RN1</b>	<b>1</b>	<b>100</b>	<b>1</b>	<b>Lip 1030 x 7936</b>	<b>~ 19Mn4</b>			<b>X</b>	
<b>RN2</b>	"	"	"	"	"			<b>X</b>	
<b>LN1</b>	"	"	"	"	"			<b>X</b>	
<b>LN2</b>	"	"	"	"	"			<b>X</b>	

Bemerkungen : **Endprüfung Test after repair**  
Remarks :

Ort : **Bremerhaven** den : **30.09.90** Sachverständiger :  
Place : dated : Expert :

Prüfer : **Schiller** Prüfaufsicht : **[Signature]**  
Operator: Test Supervision: **[Signature]**

CERTIFIED TO BE A TRUE COPY  
**[Signature]** P.54 of 69

Code

Job No.



94 - 8351 - 998

SS Norway

Component

Boiler 23, lateral drum

Inspection result before repair



RN1  
o→

RN2

Distance from o→ [mm]	Wall thickness [mm]	
	LN1	LN2
1500	21,6	21,8
1800	21,4	-
2000	17,5	19,6
2500	18,2	20,6
3000	19,5	18,3
3500	19,3	19,4
4000	19,9	23,5
4500	22,1	-

LN1: 1000 - 3000 mm crack-like indications

LN2: 4 to 5 crack-like indications 8 to 10 mm long distributed over the full length.

⊗ After grinding out the crack indications.

Reproduction, even in an abridged form, only permitted with the approval of DEW AG

Verdruck  
Ausgabe

Erection division

Date

24.1.91

Signature

J. Böhm

Date

Signature

CERTIFIED TO BE A TRUE COPY

de 50 p. 55 of 69

Code

Job No.


94 - 8351 - 998

SS Norway


Component

Boiler 23, Lateral drum

Inspection result before repair



RN1



RN2

Distance from  $\rightarrow$

Wall thickness [mm]

	RN1	RN2
0 o'clock	30,0	24,2
3 o'clock	28,5	25,5
6 o'clock	28,4	24,7
9 o'clock	28,6	24,8

RN1 + RN2 : No crack-like indications

Verdruck  
Ausgabe

Erection division

Date

25.1.91

Signature

*J. Becker*

Date


Signature



Kennwort- *SS Norway* Kom. Nr. *94-8351-998*

*Boiler 23 Lateral drum*  
*Kessel 23 Seitentrommel LNA*

Nachtr. 1 auch aufzuführen, ist nur mit Genehmigung der Deutschen Babcock Werke A.G., 47 Oberhausen, gestattet



*Stromausfall*  
*missing of current*

*Boiler 23 Lateral drum*  
*26.03.90 Kessel 23, Seitentrommel*  
 12 *oberlängsnaht / 1 Schweißnaht 1300 - ca 2800*  
*Upper long seam weld area 1300 - 2800 mm*

Vordr. 7a

<i>K. J. Koczonka</i>							
Datum		Datum	Unterschrift	Datum		Datum	Unterschrift

CERTIFIED TO BE A TRUE COPY

*Handwritten signature* p. 57 of 69

Kennwort-


SS Norway

Kom. Nr.

94-8351-998

Boiler 23 Lateral drum  
Kessel 23 Seitentrommel LN1

Nachtr. 1 auch mit Genehmigung der Deutschen Babcock Werke AG, 42 Oberhausen, erstellt



Ni Cr-Ni DIN  
**BABCOCK**  
Montage-Schweißtechnik

32m-a-18 86.5604

Boiler 23 Lateral drum  
27.09.90 Kessel 23 Seitentrommel

Ni Cr-Ni DIN

**BABCOCK**  
Montage-Schweißtechnik

obere Längsnaht 12 Schweißpaar 2800-4400 mm  
upper Longream weld area 2800-4400 mm

Vordr. 7a

S. 815	<p>7.9.90 Datum  Unterschrift</p>		<p>Datum _____ Unterschrift _____</p>		<p>Datum _____ Unterschrift _____</p>	

CERTIFIED TO BE A TRUE COPY

*Handwritten signature* p. 58 of 69

Code

Job No.



94 - 8351 - 998

SS Norway

Component

Boiler 23, lateral drum

Inspection result after repair



RN1  
0 →

RN2

Distance from 0 →  
[mm]

Wall thickness [mm]

	LN1	LN2
	1300	22,8
2000	22,7	
3000	23,7	
4000	24,0	

LN1: The area of 1300 to 4400 mm was rewelded and subsequently ground. Transitions of the weld heads are still visible

Surface crack test: No defects detected.

Vordruck

Ausgabe

Erection division

Date

22.1.77

Signature

G. Becken

Date


Signature

CERTIFIED TO BE A TRUE COPY

fa 50 P. 59 of 69

Kennwort- *S.S. Norway* Kom. Nr. 94-8351-998

*Boiler 23 Lateral drum  
 Kessel 23 Seitentrommel L.N.2*



Vordr. 7a

Nachdr. 7a


<i>M. J. ...</i>			
Datum	Unterschrift	Datum	Unterschrift

Kennwort- *SS Norway*

Kom. Nr. 94-8351-998

*Boiler 23 Lateral drum  
Kessel 23 Seitentrommel LN2*

Nachrichtlich durch Auftragnehmer, ist nur mit Genehmigung der "Deutsche Babcock Werke AG", 42 Oberhausen, gestattet



Ni Cr-Ni DIN  
**BABCOCK**  
Montage-Schweißtechnik

32m-a-18 86.5604

*Boiler 23 Lateral drum  
26.03.90 Kessel 23, Seitentrommel  
17 untere Längsnaht 1/2 Schweißzug. etc.  
lower long seam weld area 2300 - 3700 mm*

Ni Cr-Ni DIN  
**BABCOCK**  
Montage-Schweißtechnik  
3300-3700

Vordr. 7a

*H. J. Wocinski*  
Datum



Datum

Unterschrift

Datum

Unterschrift

CERTIFIED TO BE A TRUE COPY

*Handwritten signature and page number: p. 61 of 69*

Code

Job No.


94-8351-998

SS Norway

Component


Boiler 23, Lateral drum

Inspection result after repair



RN1  
o→

RN2



Distance from o→  
[mm]

Wall thickness [mm]

	LN 2	
	LN 1	LN 2
900		23,6
1500		22,4
2000		23,0
2700		21,4
3000		21,2
3700		21,6

LN 2: The area of 900 to 3700mm was rewelded and subsequently ground. Transitions of the weld beads are still visible.

Surface crack test: No defects detected.

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Vordruck  
Ausgabe

Erection division

Date

25.1.97

Signature

J. Becker

Date

Signature

CERTIFIED TO BE A TRUE COPY

2/250 p. 62 of 69

Code

Job No.


94-8351-998

SS Norway


Component

Boiler 23, lateral drum

Inspection result after repair



RN1



RN2

Distance from  $\rightarrow$

Wall thickness [mm]

	RN1	RN2
6 o'clock	> 28,0	> 23,9

RN1 + RN2: No crack-like indications

Reproduction, even in an abridged form, only permitted with the approval of DBW AG

Vordruck

Ausgabe

Erection division

Date  
25.1.91

Signature

*G. Becker*

Date

Signature

CERTIFIED TO BE A TRUE COPY

*Yes, p. 63 of 69*

BABCOCK

HÄRTEPRÜFUNG  
HARDNESS TEST

Besch.-Nr.:  
Certif.-No.: 62  
Blatt von  
Sheet of

Kennwort:  
Code word: SS Norway  
Kon.:  
Job.: 94-8351-998 Blatt: \_\_\_\_\_ Pos.: \_\_\_\_\_  
Sheet: \_\_\_\_\_ Item: \_\_\_\_\_

AK-Nr.:  
Plant Identification No.:  
System:  
System:

Gegenstand: Lateral drum Boiler 23  
Subject: Seitentrommel Kessel 23

Fabr.-Nr.:  
Fabrication No.:

Teil:  
Component: LN 2

KE-Nr.:  
Bgr.: TE:  
Ass.: Term. unit:

Zeichn.-Nr.:  
Drawg.-No.: s. Kesselübersicht Wärmebehandlung Heat treatment ja  nein   
yes  no

Prüflächenzustand/Nahtoberfläche:  
Surface Condition of test area/Surface of seam: geschliffen ground Schweißverfahren: E-Hand  
Scope of Test:

Prüfung nach:  
Test according to: Din 50150 Prüfvolumen: Stichprobe  
Test volume:

Prüfgerät:  
Test app.: Equotip Prüflast:  
Test load:

Bemerkungen:  
Notes:

Pos. Item	Naht-Nr. Weld-No.	Abmessung Dimension	Werkstoff Material	Bemerkungen Notes
	<u>LN 2</u>	<u>Lip 694x 50/24</u>	<u>≈ 19 Mn 4</u>	

Prüfresultat in HV / Examination result in HV


Pos. Item	Grundwerkstoff Base metal	Übergangszone Transition zone	Schweißnaht Weld seam	Pos. Item	Übergangszone Transition zone	Grundwerkstoff Base metal
<u>LN 2</u>	<u>175 HB</u>	<u>/ / /</u>	<u>183 HB</u>		<u>/ / /</u>	<u>170 HB</u>

Ort: Bremerviken den 30.09.90 Sachverständiger:  
Place: dated Expert:  
Prüfer: Schiller Prüfaufsicht: LI 1117E  
Operator: Test Director:

CERTIFIED TO BE A TRUE COPY

W. J. O. P. 64 9 F 69



<b>BABCOCK</b>		<b>OBERFLÄCHENRISSPRÜFUNG SURFACE CRACK TEST</b>		Besch.-Nr.: 63 Certif.-No.:					
Kennwort : <i>SS Norway</i> Code word :		Blatt : 1 von 1 Sheet : 1 of		AK-Nr.: Plant identification No.:					
Kom. : <i>94-8351-998</i> Job. :		Blatt : Sheet :		System:					
Gegenstand : <i>seitentrommel Kessel 23</i> Subject : <i>lateral drum boiler</i>		Abmessung : Dimension :		Fabr.-Nr.: Fabrication No.:					
Bauteil : Component :		Schweißverfahren : <i>E</i> Welding process : <i>SAW</i>		KE-Nr.: Bgr.: TE: Ass.: Term unit:					
Zeichn.-Nr. : <i>s. Kesselübersicht</i> Drawg.-No. :		Prüfung nach : <i>HP 5/3</i> Test according to							
Prüflächenzustand / Nahtoberfläche : <i>geschliffen</i> Surface condition of test area / Surface of seam		Beurteilung durch : <i>DB</i> Evaluation by :							
Wärmebehandlung : Heat treatment :		Schweißkante : <input checked="" type="checkbox"/> Weld edge		Schweißnaht : <input checked="" type="checkbox"/> Weld seam					
Prüfung an : Test on :		Grundwerkstoff : <input type="checkbox"/> Base material							
MAGNETPULVERPRÜFUNG nach : <i>Din 54130</i> MAGNETIC particle test acc. to		Testkörper : <i>Beithold</i> Testbody :							
Prüfgerät : <i>Tiede TWM 42 V</i> Test equipment :		Stromstärke : Current intensity :							
Prüfmittel : <i>Peters MP 205</i> Medium for testing :		Magnetisierungsart : <i>JEW</i> Kind of magnetization :							
naß / trocken wet / dry		Kontrastmittel : <i>Peters MP 204</i> Medium of contrast :							
fluoreszierend : <i>ja / nein</i> fluorescent : <i>yes / no</i>		Tangentialfeldstärke : <i>4.0</i> KA/m Tangential field intensity :							
Pos. / Item or Naht-Nr. Weld-No.	Gesamtstückzahl Total Quantity	Prüflänge % Test volume	geprüfte Stückzahl tested quantity	Abmessung Dimension [ mm ]	Werkstoff Material	Beurteilung / evaluation			
						erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory	erfüllt satisfactory
<i>RN1</i>	<i>1</i>	<i>100</i>	<i>1</i>	<i>Lip 694 x 50/24</i>	<i>~ 19 Mn 4</i>			<input checked="" type="checkbox"/>	
<i>RN2</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>			<input checked="" type="checkbox"/>	
<i>LN1</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>			<input checked="" type="checkbox"/>	
<i>LN2</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>	<i>"</i>			<input checked="" type="checkbox"/>	
<i>Test after repair</i>									
Bemerkungen : <i>Endprüfung n. d. Schweißen</i> Remarks :									
Ort : <i>Bremerhaven</i> Place :		den : <i>30.09.90</i> dated :		Sachverständiger : Expert :					
Prüfer : <i>Schiller</i> Operator :		Prüfaufsicht : <i>Sell</i>  Test Supervision :							

91-2972 5.87

CERTIFIED TO BE A TRUE COPY

*L. J. S. p. 65 of 69*