

Docket No. SA-534

Exhibit No. 2-AE

NATIONAL TRANSPORTATION SAFETY BOARD

Washington, D.C.

NTSB_019-002

PROVIDE A LIST OF TRANSMISSION LINES WITH
CORRESPONDING MAOP'S IN SAN BRUNO

(1 Pages)

**PACIFIC GAS AND ELECTRIC COMPANY
San Bruno Gas Transmission Line Incident
Data Response**

PG&E Data Request No.:	NTSB_019-002		
PG&E File Name:	San Bruno GT Line Incident_DR_NTSB_019-002		
Request Date:	September 22, 2010	Requesting Party:	NTSB
Date Sent:	October 1, 2010	Requestor:	NTSB (Rick Downs)

QUESTION 2

Provide a list of transmission lines with corresponding MAOP's in San Bruno.

ANSWER 2

Pipelines L-132, L-109 and L-101 located in San Bruno have MAOP's 400 psig, 375 psig and 275 psig respectively.