

REPORT OF ANALYSIS

Certificate Number: CERT - 19810

June 4, 2017


Customer Name: Airport Aviation Services, Inc.
 Contact: Brian Ramirez
 Customer Address: Santana Ave. 575 Central Sector, Base Muñiz
 Carolina PR 00983
 Phone/Fax: 787-791-8500
 Project Name: Quality Test
 Reference Number: N/A
 Product Name: AV GAS
 Sampled By: Nehemias Hernandez

Sampled Date: Sunday, June 4, 2017
 Sampled Time: 0915 hrs.
 Received Date: Sunday, June 4, 2017
 Received Time: 1110 hrs.
 Custody Number: P 40822
 Lab. Sample Number: AT-17-5138
 Tank Number: TK R 03
 Sample Location: Base Muñiz, Carolina

Test	Units	Method	Result	Specification
API Gravity (Hydrometer Method)	*API @ 60°F	ASTM D1298-12b	64.0	---
Distillation	---	---	---	---
Final Boiling Point	°C	ASTM D86	153.3	170
Loss	%	ASTM D86	0.6	1.5
Distillation - Recovery	%	ASTM D86	98	97
Residue	%	ASTM D86	1.2	1.5
Distillation at 10 %	°C	ASTM D86	70.0	75
Distillation at 20 %	°C	ASTM D86	84.4	---
Distillation at 50 %	°C	ASTM D86	102.2	105
Distillation at 90 %	°C	ASTM D86	113.3	135
Initial Boiling Point	°C	ASTM D86	37.8	Report

We certify that this product complies with ASTM 910-15 for the parameters tested.

Saira Vázquez Baez
 Laboratory Operations Director
 Licensed Chemist #5471



Saira Vázquez Baez
 June 4, 2017
 A 1622150