

PETRO MARINE SERVICES

Petroleum Marketing to the Marine Industry

I pulled two samples of 100LL Av Gas from Homer Air's fuel truck on the 24th of August 2010 for testing. One sample from the dispensing hose and one sample directly from the tank. The tests are as follows.....

Hose sample.

Blue – clear and bright

0 water and 0 sediment

A.P.I. 64 at 54 degrees F.

A.P.I. adjusted to 60 degrees F. (64.8)

Tank sample.

Blue – clear and bright

0 water and 0 sediment

A.P.I. 64 at 54 degrees F.

A.P.I. adjusted to 60 degrees F. (64.8)

Tested at 9:30 A.M. 8/25/10

Rod Mclay

Plant Foreman



4755 Homer Spit Road • Homer, Alaska 99603

A HARBOR ENTERPRISES COMPANY