

33 7/8

JET TRUCK FUEL SHEET

MASTER

SUMPED BY: CL
 DATE: 3-31-12
 TRUCK#: Jet-A

LFT METER START: 200158
 RT METER START: ~~000~~ 553035

BEGINNING FUEL BALANCE 625

INVOICE#	CARD#	A/CTYPE	REG#	L.METER START	L.METER END	R.METER START	R.METER END	GAL SOLD	TYPE OIL	QTS.	INIT.	SVC TIME	FUEL BAL
111793	Wejete	Comp Air	5485F	158	310	035	-	152	-		CL	1140	
111798		Meridian	715LM	310	371	035	-	61	-		CL		
		Fuel Transfer				1543							3000

Storage Facility Inspection Record



Facility Name: **KCOI** Month: **March 12** Tank No.: **JETA** Product: **JETA** Capacity: **12,000**

Requirements	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Daily (Use Applicable Markings)	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S
Condition of Tank Yard	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S
Fuel Leaks	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S
Storage Tank Sump (Record Findings)	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	
Filter Sump (Record Findings-See Rating)	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	1A	
Filter Differential Pressure (Record DP)	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	
Filter Flow Rate (Record actual gpm)	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	
Hoses, Swivels, Nozzles & Dust Caps	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	
Bonding Cables, Clamps & Reels	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S
Fire Extinguishers	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S
Initials	AE	CL	AE	AE	CL	CL	CL	AE	AE	AE	AE	CL	CL	AE	AE	AE	AE	AE	CL	CL	CL	AE	CL	CL	AE	CL	CL	CL	AE	AE	CL

Monthly	Markings	Date	Initials
Filter Membrane Color Test (Jet Only)			
Bonding Cable Continuity			
Hose Pressure Test			
FSII Concentration (.1 - .15%)			
Nozzle Screens - Clean and Inspect			
Piping Low Points			
Signs, Placards, and Product Labeling			
Fuel Emergency Shut-Off System			
Vents, Hatches, and Floating Suction			
Water test - 15ppm maximum (jet fuel only)			

Rating Of Sump Samples	
Solids	Water
1 = Clear	A = Bright
2 = Slight	B = Hazy
3 = Particulate	C = Cloudy
4 = Dirty	D = Wet

Markings
S = Satisfactory
C = Comment
N/U = Not Used
N/A = Not Applicable

Comments:

Reviewed By: