

Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
1			10013986	1	BODY	PIT	EXCR	Plastic, 5/8 inch Service Replacement	LISCO	Replace,Service,6409 Joppa Court	2003	2: GRADE 2 LEAK	3/25/2003	Service	SADDLE-SERVICE 2-1/4 CI X 3/4; TEE 3/4 X 5/8 OD SCRW BS X COMP OUT STL		
2			10017190	2	BODY	PIT	EXCR	Cast Iron, 2-1/4 inch Main	GCALVERT	Repair,Main,7508 64th Courtway South	2004	2: GRADE 2 LEAK	4/16/2003	Main			
3			10036096	1	BODY	PIT	EXCR	Steel, 1 inch Service Maintenance	DISPATCH	Repair,Service,7510 Georgia Road	2003	2: GRADE 2 LEAK	9/9/2003	Service			
4			10064603	1	BODY	PIT	EXCR	Steel, 1 inch Service Maintenance	PUBLIC	Repair,Leak,6414 Kimberly Avenue U87	2004	2: GRADE 2 LEAK	4/21/2004	Service	WRAP-PIPE 2 X 75 FT COLD APPLIED H-35-G; MASTIC-PIPE, 1 GALLON, TAPECOAT, COLD AP; CLAMP-REPAIR 1 X 6 SMITH/BLAIR 245 STL		
5			10068540	1	BODY	PIT	EXCR	Cast Iron, 2 inch Main	PUBLIC	Repair,Leak,7508 Georgia Road	2004	2: GRADE 2 LEAK	5/18/2004	Main			
6			10076367	1	BODY	PIT	EXCR	Steel, 1 inch Service Maintenance	PUBLIC	Repair,Service,7580 66th Street South	2004	2: GRADE 2 LEAK	7/22/2004	Service			
7			10085148	1	BODY	PIT	EXCR	Steel, 1 inch Service Maintenance	PUBLIC	Repair,Service,7532 66th Courtway South	2004	2: GRADE 2 LEAK	10/14/2004	Service			
8			10096361	3	BODY	PIT	CORR	Cast Iron, 2-1/4 inch Main	PUBLIC	Repair,Main,6505 Interlaken Avenue	2005	2: GRADE 2 LEAK	1/14/2005	Main	MASTIC-PIPE, 1 GALLON, TAPECOAT, COLD AP		
9			10096361	2	BODY	PIT	EXCR	Cast Iron, 2-1/4 inch Main	PUBLIC	Repair,Main,6505 Interlaken Avenue	2005	2: GRADE 2 LEAK	1/14/2005	Main	MASTIC-PIPE, 1 GALLON, TAPECOAT, COLD AP		
10			10098027	1	BODY	WEAR	OTHE	Steel, 1 inch Service Maintenance	PUBLIC	Repair,Service,7580 66th Street South	2005	2: GRADE 2 LEAK	1/24/2005	Service			
11			10101099	2	BODY	INSP	OTHE	Steel, 3/4 inch Service Maintenance	PUBLIC	Repair,Service,7552 67th Court Way	2005	2: GRADE 2 LEAK	2/8/2005	Service			
12			10101099	1	BODY	PIT	CORR	Steel, 3/4 inch Service Maintenance	PUBLIC	Repair,Service,7552 67th Court Way	2005	2: GRADE 2 LEAK	2/8/2005	Service			
13			10101099	3	BODY	INSP	OTHE	Steel, 3/4 inch Service Maintenance	PUBLIC	Repair,Service,7552 67th Court Way	2005	2: GRADE 2 LEAK	2/8/2005	Service			
14			10101589	1	JONT	WEAR	OTHE	Cast Iron, 2-1/4 inch Main	EMPLOYEE	Repair,Main,6611 Interlaken Avenue U303	2005	2: GRADE 2 LEAK	2/17/2005	Main			
15			10101589	2	BODY	INSP	OTHE	Cast Iron, 2-1/4 inch Main	EMPLOYEE	Repair,Main,6611 Interlaken Avenue U303	2005	2: GRADE 2 LEAK	2/17/2005	Main			
16			10111009	1	BODY	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	B. GOLDEN	Repair,Service,6857 Joppa Avenue U431	2005	2: GRADE 2 LEAK	4/30/2005	Service	CLAMP-REPAIR 1-1/2 X 6 244 S/B REDI STL		
17			10113454	1	BODY	BROK	OTHE	Steel, 1 inch Service Maintenance	PUBLIC	Abandon,Service,6424 Kimberly Avenue	2005	1: GRADE 1 LEAK	5/14/2005	Service	COUPLING-MECHANICAL-STAB 1 CTS BLIND-END		
18			10113454	2	TEE	NONE	OTHE	Steel, 1 inch Service Maintenance	PUBLIC	Abandon,Service,6424 Kimberly Avenue	2005	1: GRADE 1 LEAK	5/14/2005	Service	COUPLING-MECHANICAL-STAB 1 CTS BLIND-END		
19			10113864	1	BODY	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	PUBLIC	Repair,Service,6642 Joppa Avenue	2005	2: GRADE 2 LEAK	5/18/2005	Service	CLAMP-REPAIR 1-1/4 X 6 FOR STL S/B		
20			10122017	1	RISR	BROK	OOFD	Steel, 1 inch Service Maintenance	PUBLIC	Repair,Service,7542 67th Court Way South	2005	1: GRADE 1 LEAK	7/26/2005	Service	COUPLING-MECHANICAL-STAB 1/2 CTS (5/8 OD); COUPLING-MECHANICAL-STAB 3/4 IPS X 1/2 CTS; COUPLING-MECHANICAL-STAB 3/4 IPS X 12 REPAIR; RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK		
21			10144018	1	RISR	WEAR	MAWE	Steel, 1 inch Service Maintenance	PUBLIC	Repair,Riser,6840 Kimberly Avenue U427	2006	2: GRADE 2 LEAK	1/12/2006	Service			
22			10149103	1	BODY	BROK	NATF	Cast Iron, 2 inch Main	JONE	Repair,Main,7554 67 Courtway South	2006	1: GRADE 1 LEAK	2/13/2006	Main	CLAMP-REPAIR 2-1/4 X 12-1/2 225 CI 100 PSI		
23			10149319	1	JONT	INSP	OTHE	Cast Iron, 4 inch Main	TUCKER	Repair,Main,6816 Kimberly Avenue	2006	2: GRADE 2 LEAK	2/14/2006	Main			
24			10162460	1	BODY	PIT	CORR	Cast Iron, 2-1/4 inch Main	PUBLIC	Repair,Main,7525 66th Street South	2006	2: GRADE 2 LEAK	5/23/2006	Main			
25			10177363	1	BODY	BROK	NATF	Cast Iron, 2 inch Main	PUBLIC	Repair,Main,6416 Madrid Avenue	2006	2: GRADE 2 LEAK	9/20/2006	Main			
26			10180539	2	BODY	WEAR	CORR	Cast Iron, 4 inch Main	PUBLIC	Repair,Leak,7534 66th Street South	2006	2: GRADE 2 LEAK	10/19/2006	Main			
27			10183640	1	TEE	PIT	CORR	Steel, 1 inch Service Maintenance	BJONES	Repair,Service,7520 66th Street South	2006	2: GRADE 2 LEAK	11/18/2006	Service			
28			10186739	3	TEE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	EMPLOYEE	Repair,Service,6710 Joppa Avenue	2006	1: GRADE 1 LEAK	12/20/2006	Service	RISER-SERVICE 3/4 MPTX 3/4 IPS W/CPG & VALVE; RISER-SERVICE 3/4 MPTX1/2 CTS PGTL SERVICE CK		
29			10186739	2	TEE	WEAR	CORR	Steel, 1-1/4 inch Service Maintenance	EMPLOYEE	Repair,Service,6710 Joppa Avenue	2006	1: GRADE 1 LEAK	12/20/2006	Service	RISER-SERVICE 3/4 MPTX 3/4 IPS W/CPG & VALVE; RISER-SERVICE 3/4 MPTX1/2 CTS PGTL SERVICE CK		
30			10186739	1	TEE	NONE	CORR	Steel, 1-1/4 inch Service Maintenance	EMPLOYEE	Repair,Service,6710 Joppa Avenue	2006	1: GRADE 1 LEAK	12/20/2006	Service	RISER-SERVICE 3/4 MPTX 3/4 IPS W/CPG & VALVE; RISER-SERVICE 3/4 MPTX1/2 CTS PGTL SERVICE CK		
31			10188430	1	TEE	BROK	NATF	Cast Iron, 2 inch Main	PUBLIC	Repair,Main,7522 Joppa Avenue	2007	2: GRADE 2 LEAK	1/12/2007	Main			
32			10198254	1	TEE	WEAR	CORR	Steel, 1 inch Service Maintenance	JNIVENS	Repair,Service,7520 66th Street South	2007	1: GRADE 1 LEAK	3/5/2007	Service			
33			10239933	1	TEE	PIT	CORR	Plastic, 5/8 inch Service Replacement	AWALKER	Replace,Service,6704 Joppa Avenue	2008	2: GRADE 2 LEAK	1/4/2008	Service	RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK; SADDLE-SERVICE 4 X 3/4 CI		
34			10243199	1	BODY	BROK	EXCA	Cast Iron, 2-3/4 inch Main	PUBLIC	Repair,Main,6507 interlaken avenue	2008	2: GRADE 2 LEAK	1/23/2008	Main			
35			10243271	1	BODY	WEAR	CORR	Cast Iron, 2 inch Main	PUBLIC	Repair,Main,6502 Interlaken Avenue	2008	2: GRADE 2 LEAK	1/24/2008	Main			
36			10243428	1	TEE	PIT	CORR	Plastic, 5/8 inch Service Maintenance	PUBLIC	Replace,Service,6502 Interlaken Avenue	2008	2: GRADE 2 LEAK	1/24/2008	Service			
37			10256285	1	TEE	BROK	EXCA	Steel, 3/4 inch Service Retirement	PUBLIC	Retire,Service, 68th PI S/Kimberly Ave	2008	1: GRADE 1 LEAK	4/30/2008	Service			
38			10277806	1	BODY	PIT	CORR	Cast Iron, 2 inch Main	JJOHNSON	Repair,Main,7416 67th Street South	2008	2: GRADE 2 LEAK	10/16/2008	Main			
39			10277806	2	BODY	PIT	CORR	Cast Iron, 2 inch Main	JJOHNSON	Repair,Main,7416 67th Street South	2008	2: GRADE 2 LEAK	10/16/2008	Main			
40			10282318	1	BODY	BROK	NATF	Cast Iron, 2 inch Main	PUBLIC	Repair,Main,6505 Interlaken Avenue	2008	2: GRADE 2 LEAK	11/21/2008	Main			
41			10301787	1	FITG	WEAR	EQUI	Cast Iron, 6 inch Main	EMPLOYEE	Repair,Main,7700 Georgia Road	2010	2: GRADE 2 LEAK	4/23/2009	Main	SADDLE-SERVICE 6 X 3/4 STL; SADDLE-SERVICE 8 X 3/4 CI		
42			10304240	1	TEE	PIT	CORR	Steel, 1 inch Service Maintenance	MHUDSON	Repair,Service,7570 Georgia Road U023	2010	2: GRADE 2 LEAK	5/18/2009	Service			
43			10305556	1	BODY	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	CLANE	Repair,Service,7515 64th Courtway South	2009	2: GRADE 2 LEAK	6/3/2009	Service	CLAMP-REPAIR 1-1/2 X 6 FOR STL S/B		
44			10315485	1	BODY	PIT	CORR	Cast Iron, 2 inch Main	EMPLOYEE	Repair,Main,Interlaken Avenue	2009	2: GRADE 2 LEAK	9/8/2009	Main			
45			10316641	1	JONT	WEAR	EQUI	Cast Iron, 6 inch Main	JETHERIDGE	Repair,Service,7517 Georgia Road	2009	2: GRADE 2 LEAK	9/16/2009	Main			
46			10317750	1	TEE	BROK	EXCA	Steel, 3/4 inch Service Maintenance	PUBLIC	Repair,Service,7811 Georgia Road	2009	1: GRADE 1 LEAK	9/29/2009	Service			
47			10318756	1	TEE	PIT	CORR	Plastic, 5/8 inch Service Maintenance	QCARTER	Repair,Service,7564 66th Courtway South	2009	2: GRADE 2 LEAK	10/12/2009	Service	TEE PLS MECHANICAL-STAB 1/2 CTS PLS TO PLS		
48			10324372	1	BODY	PIT	CORR	Cast Iron, 2-1/4 inch Main	PUBLIC	Repair,Service,7524 64th Courtway South	2009	2: GRADE 2 LEAK	11/18/2009	Main	CLAMP-REPAIR 2-1/4 X 12-1/2 225 CI 100 PSI		
49			10326430	1	RISR	WEAR	EQUI	Plastic, 3/4 inch Service Maintenance	METER READER	Repair,Service,6824 Kimberly Avenue U419	2009	2: GRADE 2 LEAK	12/13/2009	Service			
50			10329352	1	TEE	NONE	CORR	Steel, 1 inch Service Maintenance	JMCRAY	Repair,Service,7544 64th Courtway S U139	2010	1: GRADE 1 LEAK	1/11/2010	Service			
51			10329681	1	BODY	BROK	NATF	Cast Iron, 2 inch Main	KELLEY	Repair,Main,6416 Madrid Avenue	2010	1: GRADE 1 LEAK	1/13/2010	Main	CLAMP-REPAIR 2 X 7-1/2 225 STL/CI 100 PSI		
52			10331305	1	RISR	WEAR	EQUI	Steel, 1 inch Service Maintenance	LKELLEY	Repair,Service,7561 66th Street So, U214	2010	2: GRADE 2 LEAK	1/15/2010	Service			
53			10331393	1	BODY	BROK	NATF	Cast Iron, 6 inch Main	JMCCRAY	Repair,Main,7520 66th Street South	2010	1: GRADE 1 LEAK	1/17/2010	Main	CLAMP-REPAIR 6 X 7-1/2 S/B 225 STL/CI; CLAMP-REPAIR 6 X 7-1/2 S/B 225 STL/CI		
54			10331694	1	BODY	PIT	CORR	Steel, 1 inch Main	GIBSON,D.	Repair,Main,7544 65th Courtway South	2010	2: GRADE 2 LEAK	1/20/2010	Main			
55			10344603	1	RISR	WEAR	CORR	Steel, 1-1/4 inch Service Maintenance	CARTER	Repair,Service,6520 Joppa Court	2010	1: GRADE 1 LEAK	4/20/2010	Service			
56			10344643	1	RISR	NONE	EQUI	Steel, 3/4 inch Service Maintenance	BGRIGGS	Repair,Service,7547 64th Courtway South	2010	2: GRADE 2 LEAK	4/20/2010	Service			
57			10346611	1	RISR	WEAR	EQUI	Steel, 1-1/4 inch Service Maintenance	CARTER	Repair,Service,6520 Joppa Court	2010	1: GRADE 1 LEAK	5/11/2010	Service			
58			10347761	1	TEE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	EMPLOYEE	Repair,Service,6520 Joppa Court	2010	2: GRADE 2 LEAK	5/13/2010	Service			
59			10353830	1	RISR	WEAR	EQUI	Steel, 3/4 inch Service Maintenance	QCARTER	Repair,Service,7570 Georgia Road U023	2010	2: GRADE 2 LEAK	7/14/2010	Service	VALVE-SERVICE 1 INSULTLATED, 175 PSIG,T.E.A.		
60			10357392	1	TEE	PIT	CORR	Steel, 1 inch Service Maintenance	QCARTER	Repair,Service,6709 Interlaken Avenue	2010	2: GRADE 2 LEAK	8/15/2010	Service			
61			10358201	1	RISR	WEAR	EQUI	Steel, 1 inch Service Maintenance	EMPLOYEE	Repair,Service,6600 Joppa Avenue	2010	2: GRADE 2 LEAK	8/20/2010	Service			
62			10358603	1	RISR	WEAR	EQUI	Plastic, 5/8 inch Service Maintenance	BREWER	Repair,Service,7526 66th Street South	2010	2: GRADE 2 LEAK	8/26/2010	Service	RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK		
63			10362268	1	RISR	NONE	EQUI	Steel, 1 inch Service Maintenance	R.SMITH	Repair,Service,7561 67 Courtway South	2010	2: GRADE 2 LEAK	10/1/2010	Service	VALVE-SERVICE 1 INSULTLATED, 175 PSIG,T.E.A.		
64			10364762	1	RISR	WEAR	EQUI	Steel, 1 inch Service Maintenance	BGRIGGS	Repair,Service,7574 66th Courtway South	2010	2: GRADE 2 LEAK	10/21/2010	Service	COUPLING-MECHANICAL-STAB 1/2 CTS (5/8 OD); RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK; VALVE-SERVICE 1-1/2 NON-INSLTD 175 PSIG, T.E.A		
65			10368266	1	RISR	WEAR	EQUI	Plastic, 5/8 inch Service Maintenance	KMICHALICK	Repair,Service,6826 Joppa Avenue U470	2010	2: GRADE 2 LEAK	11/15/2010	Service			
66			10372430	1	CPLG	WEAR	EQUI	Steel, 2 inch Main	HUDSON	Repair,Main,6801 Joppa Avenue	2010	1: GRADE 1 LEAK	12/9/2010	Main			
67			10372765	1	JONT	WEAR	EQUI	Steel, 4 inch Main	THARGROVE	Repair,Main,6825 Joppa Ave	2010	2: GRADE 2 LEAK	12/10/2010	Main			
68			10375495	1	JONT	NONE	EQUI	Cast Iron, 2 inch Main	BJONES	Repair,Main,6505 Joppa Court	2011	2: GRADE 2 LEAK	1/2/2011	Main			
69			10375677	1	TEE	PIT	CORR	Steel, 1 inch Service Maintenance	RWALTON	Repair,Service,7538 67th Courtway South	2011	2: GRADE 2 LEAK	1/3/2011	Service			
70			10375787	1	TEE	WEAR	EQUI	Steel, 1 inch Service Maintenance	BGRIGGS	Repair,Service,6511 Joppa Court U195	2011	2: GRADE 2 LEAK	1/4/2011	Service			
71			10376295	1	BODY	BROK	NATF	Cast Iron, 2-1/4 inch Main	RMARTIN	Repair,Main,6425 Joppa Court	2011	1: GRADE 1 LEAK	1/11/2011	Main	CLAMP-REPAIR 2 X 7-1/2 225 STL/CI 100 PSI		
72			10376453	1	TEE	NONE	CORR	Steel, 3/4 inch Service Maintenance	EMPLOYEE	Repair,Service,6423 Joppa Court	2011	2: GRADE 2 LEAK	1/11/2011	Service			
73			10376901	1	BODY	BROK	NATF	Cast Iron, 2-1/4 inch Main	EMPLOYEE	Repair,Main,6426 Joppa Court	2011	1: GRADE 1 LEAK	1/11/2011	Main			
74			10379107	1	CPLG	WEAR	EQUI	Steel, 1 inch Main	RYMAN	Repair,Main,6511 Joppa Court	2011	1: GRADE 1 LEAK	1/21/2011	Main			
75			10400049	1	FITG	WEAR	EQUI	Steel, 3/4 inch Service Maintenance	PUBLIC	Repair,Service,6827 Interlaken Way	2011	1: GRADE 1 LEAK	7/8/2011	Service			
76			10400														

Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
77		1	10416662	1	BODY	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	LSOCROSS	6842 Kimberly Ave., 428	2012	2: GRADE 2 LEAK	10/22/2011	Service		"11/29/2011 11:37:17 LaVon Carter (LCARTER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI, CLMP-RPR 2-1/4 X 12-1/2 225 CI 100 PSI 0000 Grade 2 leak with 20% gas found by southern cross. 09/04/2012 15:43:06 Rochelle Holmes (RHOLMES) LASH Fixed corrosion leak on 1-1/2 M.W. trunk line fixed leak Job complete. 08/31/2012"	
78		2	10416686	1	BODY	INSP		Cast Iron, 4 inch Main	LSOCROSS	6809 Joppa Ave, U452	2012	2: GRADE 2 LEAK	10/26/2011	Main	CLMP-RPR 2-1/4 X 6 244 S/B REDI STL,CPLNG-MCH-STB 2 IPS,CPLNG-MCH-STB 2 IPS X 15-3/4 REPAIR	"11/29/2011 13:09:42 LaVon Carter (LCARTER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI 0000 Grade 2 leak with 60% gas found by southern cross. 09/17/2012 10:28:03 Rochelle Holmes (RHOLMES)  Holloman Bartest and found no gas or LEL. Job complete 09/15/2012 09/17/2012 10:34:15 Rochelle Holmes (RHOLMES)"	
79		3	10417747	1	PIPE	INSP	CORR	Steel, 3/4 inch Service Maintenance	LSOCROSS	6702 Joppa Ave, U362	2012	2: GRADE 2 LEAK	10/27/2011	Service		"12/08/2011 12:58:58 LaVon Carter (LCARTER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI, CLMP-RPR 2-1/4 X 12-1/2 225 CI 100 PSI 0000 Grade 2 leak with 20% gas found by southern cross. 08/31/2012 11:44:22 Rochelle Holmes (RHOLMES) Handley Investigated job found 30% gas at the foundation and service needed renewing. 08/30/2012 09/05/2012 09:51:02 Arthur Cheatham (ACHEATHA) Phone 2-1/4 X 12-1/2 225 CI 100 PSI 0000 Refer to order 30171208 for the renewal information. The job is complete."	
80		4	10417741	1	TEE	PIT	CORR	Cast Iron, 2-1/4 inch Main	LSOCROSS	Repair, Main 6414 Kimberly Ave, U087	2012	2: GRADE 2 LEAK	10/27/2011	Main	CLMP-RPR 2-1/4 X 12-1/2 225 CI 100 PSI, CLMP-RPR 2-1/4 X 12-1/2 225 CI 100 PSI		
81			10413565	1	RISR	NONE	EQUI	Steel, 3/4 inch Service Maintenance	CARTER	Repair,Service,7529 65th Courtway South	2011	2: GRADE 2 LEAK	10/29/2011	Service			
82		5	10413611	1	RISR	PIT	CORR	Steel, 1 inch Service Maintenance	LSOCROSS	Repair,Service,7538 67th Court Way South	2011	1: GRADE 1 LEAK	10/31/2011	Service			
83		6	10417742	1	RISR	WEAR	EQUI	Steel, 3/4 inch Service Maintenance	LSOCROSS	Repair, Service, 7518 Georgia Rd, U47	2012	2: GRADE 2 LEAK	11/1/2011	Service			
84		7	10456883	1	JONT	PIT	CORR	Cast Iron, 2-1/2 inch Main	SO CROSS	6427 U095 Joppa Ct Birmingham 35212	2012	Below Ground Grade 2	11/1/2011	Main			
85		8	10456883	2	PIPE	PIT	CORR	Cast Iron, 2-1/2 inch Main	SO CROSS	6427 U095 Joppa Ct Birmingham 35212	2012	Below Ground Grade 2	11/1/2011	Main			
86		9	10421020	1	TEE	WEAR	CORR	Steel, 1 inch Service Maintenance	LSOCROSS	6713 Interlaken Ave, U375	2012	2: GRADE 2 LEAK	11/5/2011	Main		"01/06/2012 11:46:07 LaVon Carter (LCARTER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI 0000 Grade 2 leak with 10% gas found by southern cross. 09/06/2012 12:39:27 Rochelle Holmes (RHOLMES)  Holloman We repaired a leak on the main. 09/05/2012"	
87		10	10421028	1	JONT	WEAR	NATF	Cast Iron, 2-1/4 inch Main	LSOCROSS	6707 Interlaken Ave, U365	2012	2: GRADE 2 LEAK	11/5/2011	Main		"01/06/2012 11:25:54 LaVon Carter (LCARTER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI 0000 Grade 2 leak with 40% gas found by southern cross. 09/06/2012 12:43:53 Rochelle Holmes (RHOLMES)  Robison We found leak in rear of 6713 on service line that feeds 6708 Joppa Av we renewed servie and wrote up capital ACC ticket. 09/04/2012"	
88		11	10421023	1	JONT	WEAR	NATF	Service Lines, Maintenance	LSOCROSS	6705 Interlaken Ave, U366	2012	2: GRADE 2 LEAK	11/5/2011	Service		01/06/2012 11:28:17 LaVon Carter (LCARTER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI 0000 Grade 2 leak with 30% gas found by southern cross. 09/06/2012 09:23:12 Rochelle Holmes (RHOLMES)  Robison This job was already completed by truck 665 on 09/04/12 we were on site with them. 09/05/2012	Job completed by truck 665 on notification 10421028 according to leak ticket
89			10419207	1	BODY	PIT	CORR	Cast Iron, 2-1/4 inch Main	GOLDEN	Repair,Main,7550 65th Courtway South	2011	1: GRADE 1 LEAK	12/15/2011	Main			
90			10431589	1	BODY	SPLT	NATF	Cast Iron, 2-1/4 inch Main	WILLIAMSON	Repair,Main,7521 66th Strret South	2012	2: GRADE 2 LEAK	3/15/2012	Main			
91			10431589	2	BODY	BROK	NATF	Cast Iron, 2-1/4 inch Main	WILLIAMSON	Repair,Main,7521 66th Strret South	2012	2: GRADE 2 LEAK	3/15/2012	Main			
92			10458253	1	PIPE	PIT	CORR	Steel, 2 inch Main	SO CROSS	7700 Georgia Rd Birmingham 35212	2013	Below Ground Grade 2	4/16/2012	Main			
93			10438578	1	TEE	PIT	CORR	Steel, 1 inch Service Maintenance	PUBLIC	Repair,Service,7529 64th Courtway South	2012	1: GRADE 1 LEAK	4/26/2012	Service			
94			10458226	1	PIPE	INSP	OTHE	Steel, 2 inch Service Maintenance	EMPLOYEE	7578 66th St S Birmingham 35212	2013	Below Ground Grade 2	7/5/2012	Service			
95			10458255	1	PIPE	INSP	OTHE	Steel, 2 inch Service Maintenance	EMPLOYEE	6425 Joppa Ct Birmingham 35212	2013	Below Ground Grade 2	7/11/2012	Service			
96			10450194	1	RISR	INSP	OTHE	Service Lines, Maintenance	PUBLIC	7527 64th Courtway S Birmingham 35212	2012	1: GRADE 1 LEAK	7/24/2012	Service			
97			10464097	1	JONT	WEAR	CORR	Steel, 2 inch Service Maintenance	EMPLOYEE	6811 Joppa Ave Birmingham 35212	2013	Below Ground Grade 2	1/3/2013	Service	COUPLING-MECHANICAL-STAB 1-1/4 IPS X 1 CTS		
98			10464097	2	JONT	WEAR	CORR	Steel, 2 inch Service Maintenance	EMPLOYEE	6811 Joppa Ave Birmingham 35212	2013	Below Ground Grade 2	1/3/2013	Service	COUPLING-MECHANICAL-STAB 1-1/4 IPS X 1 CTS		
99			10477739	1	PIPE	WEAR	CORR	Steel, 2 inch Service Maintenance	EMPLOYEE	7545 67th Courtway S Birmingham 35212	2013	Emergency Grade 1	10/24/2013	Service	CLAMP-REPAIR 2-1/4 X 12-1/2 225 CI 100 PSI		
100			10477739	2	PIPE	WEAR	CORR	Steel, 2 inch Service Maintenance	EMPLOYEE	7545 67th Courtway S Birmingham 35212	2013	Emergency Grade 1	10/24/2013	Service	CLAMP-REPAIR 2-1/4 X 12-1/2 225 CI 100 PSI		
101	1		10487213	1	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	EMPLOYEE	7515 64th Courtway S Birmingham 35212	2013	Below Ground Grade 2	12/17/2013	Service		03/20/2014 09:57:45 Debbie Barber (DBARBER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI XXXX Notification and Work order created to document work done on 12/17/2013.  Had 1 1/2" service with 2 corrosion leak fixed leaw with 1 6" by 1 1/2" repair clamp and 1 3" x 1 1/2" repair clamp. Job complete on 12/17/2013. 03/20/2014 10:31:11 Debbie Barber (DBARBER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI XXXX Crew id 578	
102	2		10487217	1	PIPE	WEAR	CORR	Steel, 1-1/4 inch Service Maintenance	EMPLOYEE	7523 64th Courtway S Birmingham 35212	2013	Below Ground Grade 2	12/17/2013	Service		03/20/2014 10:25:19 Debbie Barber (DBARBER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI XXXX Notification and Work order created to document work done on 12/17/2013.  Found fuzz leak on service cock, replaced. Job complete Crew 934	
103	3		10487215	1	MECH	WEAR	EQUI	Cast Iron, 2 Inch Main	EMPLOYEE	6425 Joppa Court Birmingham 35212	2013	Below Ground Grade 2	12/17/2013	Main		03/20/2014 10:13:59 Debbie Barber (DBARBER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI XXXX Notification and Work order created to document work done on 12/17/2013.  Found fuzz leak on wrap around on 2 1/4" CI main. Tightened wrap around to repair leak. Crew id 036.	
104	4		10487214	1	PIPE	WEAR	EQUI	Cast Iron, 2-1/4 inch Main	EMPLOYEE	7546 65th Ct S Birmingham 35212	2013	Below Ground Grade 2	12/17/2013	Main		03/20/2014 10:10:07 Debbie Barber (DBARBER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI XXXX Notification and Work order created to document work done on 12/17/2013.  Replace bolts in mechanical joint. Job complete 12/17/13 03/20/2014 10:29:01 Debbie Barber (DBARBER) Phone 2-1/4 X 12-1/2 225 CI 100 PSI XXXX Crew id 3	

Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
105	5		10487213	2	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	EMPLOYEE	7515 64th Courtway S Birmingham 35212	2013	Below Ground Grade 2	12/17/2013	Service		03/20/2014 09:57:45 Debbie Barber (DBARBER) Phone ██████████ ██████████ Notification and Work order created to document work done on 12/17/2013.  Had 1 1/2" service with 2 corrosion leak fixed leaw with 1 6" by 1 1/2" repair clamp and 1 3" x 1 1/2" repair clamp. Job complete on 12/17/2013. 03/20/2014 10:31:11 Debbie Barber (DBARBER) Phone ██████████ ██████████  Crew id 578	
106	6		10480388	1	JONT	WEAR	MAWE	Cast Iron, 2-1/4 inch Main	EMPLOYEE	7546 65th Courtway S Birmingham 35212	2013	Emergency Grade 1	12/17/2013	Main		12/17/2013 14:03:12 PIAPPLUSER (PIAPPLUSER) Phone ██████████ ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 547 REMARKS: REPAIRED LEAKING MECHANICAL JOINT. JOB COMPLETE.	
107	7		10480452	1	PIPE	BROK	NATF	Cast Iron, 2-1/4 inch Main	PUBLIC	7547 65th Courtway S Birmingham 35212	2013	Emergency Grade 1	12/17/2013	Main	CLAMP-REPAIR 1- 1/2 X 3 FOR STL S/B; CLAMP-REPAIR 1-1/2 X 6 FOR STL S/B; CLAMP-REPAIR 2-1/4 X 7-1/2 225 CI 100PSI; CLAMP-REPAIR 1-1/4 X 3 244 S/B REDI STL	12/17/2013 04:17:15 Rochelle Holmes (RHOLMES) EXPLOSION ----- 12/17/2013 16:29:42 PIAPPLUSER (PIAPPLUSER) Phone ██████████ ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 398 REMARKS: REPAIRED BROKE MAIN WITH 2.25" SMITH BLAIR WRAPAROUND.JOB COMPLETE.	This leak was related to the incident at 7546 64th Courtway S. Actual work was performed at 7546 64th Courtway S. Exhibit 1 pipe sample.
108	8		10480471	1	JONT	WEAR	EQUI	Cast Iron, 2-1/4 inch Main	EMPLOYEE	7549 67th Courtway S Birmingham 35212	2013	Emergency Grade 1	12/17/2013	Main		12/17/2013 10:46:39 Melanie Barnett (MSBARNET) Phone ██████████ ██████████ 95% gas less that 20 feet from building per McGraw ----- 12/17/2013 13:21:43 PIAPPLUSER (PIAPPLUSER) Phone ██████████ ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 578 REMARKS: FOUND MECH JOINT LEAKING CHANGED BOLTS TO STOP LEAK JOB COMPLETE	
109	9		10480501	1	CLMP	WEAR	EQUI	Cast Iron, 2-1/4 inch Main	EMPLOYEE	7545 67th Courtway S Birmingham 35212	2013	Below Ground Grade 2	12/17/2013	Main		12/17/2013 12:37:10 Denise Griffin (DDGRIFFI) Phone ██████████ XXXX called in by mcgraw.... hogland on site ----- 12/17/2013 13:27:17 PIAPPLUSER (PIAPPLUSER) Phone ██████████ ██████████ Operation : 0010 Template : REMARKS_GRADE23 CREW_CODE : 578 DUG UP WRAP AROUND LEAKING TIGHTEN BOLTS TO STOP LEAK JOB COMPLETE	
110	10		10480503	1	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	EMPLOYEE	7566 66th Courtway S Birmingham 35212	2013	Below Ground Grade 2	12/17/2013	Service		12/17/2013 12:42:27 Denise Griffin (DDGRIFFI) Phone ██████████ XXXX caled in by mcgraw. give to hogland on site ----- 12/17/2013 18:34:03 PIAPPLUSER (PIAPPLUSER) Phone ██████████ ██████████ Operation : 0010 Template : REMARKS_GRADE23 CREW_CODE : 578 DUG 11/2" STEELTRUNKUNE WITH CORROSION LEAK FIXED WITH REPAIR CLAMP JOB COMPLETE	
111	11		10480508	1	MECH	WEAR	MAWE	Steel, 1-1/4 inch Service Maintenance	EMPLOYEE	7540 67th Courtway S Birmingham 35212	2013	Emergency Grade 1	12/17/2013	Service		12/17/2013 13:32:52 Twonnie Wilson (TWILSON) Phone ██████████ ██████████ 99% gas next to building wall per MMcGraw ----- 12/17/2013 15:36:39 PIAPPLUSER (PIAPPLUSER) Phone ██████████ ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 547 REMARKS: TIGHTENED COUPLING ON SERVICE TO REPAIR LEAK. JOB COMPLETE.	
112	12		10480513	1	PIPE	PIT	CORR	Steel, 1 inch Main	EMPLOYEE	7572 Georgia Rd Birmingham 35212	2013	Emergency Grade 1	12/17/2013	Service	CLAMP-REPAIR 3/4 X 3 244 S/B REDI STL; CLAMP-REPAIR 1-1/4 X 3 244 S/B REDI STL	12/17/2013 14:15:26 Twonnie Wilson (TWILSON) Phone ██████████ ██████████ 10% gas 5' from the foundation per RWalton ----- 12/17/2013 20:33:55 PIAPPLUSER (PIAPPLUSER) Phone ██████████ ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 548 REMARKS: REPAIRED CORROSION LEAK ON 1" MW STL MAIN WITH REPAIR CLAMP	Leak reported on main, but actual repair was made on 1" branched service line
113	13		10480513	2	PIPE	PIT	CORR	Steel, 1 inch Main	EMPLOYEE	7572 Georgia Rd Birmingham 35212	2013	Emergency Grade 1	12/17/2013	Service	CLAMP-REPAIR 3/4 X 3 244 S/B REDI STL; CLAMP-REPAIR 1-1/4 X 3 244 S/B REDI STL	12/17/2013 14:15:26 Twonnie Wilson (TWILSON) Phone ██████████ ██████████ 10% gas 5' from the foundation per RWalton ----- 12/17/2013 20:33:55 PIAPPLUSER (PIAPPLUSER) Phone ██████████ ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 548 REMARKS: REPAIRED CORROSION LEAK ON 1" MW STL MAIN WITH REPAIR CLAMP	Leak reported on main, but actual repair was made on 1" branched service line
114	14		10480528	1	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	EMPLOYEE	7530 64th Courtway S Birmingham 35212	2013	Emergency Grade 1	12/17/2013	Service	VALVE-SERVICE 3/4 INSULTLATED, 175 PSI, T.E.A.	12/17/2013 20:23:08 Monte Ransom (MRANSOM) Phone ██████████ ██████████ 75% gas 2ft from foundation ----- 12/17/2013 21:28:33 PIAPPLUSER (PIAPPLUSER) Phone ██████████ ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 547 REMARKS: PLUGGED TEE AND INSTALLED NEW RISER TO REPAIR LEAK. JOB COMPLETE.	Exhibit 2 pipe sample.

Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
115	15		10480534	1	JONT	WEAR	EQUI	Cast Iron, 2-1/4 inch Main	EMPLOYEE	7518 Georgia Rd Birmingham 35212	2013	Emergency Grade 1	12/17/2013	Main		12/17/2013 18:27:43 Mark Costabile (MCOSTABI) Getting 30% gas at the main . send to truck 578 ----- 12/17/2013 21:26:17 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 578 REMARKS: BARTESTED MAIN GOT 70 GAS OVER MECHANICAL JOINT FIXED BY CHANGING BOLTS COMPLETETE	
116	16		10480530	1	<Null>	<Null>	<Null>	Mains, Maintenance	EMPLOYEE	6811 Joppa Ave Birmingham 35212	2013	Below Ground Grade 2	12/17/2013	Main	ANODE 17LB; COUPLING 2.25 CIX2 INS RDCR; SADDLE-SVC 2.25CIX3/4; STP FIT-LN 2.25 H17165MJ STL/CI; MASTIC, 1GAL, TAPECOAT, COLD AP; VALVE-SVC 3/4 INSULTLATED, 175 PSI, T.E.A.; STIFFENER-METAL INS 2X7.5	12/17/2013 16:12:13 Mark Costabile (MCOSTABI) getting 10% over main ,marked with yellow paint. ----- 12/21/2013 00:20:13 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE23 CREW_CODE : 036 FOUND CRACKED 2.25" CI MAIN.STOPPED OFF MAIN AND CUT OUT 81.75" OF MAIN TO REPAIR LEAK.JOB COMPLETE	Exhibit 7 pipe sample.
117	17		10486499	1				Plastic, 5/8 inch Service Maintenance	EMPLOYEE	7547 64th Courtway S Birmingham 35212	2013	Emergency Grade 1	12/17/2013	Service		03/07/2014 14:24:52 Robert Rumph (RRUMPH) Phone [REDACTED] [REDACTED] XXXX ***Leak on service. Completed on 12/17/2013, order created to capture repair.*** ----- 03/07/2014 14:51:01 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 946	Completed on 12/17/2013. Exhibit 3 pipe sample.
118	18		10487216	1	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	EMPLOYEE	7572 Georgia Road Birmingham 35212	2013	Emergency Grade 1	12/18/2013	Service		03/20/2014 10:17:04 Debbie Barber (DBARBER) Phone [REDACTED] [REDACTED] XXXX Notification and Work order created to document work done on 12/17/2013.  Repaired corrosion leak on a 1" mill wrap service with a 1"X3" smith blair 360 wrap around. Job complete.  crew id 398	
119	19		10480725	1	PIPE	BROK	NATF	Cast Iron, 2 inch Main	EMPLOYEE	7524 64th Courtway S Birmingham 35212	2014	Emergency Grade 1	12/19/2013	Main		12/19/2013 17:24:41 Lavon Jones (LJONES) Phone [REDACTED] per Robert Rumph ----- 01/07/2014 08:27:52 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 398 REMARKS: DUG UP LEAK AND COULD NOT REPAIR DUE TO INVESTIGATION,LEFT HOLE OPEN AND A OPERATOR STANDING BY.LEAK WAS DOWN GRADED BY BILL ROBERSO N.NEED TO RETURN AND CUT OUT MAIN. REMARKS: CUT OUT SECTION OF MAIN AND REPLACED WITH PLASTIC. REMARKS: JOB ALREADY COMPLETED.	Exhibits 6 and 8 pipe samples.
120	20		10480789	1	RISR	PIT	CORR	Steel, 1 inch Service Maintenance	EMPLOYEE	7527 64th Courtway S Birmingham 35212	2013	Emergency Grade 1	12/20/2013	Service	CLAMP-REPAIR 1 X 3 244 S/B REDI STL	12/20/2013 16:20:40 Javonti Barnes (JBARNES) Phone [REDACTED] 0000 Leak on riser below service cock. Assigned to Truck 398 ----- 12/20/2013 19:31:05 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 398 REMARKS: REPAIRED CORROSION LEAK ON RISER WITH A 1" X 3" THREESIXTY WRAPAROUND.JOB COMPLETE.	
121	21		10481337	1	JONT	WEAR	MAWE	Steel, 1 inch Service Maintenance	EMPLOYEE	6702 Kimberly Ave Birmingham 35212	2013	Emergency Grade 1	12/30/2013	Service		12/30/2013 17:30:34 Annette Guthrie (AGUTHRIE) giv to tim moore ----- 12/30/2013 21:48:38 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 506 REMARKS: FOUND SCREW FITTINGS ON THE SERVICE LEAKING. TIGHTNED FITTINGS TO REPAIR LEAK.	
122	22		10481350	1	JONT	WEAR	NATF	Cast Iron, 2 inch Main	EMPLOYEE	7551 67th Courtway S Birmingham 35212	2013	Emergency Grade 1	12/30/2013	Main		12/30/2013 18:15:28 Annette Guthrie (AGUTHRIE) turner standing by 29% gas over main; ----- 12/30/2013 22:40:06 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 548 REMARKS: 30 % GAS OVER MAIN REPLACED T BOLTS IN 2 " MECHANICAL JOINT TO CLEAR LEAK JOB COMPLETED	
123	23		10481441	1	PIPE	PIT	CORR	Plastic, 5/8 inch Service Maintenance	EMPLOYEE	7507 66th St S Birmingham 35212	2013	Emergency Grade 1	12/31/2013	Service	RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK	12/31/2013 11:54:39 Cynthia Harris (CHARRIS) notification #20222155 AOCH133-650-894 ONelson is getting 8% gas 5" from foundation ----- 12/31/2013 15:57:33 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 547 REMARKS: RE-NEWED SERVICE FROM SPLIT TO FIX LEAK .JOB COMPLETE.	

Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
124	24		10481466	1	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	EMPLOYEE	6839 Joppa Ave Birmingham 35212	2013	Emergency Grade 1	12/31/2013	Service	CLAMP-REPAIR 1 X 3 244 S/B REDI STL	12/31/2013 18:02:54 Annette Guthrie (AGUTHRIE) 75% GAS SEVEN FT FROM FOUNDATION PER SHERMAN PEARSON ----- 12/31/2013 21:01:57 PIAPPLUSER (PIAPPLUSER) Phone 2- Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 402 REMARKS: WE FOUND A CORROSION LEAK ON A 1" ST SERVICE. WE USED A 1X3" WRAPAROUND TO STOP THE LEAK. JOB COMPLETE.	
125	25		10481597	1	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	SO CROSS	7582 66th St S Birmingham 35212	2014	Emergency Grade 1	1/3/2014	Service	PIPE-PLS 1/2 CTS 5/8 OD SDR-7; RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK; CLAMP-REPAIR 1 X 6 244 S/B REDI STL; CLAMP-REPAIR 1 X 3 244 S/B REDI STL	01/03/2014 10:04:17 Sonya Demps (SDEMPS) 01/03/2014 09:48:55 Denise Griffin (DDGRIFFI) Phone - XXXX 20% gas 6' from building wall. Special survey for GATE CITY called in by Jason with Southern Cross . AOCH140030380 ----- 01/03/2014 17:28:30 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 194 REMARKS: BAR TESTED OVER SER LINE FOR LEAK CALLED IN BY SOTHERN CROSS WE FOUND MULTIPLE LEAKS ON TRUNK LINE AND SER LINE SERVING APT BUILDING ADDRESSES ARE 7580 7582 7586 AND 600 66TH STREET SOUTH WE DUG UP MAIN AND DID A COMPLETE REPLACEMENT ON SER AND TRUNK LINE 75' OF 3 /4" PLASTIC LONG SIDE ACCROSS STREET FROM MAIN TO TRUNK LINE THEN WE INSERTED 50' OF 5/8" PLASTIC TO RENEW TRUNK LINE THAT FED SER LINE AND LAID TWO RISERS AND 8' OFSERLINEEACH TO SERVE TWO, TWO METER LOOPS	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee
126	26		10481597	2	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	SO CROSS	7582 66th St S Birmingham 35212	2014	Emergency Grade 1	1/3/2014	Service	PIPE-PLS 1/2 CTS 5/8 OD SDR-7; RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK; CLAMP-REPAIR 1 X 6 244 S/B REDI STL; CLAMP-REPAIR 1 X 3 244 S/B REDI STL	01/03/2014 10:04:17 Sonya Demps (SDEMPS) 01/03/2014 09:48:55 Denise Griffin (DDGRIFFI) Phone - XXXX 20% gas 6' from building wall. Special survey for GATE CITY called in by Jason with Southern Cross . AOCH140030380 ----- 01/03/2014 17:28:30 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 194 REMARKS: BAR TESTED OVER SER LINE FOR LEAK CALLED IN BY SOTHERN CROSS WE FOUND MULTIPLE LEAKS ON TRUNK LINE AND SER LINE SERVING APT BUILDING ADDRESSES ARE 7580 7582 7586 AND 600 66TH STREET SOUTH WE DUG UP MAIN AND DID A COMPLETE REPLACEMENT ON SER AND TRUNK LINE 75' OF 3 /4" PLASTIC LONG SIDE ACCROSS STREET FROM MAIN TO TRUNK LINE THEN WE INSERTED 50' OF 5/8" PLASTIC TO RENEW TRUNK LINE THAT FED SER LINE AND LAID TWO RISERS AND 8' OFSERLINEEACH TO SERVE TWO, TWO METER LOOPS	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee
127	27		10481631	1	PIPE	PIT	CORR	Steel, 1 inch Main	SO CROSS	7576 66th St S Birmingham 35212	2014	Emergency Grade 1	1/3/2014	Service	CLAMP-REPAIR 1-1/4 X 6 244 S/B REDI STL; CLAMP-REPAIR 1 X 6 244 S/B REDI STL	01/03/2014 11:12:13 Sonya Demps (SDEMPS) 01/03/2014 10:30:16 Denise Griffin (DDGRIFFI) Phone - XXXX 60% gas 3' from the building. called in by southern cross- Special Survey- GATE City Jacob - AOCH140030530 ----- 01/03/2014 13:09:04 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 402 REMARKS: WE FOUND TWO CORROSION LEAKS ON A 1" MW TRUNK LINE. WE USED TWO 6X1" WRAPAROUNDS TO STOP THE LEAK. JOB COMPLETE.	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee. The leak was reported on main, but actual repair was made on 1" branched service line.
128	28		10481631	2	PIPE	PIT	CORR	Steel, 1 inch Main	SO CROSS	7576 66th St S Birmingham 35212	2014	Emergency Grade 1	1/3/2014	Service	CLAMP-REPAIR 1-1/4 X 6 244 S/B REDI STL; CLAMP-REPAIR 1 X 6 244 S/B REDI STL	01/03/2014 11:12:13 Sonya Demps (SDEMPS) 01/03/2014 10:30:16 Denise Griffin (DDGRIFFI) Phone 2- XXXX 60% gas 3' from the building. called in by southern cross- Special Survey- GATE City Jacob 2- AOCH140030530 ----- 01/03/2014 13:09:04 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 402 REMARKS: WE FOUND TWO CORROSION LEAKS ON A 1" MW TRUNK LINE. WE USED TWO 6X1" WRAPAROUNDS TO STOP THE LEAK. JOB COMPLETE.	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee. The leak was reported on main, but actual repair was made on 1" branched service line.
129	29		10481636	1	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	SO CROSS	7574 66th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/3/2014	Service	COUPLING-MECHANICAL-STAB 1/2 CTS (5/8 OD); RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK; SADDLE-SERVICE 4 X 3/4 CI; TEE 3/4 X 5/8 OD SCRW BS X COMP OUT STL	01/03/2014 13:03:38 Sonya Demps (SDEMPS) 01/03/2014 12:22:35 Denise Griffin (DDGRIFFI) Phone - XXXX 25% 7" from wall. Special Survey Gate City Jason with southern cross - AOCH140030724 ----- 01/03/2014 15:30:20 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 826 REMARKS: FOUND LEAK ON SERVICE LINE. RETIRED STEEL SERVICE AND DIRECT BURIED NEW 5/8" PLASTIC SERVICE LINE	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee
130	30		10482024	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	6601 KIMBERLY AVE BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/3/2014	Main		01/06/2014 14:42:28 BATCHADM (BATCHADM) Phone - GAS NEAR LAMP POLE. METER REMOVED - MAIN	



Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
131	31		10482025	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	7580 66TH ST S U267 BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/3/2014	Main		01/06/2014 14:42:53 BATCHADM (BATCHADM) Phone ██████ ██████ GAS NEAR PYLON. 2 FT FROM MARKER - MAIN	
132	32		10482040	1	<Null>	<Null>	<Null>	Service Lines, Maintenance	SO CROSS	7712 65TH ST S BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/3/2014	Service		01/06/2014 14:43:19 BATCHADM (BATCHADM) Phone ██████ ██████ - RISER ONLY. LEAK ALSO FROM REG VENT - SERVICE(SERVICE COCK)	
133	33		10482041	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	7708 65TH ST S BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/3/2014	Main		01/06/2014 14:43:24 BATCHADM (BATCHADM) Phone ██████ ██████ - RISER ONLY. HOLE PUNCHED AT ANGLE UNDER SIDE OF ROAD - MAIN	
134	34		10482042	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	6503 JOPPA CT BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/3/2014	Main		01/06/2014 14:43:28 BATCHADM (BATCHADM) Phone ██████ ██████ BEHIND BUILDING 2 FEET FROM SIDE ST - MAIN	
135	35		10482043	1	<Null>	<Null>	<Null>	Service Lines, Maintenance	SO CROSS	7577 66TH ST S BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/3/2014	Service		01/06/2014 14:43:33 BATCHADM (BATCHADM) Phone ██████ ██████ - SERVICE(SERVICE COCK)	
136	36		10482044	1	<Null>	<Null>	<Null>	Service Lines, Maintenance	SO CROSS	6427 JOPPA CT U095 BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/3/2014	Service		01/06/2014 14:43:37 BATCHADM (BATCHADM) Phone ██████ ██████ - SERVICE(SERVICE COCK)	
137	37		10482129	1	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	SO CROSS	7540 66th St S Birmingham 35212	2014	Emergency Grade 1	1/8/2014	Service	COUPLING-MECHANICAL-STAB 1/2 CTS (5/8 OD); RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK	01/08/2014 09:19:20 Sonya Demps (SDEMPS) 20% gas 1ft from foundation per Jason w/Southern Cross. AOC#140080360 ----- 01/08/2014 15:25:50 PIAPPLUSER (PIAPPLUSER) Phone ██████-6-██████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 724 REMARKS:	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee
138	38		10482224	1	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	SO CROSS	7582 Georgia Rd Birmingham 35212	2014	Emergency Grade 1	1/8/2014	Service		01/08/2014 10:29:45 Sonya Demps (SDEMPS) 15% GAS SFT FROM BUILDING PER SOUTHERN CROSS. AOC#140080549 ----- 01/08/2014 16:19:27 PIAPPLUSER (PIAPPLUSER) Phone ██████8100 Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 934 REMARKS: REPAIRED LEAK ON 1" ST SERVICE WITH 360 WRAP AROUND FIXED LEAK JOB COMPLETE	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee
139	39		10482227	1	PIPE	PIT	CORR	Steel, 1 inch Main	SO CROSS	7522 66th St S Birmingham 35212	2014	Emergency Grade 1	1/8/2014	Service	CLAMP-REPAIR 1 X 6 244 S/B REDI STL; CLAMP-REPAIR 1 X 3 244 S/B REDI STL	01/08/2014 10:50:45 Twonnie Wilson (TWILSON) Phone ██████ ██████ 20% gas 1' from the foundation per Jason w/Southern Cross 01/08/2014 10:53:07 Twonnie Wilson (TWILSON) Phone ██████ ██████ 30% gas 4' from foundation per Jason w/Southern Cross ----- 01/08/2014 17:40:34 PIAPPLUSER (PIAPPLUSER) Phone ██████ ██████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 724 REMARKS: REPAIRED TWO CORROSION LEAKS ON A 1" TRUNK LINE. USED ONE 1 X 6 AND ONE 1 X 3 TO REPAIR LEAKS.	Leak reported on main, but actual repair was made on 1" branched service line
140	40		10482227	2	PIPE	PIT	CORR	Steel, 1 inch Main	SO CROSS	7522 66th St S Birmingham 35212	2014	Emergency Grade 1	1/8/2014	Service	CLAMP-REPAIR 1 X 6 244 S/B REDI STL; CLAMP-REPAIR 1 X 3 244 S/B REDI STL	01/08/2014 10:50:45 Twonnie Wilson (TWILSON) Phone ██████ ██████ 20% gas 1' from the foundation per Jason w/Southern Cross 01/08/2014 10:53:07 Twonnie Wilson (TWILSON) Phone ██████ ██████ 30% gas 4' from foundation per Jason w/Southern Cross ----- 01/08/2014 17:40:34 PIAPPLUSER (PIAPPLUSER) Phone ██████ ██████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 724 REMARKS: REPAIRED TWO CORROSION LEAKS ON A 1" TRUNK LINE. USED ONE 1 X 6 AND ONE 1 X 3 TO REPAIR LEAKS.	Leak reported on main, but actual repair was made on 1" branched service line
141	41		10482228	1	MECH	WEAR	EQUI	Cast Iron, 6 inch Main	SO CROSS	6600 Joppa Ave Birmingham 35212	2014	Emergency Grade 1	1/8/2014	Main		01/08/2014 10:55:24 Lavon Jones (LJONES) Phone ██████ Jacob with southern cross found 40% gas in water valve cap. ----- 01/08/2014 17:29:31 PIAPPLUSER (PIAPPLUSER) Phone ██████-3-██████ ██████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 562 REMARKS: FOUND 6 INCH MECHANICAL JOINT LEAKING REPLACED BOLTS TO FIX LEAK JOB COMPLETE	
142	42		10482376	1	<Null>	<Null>	<Null>	Service Lines, Maintenance	SO CROSS	6427 JOPPA CT BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/8/2014	Service		01/09/2014 14:31:30 BATCHADM (BATCHADM) Phone ██████ ██████ - LEAK APPROX 8FT FROM WHITEPAINT APPROX 11FT FROM BLDG. NO MIGRATON. NEXT TO WHERE SIDEWALK STARTING FALL	
143	43		10482377	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	7570 GEORGIA RD BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/8/2014	Main	CLAMP-REPAIR 2-1/4 X 7-1/2 225 CI 100PSI	01/09/2014 14:31:36 BATCHADM (BATCHADM) Phone ██████ ██████ BEHIND APARTMENTS ON MADRID ALLEY - MAIN	
144	44		10482352	1	JOINT	WEAR	MAWE	Cast Iron, 2-1/4 inch Main	EMPLOYEE	7527 64th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/9/2014	Main		01/09/2014 09:25:37 Sonya Demps (SDEMPS) 100% gas over the trunk line or service per A. Brewer. AOC#140090614 ----- 01/09/2014 14:22:40 PIAPPLUSER (PIAPPLUSER) Phone ██████-██████ ██████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 194 REMARKS: BAR TESTED OVER MAIN FOUND 90% GAS HOLDING OVER MAIN DUG HOLE AND FOUND 2 1/4" MECHANICAL JOINT LEAKING WE CLEANED REPLACED BOLTS A ND RETIGHTEND TO COMPLETE REPAIRS	

Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
145	45		10482386	1	JONT	WEAR	MAWE	Cast Iron, 2-1/4 inch Main	EMPLOYEE	7533 64th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/9/2014	Main		01/09/2014 13:11:25 Sonya Demps (SDEMPS) 01/09/2014 12:20:52 Denise Griffin (DDGRIFFI) Phone 2- XXXX 81% gas 12' from foundation, cannon and pennington standing by ----- 01/09/2014 22:20:14 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 194 REMARKS: BAR TESTED OVER MAIN FOUND 94% GAS HOLDING WE DUG HOLE OVERMAIN AND MADE REPAIRS TO TWO INCH MECHANICAL JOINT BY CLEANING AND REPLAC ING BOLTS JOB COMPLETE	
146	46		10482409	1	JONT	WEAR	OOFD	Cast Iron, 2-1/4 inch Main	EMPLOYEE	7537 64th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/9/2014	Main		01/09/2014 19:54:43 Sonya Demps (SDEMPS) 01/09/2014 13:32:00 Denise Griffin (DDGRIFFI) Phone - XXXX 81% gas per Reggie Johnson. AOC#140091286 ----- 01/09/2014 20:52:22 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 665 REMARKS: WE REPAIRED A LEAK ON A 2 1/4" CAST BELL JOINT TO REPAIR THE GRADE 1 LEAK. JOB COMPLETED	
147	47		10482440	1	JONT	WEAR	OOFD	Cast Iron, 2-1/4 inch Main	EMPLOYEE	7541 64th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/9/2014	Main		01/09/2014 20:00:34 Sonya Demps (SDEMPS) 01/09/2014 13:17:40 Denise Griffin (DDGRIFFI) Phone - XXXX 90% gas. per Reggie Johnson. AOC#140091192 ----- 01/09/2014 20:58:24 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 665 REMARKS: WE REPAIRED A 2 1/4" CAST IRON BELL JOINT TO REPAIR THE GRADE 1 LEAK. JOB COMPLETED	
148	48		10482542	1	JONT	WEAR	MAWE	Cast Iron, 2-1/4 inch Main	EMPLOYEE	7527 64th Courtway S Birmingham 35212	2014	Below Ground Grade 2	1/10/2014	Main		01/10/2014 20:28:43 Monte Ransom (MRANSOM) Phone - strong gas odor outside ----- 01/11/2014 00:42:24 PIAPPLUSER (PIAPPLUSER) Phone 2- Operation : 0010 Template : REMARKS_GRADE23 CREW_CODE : 547 REPLACED BOLTS IN MECHANICAL JOINT TO REPAIR LEAK. JOB COMPLETE.	
149	49		10482542	2	JONT	WEAR	MAWE	Cast Iron, 2-1/4 inch Main	EMPLOYEE	7527 64th Courtway S Birmingham 35212	2014	Below Ground Grade 2	1/10/2014	Main		01/10/2014 20:28:43 Monte Ransom (MRANSOM) Phone - strong gas odor outside ----- 01/11/2014 00:42:24 PIAPPLUSER (PIAPPLUSER) Phone 2- Operation : 0010 Template : REMARKS_GRADE23 CREW_CODE : 547 REPLACED BOLTS IN MECHANICAL JOINT TO REPAIR LEAK. JOB COMPLETE.	
150	50		10482714	1	MECH	WEAR	NATF	Steel, 1 inch Service Maintenance	SO CROSS	6631 Interlaken Ave Birmingham 35212	2014	Emergency Grade 1	1/13/2014	Service	ADPTR-SERVICE HEAD 5/8 OD X 3/4 IPS	01/13/2014 09:52:30 Twonnie Wilson (TWILSON) Phone - 15% gas per Jacob w/Southern Cross ----- 01/13/2014 13:18:27 PIAPPLUSER (PIAPPLUSER) Phone 2- 8100 Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 548 REMARKS: 90% GAS OVER MAIN RENEWED SERVICE TO REPAIR LEAK	
151	51		10482778	1	PIPE	WEAR	OOFD	Steel, 3/4 inch Service Maintenance	SO CROSS	7716 Georgia Rd Birmingham 35212	2014	Emergency Grade 1	1/14/2014	Service		01/14/2014 10:54:34 Melanie Barnett (MSBARNET) Phone - 5% gas three feet from foundation per Chris w/SoCross ----- 01/14/2014 19:52:51 PIAPPLUSER (PIAPPLUSER) Phone 2- Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 402 REMARKS: WE FOUND A COUPLING LEAKING FROM A COPPER SERVICE. WE REPAIRED THE LEAK BY TIGHTENING THE COUPLING. THIS SERVICE NEEDS TO BE REPLACE D TO THE MAIN AS SOON AS POSSIBLE. ----- 01/14/2014 19:53:54 PIAPPLUSER (PIAPPLUSER) Phone 2- Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 402 REMARKS: WE FOUND A COUPLING LEAKING FROM A COPPER SERVICE. WE REPAIRED THE LEAK BY TIGHTENING THE COUPLING. THIS SERVICE NEEDS TO BE REPLACE D TO THE MAIN AS SOON AS POSSIBLE.	

Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
152	52		10482800	1	JONT	WEAR	OOFD	Cast Iron, 4 inch Main	SO CROSS	6626 Joppa Ave Birmingham 35212	2014	Emergency Grade 1	1/14/2014	Main		01/14/2014 08:37:19 Melanie Barnett (MSBARNET) Phone ██████████ 25% gas six feet from building per SoCross ██████████ ----- 01/14/2014 16:04:58 PIAPPLUSER (PIAPPLUSER) Phone ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 826 REMARKS: FOUND AND REPAIRED LEAK ON MECHANICAL JOINT.	
153	53		10482813	1	PIPE	WEAR	CORR	Steel, 1 inch Service Maintenance	SO CROSS	6623 Interlaken Ave Birmingham 35212	2014	Emergency Grade 1	1/14/2014	Service	COUPLING-MECHANICAL-STAB 1/2 CTS (5/8 OD); RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK; SADDLE-SERVICE 4 X 3/4 CI; TEE 3/4 X 5/8 OD SCRWS X COMP OUT STL;	01/14/2014 09:50:09 Melanie Barnett (MSBARNET) Phone ██████████ 20% gas five feet from building per Jason w/SoCross ██████████ ----- 01/14/2014 20:48:11 PIAPPLUSER (PIAPPLUSER) Phone ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 562 REMARKS: RENEWED LEAKING 1 INCH STEEL SERVICE TO MAIN TO STOP AND REPAIR LEAK	
154	54		10482843	1	MECH	WEAR	CORR	Steel, 1 inch Service Maintenance	SO CROSS	7529 65th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/14/2014	Service		01/14/2014 12:26:51 Melanie Barnett (MSBARNET) Phone ██████████ 5% gas five feet from foundation per D'Shawn w/SoCross ██████████ ----- 01/14/2014 17:55:56 PIAPPLUSER (PIAPPLUSER) Phone ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 826 REMARKS: FOUND LEAK ON TEE OF SERVICE LINE. USED TRIDENT LEAK KIT TO REPAIR LEAK.	
155	55		10483115	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	0 KIMBERLY AVE BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/14/2014	Main		01/16/2014 15:11:32 BATCHADM (BATCHADM) Phone ██████████ ----- ██████████ - ON EDGE OF SIDEWALK. VACANT LOT ACROSS FROM 6418 - MAIN	
156	56		10483116	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	7530 64TH COURTWAY S BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/14/2014	Main		01/16/2014 15:11:37 BATCHADM (BATCHADM) Phone ██████████ ----- ██████████ - - MAIN	
157	57		10483117	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	0 67TH ST S BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/14/2014	Main		01/16/2014 15:11:41 BATCHADM (BATCHADM) Phone ██████████ ----- ██████████ - 67ST ST AND INTERLAKEN CT - MAIN	
158	58		10483120	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	0 67 COURTWAY S BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/14/2014	Service	SADDLE-SERVICE 2-1/4 CI X 3/4; TEE 3/4 X 5/8 OD SCRWS BS X COMP OUT STL	1/16/2014 15:11:53 BATCHADM (BATCHADM) Phone ██████████ ----- ██████████ - - MAIN	
159	59		10483121	1	<Null>	<Null>	<Null>	Service Lines, Maintenance	SO CROSS	7555 67TH COURTWAY S BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/14/2014	Service		01/16/2014 15:11:58 BATCHADM (BATCHADM) Phone ██████████ ----- ██████████ - SERVICE TAP LEAK - SERVICE	
160	60		10483122	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	7550 66TH COURTWAY S BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/14/2014	Main		01/16/2014 15:12:03 BATCHADM (BATCHADM) Phone ██████████ ----- ██████████ - GAS UNDER ROADWAY NEAR UNIT 336 - MAIN	
161	61		10482906	1	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	EMPLOYEE	7561 67th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/15/2014	Service	RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK	01/15/2014 20:23:18 Sonya Demps (SDEMPS) Per #194 ----- 01/15/2014 22:44:57 PIAPPLUSER (PIAPPLUSER) Phone ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 194 REMARKS: BAR TESTED OVER SER LINE FOUND 45% GAS LEAKING AT TAP WE DUG HOLE OVER TAP AT MAIN AND REPLACED SER LINE FROMMAIN TO HOUSE	
162	62		10482932	1	RISR	PIT	CORR	Steel, 1 inch Service Maintenance	SO CROSS	7552 66th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/15/2014	Service	RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK	01/15/2014 09:51:57 Twonnie Wilson (TWILSON) Phone ██████████ 15% gas 4' from building wall per Jacob w/Southern Cross ----- 01/15/2014 16:04:05 PIAPPLUSER (PIAPPLUSER) Phone ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 194 REMARKS: BAR TESTED OVER SER FOUND 20% GAS AT BASE OF RISER WE DUG HOLE AND FOUND LEAK ON RISER AT BASE WE REPLACED RISER WITH NEW PERFECTIO N RISER	
163	63		10482933	1	RISR	PIT	CORR	Steel, 1 inch Service Maintenance	SO CROSS	7560 66th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/15/2014	Service	RISER-SERVICE 3/4 MPT X 1/2 CTS COUPLING SERVICE CK	01/15/2014 09:58:29 Twonnie Wilson (TWILSON) Phone ██████████ 5% gas at the building wall per Jason w/Southern Cross ----- 01/15/2014 15:33:46 PIAPPLUSER (PIAPPLUSER) Phone ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 194 REMARKS:	
164	64		10482951	1	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	SO CROSS	7515 64th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/15/2014	Service	COUPLING-COMP 3/4 1-LA-11 STLXPL;COUPLING-MECH-STAB 3/4IPSX1/2 CTS;RISER-SERVICE 3/4 MPTX1/2 CTS COUPLING SERVICE CK;TEE MECH-STAB1/2 CTS PLXPL;TEE MECH-STAB 1/2 CTS PLXPL;TEE MECH-STAB 3/4IPS PLXPL	01/15/2014 10:42:43 Lavon Jones (LJONES) Phone ██████████ Southern cross found 10% gas 6ft from the building ----- 01/15/2014 16:17:31 PIAPPLUSER (PIAPPLUSER) Phone ██████████ Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 826 REMARKS:	



Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
165	65		10482956	1	JONT	WEAR	EQUI	Cast Iron, 4 inch Main	SO CROSS	7561 67th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/15/2014	Main		01/15/2014 11:28:34 Twonnie Wilson (TWILSON) Phone 2- 20% gas 5' from building wall per Jacob w/Southern Cross ----- 01/15/2014 22:11:37 PIAPPLUSER (PIAPPLUSER) Phone 2- Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 311 REMARKS: FOUND 4 INCH MECHANICAL JOINT LEAKING CHANGED BOLTS TO STOP ANDREPAIR LEAK ----- 01/15/2014 22:12:40 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 311 REMARKS: FOUND 4 INCH MECHANICAL JOINT LEAKING CHANGED BOLTS TO STOP ANDREPAIR LEAK	
166	66		10482958	1	JONT	WEAR	EQUI	Cast Iron, 4 inch Main	SO CROSS	7557 67th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/15/2014	Main		01/15/2014 11:30:42 Twonnie Wilson (TWILSON) Phone - 60% gas 5' from building wall per Jason w/Southern Cross ----- 01/16/2014 02:37:02 PIAPPLUSER (PIAPPLUSER) Phone 2- Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 130 REMARKS: CHANGED BOLTS OUT ON MECHANICAL JOINT TO REPAIR LEAK	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee
167	67		10483125	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	7520 GEORGIA RD BIRMINGHAM 35212	2014	Below Ground Grade 2	1/15/2014	Main		01/16/2014 15:12:16 BATCHADM (BATCHADM) Phone - - BAR HOLE - MAIN	
168	68		10483035	1	RISR	WEAR	EQUI	Steel, 1 inch Service Maintenance	SO CROSS	7535 67th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/16/2014	Service		01/16/2014 09:46:59 Nytosha Lott (NLOTT) Phone 205-326-8322 XXXX Grade 1 called in by southern cross ----- 01/16/2014 15:18:51 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 311 REMARKS: FOUND OLD RISING LEAKIN AT BUILDING ABANDONED RISER AT TEE TO STOP AND REPAIR LEAK	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee
169	69		10483045	1	JONT	WEAR	CORR	Cast Iron, 4 inch Main	SO CROSS	6702 Joppa Ave Birmingham 35212	2014	Emergency Grade 1	1/16/2014	Main		01/16/2014 08:41:32 Melanie Barnett (MSBARNET) Phone 2- 40% gas four feet from building per Jacob w/SoCross ----- 01/16/2014 15:24:05 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 724 REMARKS: FOUND 98% GAS OVER MAIN. FOUND A MECHANICAL 4" JOINT LEAKING. CHANGED OUT T-BOLTS CLEANED JOINT. TO REPAIR LEAK.	
170	70		10483057	1	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	SO CROSS	6706 Kimberly Ave Birmingham 35212	2014	Emergency Grade 1	1/16/2014	Service	CLAMP-REPAIR 1 X 6 244 S/B REDI STL	01/16/2014 10:46:58 Melanie Barnett (MSBARNET) Phone 2- 30% gas four feet from foundation per SoCross ----- 01/16/2014 12:50:22 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 934 REMARKS: FIXED LEAK ON 1" MW SERVIVE WITH 360 WRAPAROUND FIXED LEAK JOB COMPLETE	
171	71		10483059	1	MECH	WEAR	EQUI	Plastic, 5/8 inch Service Maintenance	SO CROSS	6421 Interlaken Ave Birmingham 35212	2014	Emergency Grade 1	1/16/2014	Service		01/16/2014 11:04:29 Melanie Barnett (MSBARNET) Phone - 10% 8 feet from building per SoCross ----- 01/16/2014 15:39:37 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 934 REMARKS: FOUND ADAPTER FITTING LEAKING TIGHTEND TO FIX LEAK JOB COMPLETE	
172	72		10483663	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	6646 JOPPA AVE BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/16/2014	Main		01/24/2014 16:24:54 BATCHADM (BATCHADM) Phone - - GAS 10 FT FROM MARKER. NEAR SIDEWALK. NEW METER NUMBER BA829425 - MAIN	
173	73		10483132	1	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	SO CROSS	6709 Interlaken Ave Birmingham 35212	2014	Emergency Grade 1	1/17/2014	Service	CLAMP-REPAIR 1 X 6 244 S/B REDI STL; CLAMP-REPAIR 1 X 3 244 S/B REDI STL	01/17/2014 08:16:39 Melanie Barnett (MSBARNET) Phone - 30% gas 1 1/2 feet from building per SoCross ----- 01/17/2014 11:05:06 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 724 REMARKS: FOUND TWO CORROSION LEAKS ON 1" TRUNK LINE. USED TWO 1" X 3" SMITH BLAIR CLAMPS TO REPAIR LEAKS.	
174	74		10483132	2	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	SO CROSS	6709 Interlaken Ave Birmingham 35212	2014	Emergency Grade 1	1/17/2014	Service	CLAMP-REPAIR 1 X 6 244 S/B REDI STL; CLAMP-REPAIR 1 X 3 244 S/B REDI STL	01/17/2014 08:16:39 Melanie Barnett (MSBARNET) Phone - 30% gas 1 1/2 feet from building per SoCross ----- 01/17/2014 11:05:06 PIAPPLUSER (PIAPPLUSER) Phone - Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 724 REMARKS: FOUND TWO CORROSION LEAKS ON 1" TRUNK LINE. USED TWO 1" X 3" SMITH BLAIR CLAMPS TO REPAIR LEAKS.	

Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
175	75		10483147	1	RISR	PIT	OOFD	Steel, 1 inch Service Maintenance	SO CROSS	6507 Interlaken Ave Birmingham 35212	2014	Emergency Grade 1	1/17/2014	Service	ADPTR-SERVICE HEAD 5/8 OD X 3/4 IPS; VALVE-SERVICE 3/4 INSULTLATED, 175 PSI, T.E.A.	01/17/2014 09:11:10 Twonnie Wilson (TWILSON) Phone [REDACTED] [REDACTED] 10% gas 4' from building wall per Desean w/Southern Cross [REDACTED] [REDACTED] ----- 01/17/2014 14:20:35 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 665 REMARKS: WE RENEWD 18" OF 5/8" PL TO REPAIR THE GRADE 1 LEAK. JOB COMPLETED	
176	76		10483181	1	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	SO CROSS	7548 67th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/17/2014	Service	CLAMP-REPAIR 1-1/4 X 6 244 S/B REDI STL	01/17/2014 10:28:15 Twonnie Wilson (TWILSON) Phone [REDACTED] [REDACTED] Southern Cross grade 1 leak/20% gas 5' from building wall per Jason ----- 01/17/2014 15:21:49 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 194 REMARKS: WE BAR TESTED OVER TRUNK LINE FOUND 20% GAS HOLDING DUG HOLE AND MADE REPAIRS TO CORROSION LEAK WITH 1 1/4" 360 REPAIR CLAMPTO STOP LEAK	
177	77		10483182	1	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	SO CROSS	7544 67th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/17/2014	Service		01/17/2014 10:36:16 Twonnie Wilson (TWILSON) Phone [REDACTED] [REDACTED] Southern Cross grade 1-35% gas 1' from building wall ----- 01/17/2014 15:20:37 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 548 REMARKS: 30% GAS OVER SERVICE , RENEWED SERVICE TO REPAIR LEAKS . ( JOB COMPLETED )	
178	78		10483182	2	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	SO CROSS	7544 67th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/17/2014	Service		01/17/2014 10:36:16 Twonnie Wilson (TWILSON) Phone [REDACTED] [REDACTED] Southern Cross grade 1-35% gas 1' from building wall ----- 01/17/2014 15:20:37 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 548 REMARKS: 30% GAS OVER SERVICE , RENEWED SERVICE TO REPAIR LEAKS . ( JOB COMPLETED )	
179	79		10483182	3	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	SO CROSS	7544 67th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/17/2014	Service		01/17/2014 10:36:16 Twonnie Wilson (TWILSON) Phone [REDACTED] [REDACTED] Southern Cross grade 1-35% gas 1' from building wall ----- 01/17/2014 15:20:37 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 548 REMARKS: 30% GAS OVER SERVICE , RENEWED SERVICE TO REPAIR LEAKS . ( JOB COMPLETED )	
180	80		10483668	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	6807 JOPPA AVE BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/17/2014	Main		01/24/2014 16:25:24 BATCHADM (BATCHADM) Phone [REDACTED] [REDACTED] GAS IN BAR HOLE UNDER OLD PATCH. - MAIN	
181	81		10483263	1	JONT	WEAR	EQUI	Cast Iron, 2 inch Main	EMPLOYEE	6502 Joppa Ave Birmingham 35212	2014	Emergency Grade 1	1/20/2014	Main		01/20/2014 07:45:09 Nytoshia Lott (NLOTT) Phone [REDACTED] XXXX 797 getting 60% gas 10' from the building. AOC 140-200-086 ----- 01/20/2014 11:39:23 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 194 REMARKS: FOUND MECHANICAL JOINT LEAKING REPLACED BOLTS TO FIX LEAK JOB COMPLETE	
182	82		10483291	1	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	SO CROSS	7552 67th Courtway S Birmingham 35212	2014	Emergency Grade 1	1/20/2014	Service		01/20/2014 08:11:29 Nytoshia Lott (NLOTT) Phone [REDACTED] XXXX Jason with Southern Cross found 15% gas 5' from the building ----- 01/20/2014 16:06:09 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 826 REMARKS: FOUND CORROSION LEAK ON TRUNK LINE. INSTALLED CLAMP TO REPAIR LEAK.	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee
183	83		10483292	1	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	SO CROSS	6817 Joppa Ave Birmingham 35212	2014	Emergency Grade 1	1/20/2014	Service	CLAMP-REPAIR 1 X 6 244 S/B REDI STL	01/20/2014 08:24:59 Nytoshia Lott (NLOTT) Phone [REDACTED] XXXX Jason with Southern Cross reports getting 20% gas 5' from building wall ----- 01/20/2014 15:13:09 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 194 REMARKS: FOUND SMALL CORROSION LEAK ON 1 IN STEEL LINE WITH WRAPAROUND JOB COMPLETE	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee

Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
184	84		10483314	1	MECH	WEAR	OOFD	Steel, 1 inch Service Maintenance	SO CROSS	6527 Interlaken Ave Birmingham 35212	2014	Emergency Grade 1	1/20/2014	Service	WRAP-PIPE 2 X 75 FT COLD APPLIED H-35-G; TRIDENT SEAL KIT 1 1/4" - 2"	01/20/2014 13:35:05 Nytosh Lott (NLOTT) Phone [REDACTED] XXXX Southern Cross called in 15% gas 6' from the building ----- 01/20/2014 16:11:34 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 826 REMARKS: FOUND LEAK AT TEE ON TRUNK LINE. REPAIRED LEAK WITH TRIDENT KIT.	According to the notification long text, the leak was called in by Southern Cross, but input as reported by employee
185	85		10483682	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	6515 INTERLAKEN AVE BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/20/2014	Service		01/24/2014 16:25:44 BATCHADM (BATCHADM) Phone [REDACTED] [REDACTED] - MAIN	Leak reported on main, but may be on service. The repair has not been made since it is a grade 2 and pipe is being replaced in community
186	86		10483685	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	6821 JOPPA AVE BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/20/2014	Main		01/24/2014 16:25:56 BATCHADM (BATCHADM) Phone [REDACTED] [REDACTED] - GAS ON MAIN BETWEEN UNIT 447 & 446 - MAIN	
187	87		10483687	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	6818 INTERLAKEN WAY BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/20/2014	Main		01/24/2014 16:26:04 BATCHADM (BATCHADM) Phone [REDACTED] [REDACTED] GAS IN CURB. NEXT TO WATERBOX - MAIN	
188	88		10483688	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	7501 66TH ST S BIRMINGHAM 35212	<Null>	Below Ground Grade 3	1/20/2014	Service		01/24/2014 16:26:09 BATCHADM (BATCHADM) Phone [REDACTED] [REDACTED] - MAIN	Leak reported on main, but may be on service. The repair has not been made since it is a grade 3 and pipe is being replaced in community
189	89		10483708	1	<Null>	<Null>	<Null>	Mains, Maintenance	SO CROSS	7416 67TH ST S BIRMINGHAM 35212	<Null>	Below Ground Grade 2	1/22/2014	Main		01/24/2014 16:27:31 BATCHADM (BATCHADM) Phone [REDACTED] [REDACTED] HOLE PUNCHED SLANTEF UNDER THE ROAD - MAIN	
190	90		10483736	1	JONT	WEAR	EQUI	Cast Iron, 2 inch Main	EMPLOYEE	7570 Georgia Rd Birmingham 35212	2014	Emergency Grade 1	1/24/2014	Main		01/24/2014 23:57:54 Monte Ransom (MRANSOM) Phone [REDACTED] [REDACTED] 98% over main 70% lel 5ft from foundation per j.cook ----- 01/25/2014 01:27:10 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 130 REMARKS: DUG UP 98% GAS OVER MAIN FOUND MECHANICAL JOINT BLOWING CHANGED OUT BOLTS TO STOP LEAK RECHECKED LEL READINGS GOT ZERO	
191	91		10483736	2	JONT	WEAR	EQUI	Cast Iron, 2 inch Main	EMPLOYEE	7570 Georgia Rd Birmingham 35212	2014	Emergency Grade 1	1/24/2014	Main		01/24/2014 23:57:54 Monte Ransom (MRANSOM) Phone [REDACTED] [REDACTED] 98% over main 70% lel 5ft from foundation per j.cook ----- 01/25/2014 01:27:10 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 130 REMARKS: DUG UP 98% GAS OVER MAIN FOUND MECHANICAL JOINT BLOWING CHANGED OUT BOLTS TO STOP LEAK RECHECKED LEL READINGS GOT ZERO	
192	92		10483752	1	MECH	WEAR	EQUI	Steel, 3/4 inch Service Maintenance	EMPLOYEE	7500 66th St S Birmingham 35212	2014	Below Ground Grade 2	1/25/2014	Service		01/25/2014 13:47:44 Melanie Barnett (MSBARNET) Phone [REDACTED] [REDACTED] 14% gas on both sides of street with strong odor per Fred Cottrell. Work today. ----- 01/25/2014 16:24:04 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE23 CREW_CODE : 562 REPAIR TEE ON 3/4 STEEL USING TRIDENT TAPE JOB COMPLETE ----- 01/25/2014 16:24:22 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE23 CREW_CODE : 562 REPAIR TEE ON 3/4 STEEL USING TRIDENT TAPE JOB COMPLETE	
193	93		10484218	1	PIPE	BROK	EXCA	Plastic, 5/8 inch Service Maintenance	EMPLOYEE	Interlaken Ave/67 Street South Birmingh	2014	Emergency Grade 1	2/1/2014	Service	COUPLING-MECHANICAL-STAB 1/2 CTS (5/8 OD)	02/01/2014 11:20:47 Annette Guthrie (AGUTHRIE) broken blowing service at interlaken and 67 st s in woodlawn ----- 02/01/2014 15:00:37 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 311 REMARKS: ABANDONED 5/8 PLASTIC SERVICE IN EMPTY LOT TO REPAIR BROKE SERVICE	
194	94		10484207	1	PIPE	PIT	CORR	Steel, 1 inch Service Maintenance	EMPLOYEE	Interlaken Ave & 67th Street South Birm	2014	Emergency Grade 1	2/3/2014	Service		02/03/2014 09:12:20 Melanie Barnett (MSBARNET) Phone [REDACTED] [REDACTED] Broken line per Dale Gibson ----- 02/03/2014 13:09:12 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 311 REMARKS: FOUND CORROSION LEAK ON 1 INCH STUB KILLED AT CURB WITH BULLHEAD JOB COMPLETE	
195	95		10484397	1	JONT	WEAR	MAWE	Steel, 2 inch Service Maintenance	EMPLOYEE	6503 Joppa Ct Birmingham 35212	2014	Emergency Grade 1	2/3/2014	Service		02/03/2014 22:48:50 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE1 CREW_CODE : 716 REMARKS: WE REPLACED THE BOLTS IN A LEAKING JOINT IN THE REAR OF 6503 JOPPA CT.	
196	96		10484436	1	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	EMPLOYEE	6613 Interlaken Ave Birmingham 35212	2014	Below Ground Grade 2	2/4/2014	Service		02/04/2014 12:45:40 Lavon Jones (LJONES) Phone [REDACTED] leak on service line. ----- 02/04/2014 15:10:57 PIAPPLUSER (PIAPPLUSER) Phone [REDACTED] [REDACTED] Operation : 0010 Template : REMARKS_GRADE23 CREW_CODE : 826 MILLER PIPELINE UNCOVERED CORROSION LEAK ON TRUNK LINE. INSTALLED CLAMP TO REPAIR LEAK.	

Leak No	Post 12-17 Leak No	2011 Leak No	Notification	Item	Object Part	Damage Code	Cause Code	Pipe Description	Reported By	Address	Repair Year	Leak Grade	Required Start	Location	Material	Notification Long Text	Additional Comments
197	97		10484436	1	PIPE	PIT	CORR	Steel, 1-1/4 inch Service Maintenance	EMPLOYEE	6613 Interlaken Ave Birmingham 35212	2014	Below Ground Grade 2	2/4/2014	Service		02/04/2014 12:45:40 Lavon Jones (LJONES) Phone ██████ leak on service line. ----- 02/04/2014 15:10:57 PIAPPLUSER (PIAPPLUSER) Phone ██████ ██████ Operation : 0010 Template : REMARKS_GRADE23 CREW_CODE : 826 MILLER PIPELINE UNCOVERED CORROSION LEAK ON TRUNK LINE. INSTALLED CLAMP TO REPAIR LEAK.	