

Information provided to NTSB, December 18, 2013

7544 64th Courtway South (Unit 79) and 7546 64th Courtway South (Unit 80)

Birmingham, AL

Installation Data:

Pipeline installation work completed November 20, 1951

2 ¼ inch cast iron pipe

Wall thickness: unknown

Operating Data:

System MAOP 25 psig

Operating pressure 19 psig (December 17, 2013 at approximately 2:30AM)

Response to incident:

December 17, 2013 - 2:40AM received call from 911

December 17, 2013 - 3:23AM service mechanic on scene

December 17, 2013 - 6:14AM valved service off to extinguish fire at riser

Leak Detection Equipment:

Heath GMI 526 and 11B

Southern Cross Flame Pack 400