JY JUN 28 2011

Washington Gas

LEAK SURVEY FIELD ORDER

General Information

WR No:	653896	WR Type:	HFI	Quad Map:	B017NE	Crew Assigned:	LK SUR NW
Number of Services / Miles of Main:	299 S	3 M		Compliance Due Date:	21-APR-11	Scheduled Date:	31-MAR-11

Survey Information

Crew #	Date Surveyed	Survey Hrs.	Number of Services	Standby Hrs.	Down Time	Reason
935	6-15-11	7	124			
935	6-16-11	5	74			
935	6-17-11	7	103			
	Total	17	301	Alonzo Pratt #11320		

Below Ground- Leaks Found During Survey

No	Date	Location	Grade	Description of Leak	Advised
1	6-16-11	9005 Glenville Road	3	1% on curb 10 feet east from service T	

24613

Washington Gas

LEAK SURVEY FIELD ORDER

WR NO: 653896 WORK TYPE CODE: HFI

Above Ground- Leaks Found During Survey

No	Date	Location	Grade	Description of Leak	Repaired Y / N	Meter #

Non-Leak Maintenance Found During Survey

	Location	Description of Non-Leak	Priority (Check Box)				Meter #
			1 - Immediate	2 - Essential	3 - Routine	4 - Fill In	
50925	8905 Glenville Road	lower curb box to grade		✓			N/A
50926	9117 Glenville Rd	buried stopcock on riser		✓			N/A