



**PRESSURE TRANSDUCER 12-635-004**

---

REPORT NO : P255-5018-1

DATE : 12/10/2015

REVISION : 1

TITLE:	INITIAL PARAMETRIC TEST
PROJECT NO:	P255-5018-1
CUSTOMER:	CIRRUS AIRCRAFT
CUSTOMER P/N:	12-635-004 / G1014
SPECIFICATION:	TEST PLAN P255-5018
TESTED BY:	JOHN WONG
REPORT PREPARED BY:	JALPEN PATEL
REVIEWED BY:	MARCOS NASSAR

## 1. VISUAL INSPECTION

Kavlico Corporation performed functional validation test on pressure transducer 12-635-004 according to the test plan P255-5018 (Appendix I). Test was started beginning with opening a taped box in presence of Aviation Safety Inspector Mr. Bruce A. Borden.



Fig. 1: Taped box of sensor at the beginning

Pressure transducer was visually inspected for any defect or damage and following was confirmed.

- No damage on outer appearance of the sensor.
- No damage on connector and no signs of fretting on pins.
- Confirmed pressure port is not clogged or damaged.



Fig. 2: Pictures from visual inspection

## 2. X-RAY INSPECTION

Pressure transducer was examined under X-rays for further details of inside. X-rays shows details of flex wire connecting electric board and connector. From images no loose contact or damage found inside of the sensor.




Fig. 3: X-Ray Images

## 3. BENCH TEST

Bench test was performed where pressure transducer was powered up with 5 VDC supply. Also it was mounted on pressure manifold to apply full pressure of 150 PSIG at ambient temperature. From this it was confirmed that transducer reads correct pressure and provide output well within specified range. Also transducer was tapped with mallet and observed that there was no loose contact or output shift because of the impact.

Pressure	Output
PSIG	VDC
0	0.49186
75	2.5058
150	4.5192



Fig. 4: Set up for Bench test



#### 4. PARAMETRIC TEST

Kavlico Corporation performed parametric test on Pressure Transducers 12-635-004 to verify functionality during specified temperature range. It was confirmed from the test that pressure transducer is not functional and failed to provide the correct output at 100 °C.

##### a. TEST CONDITIONS

- Barometric Pressure: 14.5 ± 0.4 PSIA
- Relative Humidity: 50% ± 30%
- Room Temperature: 25 ± 5°C
- Supply Voltage 5.0 ± 0.05 VDC
- Parametric Test Pressure Range: 0 To 150 PSID
- Parametric Test Temperature Range: -30.0°C to 100.0°C

**Note:** All temperatures were held within ±2°C with the exception of tests performed at room temperature.

##### b. TEST EQUIPMENT

Measuring and test equipment, utilized in the performance of these tests, was calibrated in accordance with KP 1026, by KAVLICO, Inc., utilizing reference standards whose calibrations have been certified as being traceable to the National Institute of Standards & Technology (NIST). All Referenced standards utilized in the above calibration system are supported by certificates, reports, or data sheets attesting to the date, accuracy, and conditions under which the results furnished were obtained. All subordinate standards, measuring and test equipment is supported by like data, when such information is essential to achieve the accuracy control required by the procedure.

##### c. AUTOMATIC TEST EQUIPMENT

TEST EQUIPMENT DESCRIPTION	MANUFACTURER	MODEL NO	CALIBRATION DUE
TEMPERATURE CHAMBER	THERMOTRON	S-8C/S-8-3800	1/22/16
DATA ACQUISITION	AGILENT	34970	1/29/16
PROGRAMMABLE POWER SUPPLY	AGILENT	E3631A	8/15/16
PRESSURE CONTROLLER	DRUCK	DPI 510	12/2/16

d. SETUP FOR PARAMETRIC TEST




Fig. 5: Parametric test

VDC	0	25	50	100	150	100	50	25	0
25 °C	0.491791	1.163007	1.834687	3.176987	4.518486	3.177103	1.834609	1.163964	0.496521
-30 °C	0.48037	1.158935	1.834545	3.184833	4.530999	3.184601	1.834519	1.158987	0.480988
25 °C	0.492883	1.164493	1.83523	3.176638	4.517271	3.176702	1.835281	1.165101	0.493337
70 °C	0.49482	1.163253	1.831804	3.171428	4.511531	3.171441	1.832153	1.163408	0.494629
100 °C	0.493902	1.169035	1.83422	3.186638	-0.00035	-0.00059	-0.00099	-0.00071	-0.00065
Hi limit	0.58	1.25	1.91	3.25	4.58	3.25	1.91	1.25	0.58
Low Limit	0.42	1.09	1.75	3.09	4.42	3.09	1.75	1.09	0.42

5. CONCLUSION

Kavlico Corporation performed validation tests on Pressure Transducers 12-635-004 and confirmed failure at 100 °C temperature while running full parametric test. Further testing under vibration was not required, since failure was confirmed. A tear-down analysis will be needed to determine root cause of the failure.



KAVZICO		VALIDATION PLAN & REPORT								DVP NUMBER:					
COMPONENT/ASSEMBLY: P255-5018				SPECIFICATION: Per P255-5018-DWG				PLAN DATE		PLAN ORIGINATOR: Jalpen Patel					
MY: Oct, 2015		APPLICATIONS: Oil Pressure		SOURCE: Kavico Corp		CONCURRENCE		MANAGER APPROVAL: Marcos Nassar							
						REPORT DATE		REPORTING ENGINEER: Jalpen Patel							
TEST PLAN										TEST REPORT					
ITEM NO.	PROCEDURE OR STANDARD	TEST DESCRIPTION	ACCEPTANCE CRITERIA	TARGET REQMENT	TEST RESP.	TEST STAGE	SAMPLE		TIMING		SAMPLES TESTED			ACTUAL RESULTS	NOTES
							QTY	TYPE	START	COMPL	QTY	TYPE	PHASE		
1	Visual Inspection	- Check outer appearance of the sensor. - Inspect connector and check pins for signs of fretting. - Confirm pressure port is not clogged or damaged. - Take pictures of the sensor from different views.			Kavico	CC	1	E	12/8/15	12/8/15	1	E		PASS	
2	X-Ray Inspection	- Use X-Ray to inspect internal components. - Check condition of pressure port.			Kavico	CC	1	E	12/8/15	12/8/15	1	E		PASS	
3	Bench test	- Power up the sensor and read the output at ambient pressure. - Tap sensor to look for any output shift.	P255-5018-DWG Rev B	No Failures	Kavico	CC	1	E	12/8/15	12/8/15	1	E		PASS	
4	Parametric Test	Test Pressures (gage) in % of full scale: 0, 25, 50, 100 150, 100, 50, 25, 0  Test Temperatures in °C: -30, 25, 70, 100 45 min soak time at each temperature	Output voltage to remain within total error band per drawing P255-5018-DWG	No Failures	Kavico	CC	1	E	12/8/15	12/8/15	1	E		FAIL	FAILED @ 100°C, NO FURTHER TESTING REQUIRED
5	Vibration Test	Random vibration levels: 50 Hz / 0.014 (g <sup>2</sup> /Hz), 90 Hz / 0.004 (g <sup>2</sup> /Hz), 150 Hz / 0.0025 (g <sup>2</sup> /Hz), 300 Hz / 0.0035 (g <sup>2</sup> /Hz), 5000 Hz / 0.008 (g <sup>2</sup> /Hz), 800 Hz / 0.02 (g <sup>2</sup> /Hz), 2000 Hz / 0.02 (g <sup>2</sup> /Hz) GRMS: 5.49  One Axis mount, test at Room Temperature. Test duration 1 Hr, Monitor output continuously @ null pressure.	Output voltage to remain 0.5 ± 0.06 V	No Failures	Kavico	CC	1	E	-	-	-	-	-	N/A	
DEFINITION OF ABBREVIATIONS:						TEST STAGE	SAMPLE TYPE		PHASE						
						EV=Engr. Validation	A=Prototype (hand made)		Corresponds to program phase per CP1010						
						DV=Design Validation	B=Prototype (tooled)								
						PV= Prod. Validation	C=Program level								
						CC=Continuing	D=Initial production								
						Conformance	E=Full volume production								