

**PACIFIC GAS AND ELECTRIC COMPANY  
San Bruno Gas Transmission Line Incident  
Data Response**

PG&E Data Request No.:	NTSB_058-003		
PG&E File Name:	San Bruno GT Line Incident_DR_NTSB_058-003		
Request Date:	March 31, 2011	Requesting Party:	NTSB
Date Sent:	April 14, 2011	Requestor:	Operations (Chhatre/Nicholson)

**QUESTION 3**

SCADA

What are instrumentation ranges on pressure transducers at Milpitas?

**ANSWER 3**

All pressure transducers are calibrated 0 to 800 psi.