

Fuel Quality test was administered on 4/28/14 at 6:00 pm.

I put a sample of 100LL fuel in a clean white bucket. The fuel had proper color and clarity. There was no evidence of debris or contamination and no water was present. The smell and feel of the fuel did not show any evidence or contamination.

I also put a sample on a sheet of clean white paper and the fuel evaporated quickly.

It left a slight stain of fuel dye with no other residue. The smell of the dried paper sample was that of gasoline.

Fuel Filter replaced on 100LL Pump - 4/11/14

100LL Fuel Load Received in underground tank - 4/1/14 - 4044 gallons

Thank you,

Shawn Frye
Director
Hereford Municipal Airport

