



Systems 9 - 747-SL-20-048 - Fig. 33. Power feeder terminations in good condition. Terminations should be inspected for signs of over-heating.