



TEST DATA RECORD

Customer Support Operations

Rev. HDrawn HL SmithDate 3/30/95Test Approval [Signature]Date 3/30/95Eng. Approval [Signature]Date 3-30-95Overhaul Manual 27-20-01☐ Overhaul ☐ In-ServiceWork Order 6544468-100PART NO. 65-44861-9/65C37052- SERIAL NO. 1596A DATE OF TEST 8/21/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.																																							
11.A. Continuity Check	Check Continuity per wiring diagram (Fig. 403, Fig. 403A).	OK																																									
11.B. Pin to Pin Resistance	Check pin to pin resistance at 70°F and record. Must comply with noted valve. <table border="1"><thead><tr><th>Pins</th><th>Resistance</th><th>Sys "A"</th><th>Sys "B"</th></tr></thead><tbody><tr><td>1-2</td><td>71-87 OHMS (Solenoid PN 59600)</td><td></td><td></td></tr><tr><td>1-2</td><td>49-62 OHMS (Solenoid PN 45080 @ 77°F)</td><td></td><td></td></tr><tr><td>1-2</td><td>79-115 OHMS (Solenoid PN 45080-1 @ 77°F)</td><td></td><td></td></tr><tr><td>5-6</td><td>900-1100 OHMS</td><td></td><td></td></tr><tr><td>7-8</td><td>900-1100 OHMS</td><td></td><td></td></tr><tr><td>1-4</td><td>0 OHMS (Short)</td><td></td><td></td></tr><tr><td>9-10</td><td>80-165 OHMS</td><td></td><td></td></tr><tr><td>11-12</td><td>60-135 OHMS</td><td></td><td></td></tr><tr><td>3-Other</td><td>Infinite (No Connection)</td><td></td><td></td></tr></tbody></table>	Pins	Resistance	Sys "A"	Sys "B"	1-2	71-87 OHMS (Solenoid PN 59600)			1-2	49-62 OHMS (Solenoid PN 45080 @ 77°F)			1-2	79-115 OHMS (Solenoid PN 45080-1 @ 77°F)			5-6	900-1100 OHMS			7-8	900-1100 OHMS			1-4	0 OHMS (Short)			9-10	80-165 OHMS			11-12	60-135 OHMS			3-Other	Infinite (No Connection)				
Pins	Resistance	Sys "A"	Sys "B"																																								
1-2	71-87 OHMS (Solenoid PN 59600)																																										
1-2	49-62 OHMS (Solenoid PN 45080 @ 77°F)																																										
1-2	79-115 OHMS (Solenoid PN 45080-1 @ 77°F)																																										
5-6	900-1100 OHMS																																										
7-8	900-1100 OHMS																																										
1-4	0 OHMS (Short)																																										
9-10	80-165 OHMS																																										
11-12	60-135 OHMS																																										
3-Other	Infinite (No Connection)																																										
11.C. Dielectric Strength	Slowly apply noted voltages and hold for a period of 5 seconds (Fig. 403), 1 min (Fig. 403A). There must be no arcing or insulation failure. 1500 VAC Body to Pin 2 (Fig. 403) 1500 VAC Body to Pin 1 (Fig. 403A) 1000 VAC Body and Pins 2,5,7 connected to common lead to Pin 9 (Fig. 403)	OK OK OK																																									

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☐ In-Service

Work Order 654468-100

PART NO. <u>65-44861-9/65C37052-</u> SERIAL NO. <u>1596A</u> DATE OF TEST <u>8/21/96</u>				
PART NAME <u>RUDDER ACTUATOR PCU</u> INSPECTOR <u>KOSKINEN</u>				
☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680				
TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
11.C. Dielectric Strength (Continued)	1000 VAC Body and Pins 2,5,7 connected to common lead to Pin 11 (Fig. 403)	_____ OK	<i>investigation on 8/26/96</i>	<i>8/26/96</i>
	1000 VAC Body and Pins 1,5,7 connected to common lead to Pin 11.	_____ OK		
	1000 VAC Body and Pins 1,5,7 connected to common lead to Pin 9.	_____ OK		
	800 VAC between Pins 5 and 7	_____ OK		
	800 VAC between Pins 9 and 11 (Fig. 403A)	_____ OK		
11.D. Insulation Resistance	500 VDC between noted pins 100 Megohms min resistance 10 megohms min in-service. (Fig. 403)		<i>N/A for NT30</i>	
	<u>Pins</u> 1,5,7,9 & 11 to Body 1 to 5,7,9 & 11 5 to 7,9, & 11 7 to 9 & 11 9 to 11	<u>Sys "A"</u> <u>Sys "B"</u> _____ _____ _____ _____		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-ServiceWork Order 6544468-100

PART NO. <u>65-44861-9/65C37052-</u> SERIAL NO. <u>1596</u> DATE OF TEST <u>8/21/96</u>				
PART NAME <u>RUDDER ACTUATOR PCU</u> INSPECTOR <u>KOSKINEN</u>				
☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680				
TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.B. Return Pressure	No external leakage or permanent set, each test. No intersystem leakage.	3000 3 ± 2 Sys A _____ Sys B _____	N/A for NBS test on 8/21/96	1/1/96 1/1/96
12.C.3 & .4 Secondary Stroke/Flow Test	Measure and record leakage at open ports Ra and Rb. The unit shall not move after 25 lbs. is applied to lever TF83300-53, and leakage at each return port must not exceed the following: (a) 300-700 cc/min for overhauled unit. (b) 300-1085 cc/min for unit in service. <u>NOTE: Visual inspect lock to verify proper engagement.</u> <u>not Required For This Dash #</u>	Extend (12.C.3) Ra _____ cc/min Rb _____ cc/min Retract (12.C.4) Ra _____ cc/min Rb _____ cc/min Movement _____ in.	PAB EXPLAIN BELOW	1/1/96 1/1/96
12.D. Proof Pressure	No external leakage or permanent set, each test. No intersystem leakage.	5400 3 ± 2 Sys A _____ Sys B _____	N/A for NBS overhauled on 8/21/96	1/1/96 1/1/96
12.E. Rig Neutral Cylinder Stroke and Clearance Test	Output Rig Pin must fit. (27.46 - 27.54 Ref.) No binding or interference at 3000 PSI. Stoke 26° ± ½° each direction. Visual snubbing. No binding or interference at 0 PSI.	Rig Pin <u>GO</u> Surface Indicator at 0° <u>0°</u> Binding Yes <u>NO</u> Ext. <u>26°</u> Ret. <u>26°</u> Snubbing <u>✓</u> OK <u>✓</u> OK	CSO 22 FTO	1/1/96 1/1/96



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-ServiceWork Order 6544468-100PART NO. 65-44861-9/65C37052- SERIAL NO. 1596A DATE OF TEST 8/21/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.F. Linkage Breakout Friction	19 oz. maximum to start extend. 1 oz. minimum in extend direction to start retract.	Ext. <u>11</u> Oz. Ret. <u>2</u> Oz.		
12.G. Input Force vs. Input Travel	Force plot must fall within limits shown on Fig. 723.			
12.H. Cylinder Rod Leakage	1 drop/25 cycles max at each End Gland (In-Service 1 drop/5 cycles) 2 drops/25 cycles max. at Center Gland (In-Service 2 drops/5 cycles) 1 drop/100 cycles max at Input Shaft (In-Service 1 drop/25 cycles)	Rod Gland <u>0</u> drops Aft Gland <u>0</u> drops Center <u>0</u> drops Gland Input Shaft <u>0</u> drops		
12.J. Internal Leakage	(1) Rig neutral leakage at RA & RB. 300 cc/min - overhaul. 3000 cc/min - In-Service. (2) & (3) Input lever at extend & retract stops 300-700 cc/min - overhaul. 300-1085 cc/min - In-Service.	Neutral RA RB <u>180</u> <u>190</u> Ext. RA RB <u>410</u> <u>430</u> Ret. <u>420</u> <u>360</u>		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☐ In-ServiceWork Order 6544468-100PART NO. 65-44861-9/65C37052- SERIAL NO. 1596A DATE OF TEST 8/21/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.J. Internal Leakage (Continued)	(4) 65-44861 and 65C37052 System A energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	Neutral RA RB ____		
	(5) 65-44861 and 65C37052 System A energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	Ext. RA RB ____		
		Ret. _____		
	(6) 65-44861-5 thru -9,-11 and 65C37052-5 thru -9 System B energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	Neutral RB 640		
	(7) 65-44861-5 thru -9,-11 and 65C37052-5 thru -9 System B energized 1370 cc/min @ RB 2000 cc/min above leakage measured in step (1) (b) @ RB for In-Service	Ext. RB 640		
		Ret. 680		

CSO
22
FTO



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☐ In-ServiceWork Order 6544468-100PART NO. 65-44861-9/65C37052- SERIAL NO. 1596A DATE OF TEST 8/21/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.K. Intersystem Leakage	Combined leakage from PB and RB 10 cc/min maximum.	<u>.1</u> cc/min	CSO 22 FTO	
12.L. Transducer Output	4.2-4.8 VAC 65-44861-2 and 65C37052-2 (Sys A & B) 1.95-2.55 VAC 65-44861-3,-4 and 65C37052-2,-3,-4 (Sys A & B) 1.95-2.55 VAC 65-44861-5,-8 and 65C37052-5,-8 (Sys B) 3.07-3.67 VAC 65-44861-6,-7,-9,-11 and 65C37052-6,-7,-9 (Sys B)	"A" Extend <u> </u> VAC Retract <u> </u> VAC "B" Extend <u>3.53</u> VAC Retract <u>3.51</u> VAC	CSO 22 FTO	
12.M. Transducer Null	50 MV maximum at null for each system - Overhaul. 150 MV maximum at null for each system In-Service.	"A" Null <u> </u> VAC "B" Null <u>.059</u> VAC	CSO 22 FTO	



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-ServiceWork Order 6544468-100

PART NO. <u>65-44861-9/65C37052</u> SERIAL NO. <u>1596A</u> DATE OF TEST <u>8/21/96</u>				
PART NAME <u>RUDDER ACTUATOR PCU</u> INSPECTOR <u>KOSKINEN</u>				
☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680				
TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.N. Yaw Damper Authority	Per Figure 1, Ref. Test Data Sheet 10. Actuator must be stable and within .050" of neutral.	Ext. Ret. Sys "A" _____ Sys "B" <u>.234/.238</u> Sys "A & B" _____ Stable Yes No Position from "ZERO" _____ Ext. Ret. Stable Yes No Position from "ZERO" _____ Ext. Ret.		
12.P. Manual Hysteresis 4.3.14	Hysteresis shall not exceed .004 inch each direction - Overhaul. .006 inch each direction In-Service	Extend <u>.005</u> Inch Retract <u>.001</u> Inch		
12.Q. Yaw Damper System Phase Lag	Phase shift to be: 25 degrees (Sin Ø, 0.423) 30 degrees (Sin Ø, 0.500) for in-service units. No crossover in plot.	"A" sin Ø _____ "B" sin Ø <u>.313</u> Crossovers: Yes 		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-ServiceWork Order 654468-100PART NO. 65-44861-9/65C37052 SERIAL NO. 1596A DATE OF TEST 8/21/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.R. Yaw Damper System Repeatability and Linearity	Pattern must repeat within 0.8" (.008" at actuator) - Overhaul. 1.2" (.012" at actuator) In-Service Overshoot after reversal must be 0.2" maximum (.002" at actuator) Average input/output slope of any 10% segment must fall within the slope limits shown.	"A" _____ in max "B" <u>.28</u> in max "A" _____ in max "B" <u>.01</u> in max "A" Yes No "B" <u>Yes</u> No		
12.S. Phase Check	Manual control "extend", actuator must extend. Manual control "retract", actuator must retract. Operation smooth and stable for A and B.	Extend "A" <u>EXT</u> "B" <u>EXT</u> Retract "A" <u>RET</u> "B" <u>RET</u> Stable: <u>Yes</u> No		
12.T. Yaw Damper Engage 4.3.17	.004" maximum movement-overhaul .010" maximum movement-In-Service.	"A" _____ in "B" <u>.005</u> in		
12.U. By-Pass Valve Operation	(4) No piston movement at 250 PSI differential for either system. (6a) Noticeable decrease in flow at less than 460 PSI differential. (8) Piston rod movement of 1.00 inch or more in either direction.	"A" Yes <u>No</u> "B" Yes <u>No</u> "A" <u>360</u> PSI "B" <u>360</u> PSI Ext. <u>✓</u> OK Ret. <u>✓</u> OK		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-Service

Work Order

654468-100PART NO. 65-44861-9/65C37052-SERIAL NO. 1596ADATE OF TEST 8/21/96PART NAME RUDDER ACTUATOR PCUINSPECTOR KOSKINEN☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.V. Duty Cycle (optional) Not Required for In-Service Unless Actuator Seals Were Replaced	3.0 cc/8 hours maximum at each piston rod seal. 6.0 cc/8 hours at center gland - Overhaul. 1.8 cc/hr maximum at each piston rod seal. 3.6 cc/hr at center gland - In-Service.	Output End ____ cc ____ hrs Fixed End ____ cc ____ hrs Center ____ cc ____ hrs	N/A for AB3 investigation to be done 8/21/96 8/26/96	
12.W. Low Pressure Leakage (not same as 12.V.)	No external leakage in 8 hours - overhaul. No external leaks in one hour In-Service.	____ cc ____ hrs		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☐ In-ServiceWork Order 654468-100PART NO. 65-44861-2/65C37052- SERIAL NO. 1596A DATE OF TEST 8/21/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

OVERHAULED UNIT


PCU Assembly	Actuator Output Stroke (inches)		
	System A	System B	System AB
65-44861-2 65C37052-2	0.294 to 0.334	0.294 to 0.334	0.335 to 0.375
65-44861-3,-4 65C37052-3,-4	0.137 to 0.177	0.137 to 0.177	0.294 to 0.334
65-44861-5,-8 65C37052-5,-8	—	0.137 to 0.177	—
65-44861-6,-7,-9,-11 65C37052-6,-7,-9	—	0.215 to 0.255	—

IN-SERVICE UNIT

PCU Assembly	Actuator Output Stroke (inches)		
	System A	System B	System AB
65-44861-2 65C37052-2	0.274 to 0.354	0.274 to 0.354	0.315 to 0.394
65-44861-3,-4 65C37052-3,-4	0.117 to 0.197	0.117 to 0.197	0.274 to 0.354
65-44861-5,-8 65C37052-5,-8	—	0.117 to 0.197	—
65-44861-6,-7,-9,-11 65C37052-6,-7,-9	—	0.196 to 0.276	—

Actuator Output Stroke Limits
Figure 1

DRAWN: *n. m. m.* DATE: *10-2-10* ENG: *44861* DATE: *10-2-10* TEST APPR: *10-2-10*



PAGE 8 OF 10 ACCEPTANCE TEST DATA SHEETS			
DATE TESTED: <i>8/21/05</i>	SIZE B	BERTEA CORPORATION IRVINE, CALIFORNIA	
INSP: <i>KOSINER</i>	FSCM NO. <i>82106</i>	65-44861LG (1) G	
PART NO. & DASH NO. <i>65-44861-9</i>	PROJECT <i>737</i>	PAGE <i>743</i>	

OHM 27-20-01

DRAWN: 2/20/96

DATE: 10-2-80 ENG. APPR: [Signature]

DATE: 10-3-80

TEST APPR: [Signature]

DATE: 10-3-80



65-44861LG

SERIAL NO. 15% A

SINE Ø MAXIMUM PER TEST REQ'T .423 OVERHAUL .500 INSERVICE

$$2 \sqrt{\frac{C}{A} + \frac{D}{B}} = \text{SINE } \phi$$

CALCULATION



SYS A TEST 120 SYS B
SINE Ø PHASE LAG SINE Ø .313

(-5 ASSY, 1 SYSTEM ONLY)

PAGE 9 OF 10 ACCEPTANCE TEST DATA SHEETS			
DATE TESTED: <u>8/21/96</u>	SIZE <u>B</u>	BERTEA CORPORATION IRVINE, CALIFORNIA	
INSP DATE <u>8/22/96</u>	SCM NO. <u>82106</u>	REV <u>G</u>	
PART NO. & DASH NO. <u>65-44861-9</u>		PROJECT <u>737</u>	PAGE <u>751</u>

OHM 27-20-01

DRAWN: *n. m. m.*

DATE: 10-2-80

ENG. APPR: *[Signature]*

DATE: 10-2-80


TEST APPR: *[Signature]*

DATE: 10-2-80


DATE: 10-2-80

65-4486ILG

SERIAL NO. 1596A



SYSTEM A



SYSTEM B

TEST 12R
REPEATABILITY AND LINEARITY
(-5 ASSY, 1 SYSTEM ONLY)

PAGE 10 OF 10 ACCEPTANCE TEST DATA SHEETS			
DATE TESTED: 8/21/86	SIZE B	BERTEA CORPORATION MILPITAS, CALIFORNIA	
INSP: KOSKINEN	22	FSCM NO. 82106	65-4486ILG (3) REV G
PART NO. & DASH NO. 65-4486/9	PROJECT 737 PAGE 751		

OHM 27-20-01



TEST DATA RECORD

Customer Support Operations

Rev. HDrawn H. L. P. M.Date 3/30/95Test Approval [Signature]Date 3/30/95Eng. Approval [Signature]Date 3-30-95Overhaul Manual 27-20-01☐ Overhaul☐ In-Service

Work Order _____

PART NO. 65-44861-9/65C37052- SERIAL NO. 1596A DATE OF TEST 8/29/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☐ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.																																							
11.A. Continuity Check	Check Continuity per wiring diagram (Fig. 403, Fig. 403A).	_____OK																																									
11.B. Pin to Pin Resistance	Check pin to pin resistance at 70°F and record. Must comply with noted valve. <table><tr><td><u>Pins</u></td><td><u>Resistance</u></td><td><u>Sys "A"</u></td><td><u>Sys "B"</u></td></tr><tr><td>1-2</td><td>71-87 OHMS (Solenoid PN 59600)</td><td>_____</td><td>_____</td></tr><tr><td>1-2</td><td>49-62 OHMS (Solenoid PN 45080 @ 77°F)</td><td>_____</td><td>_____</td></tr><tr><td>1-2</td><td>79-115 OHMS (Solenoid PN 45080-1 @ 77°F)</td><td>_____</td><td>_____</td></tr><tr><td>5-6</td><td>900-1100 OHMS</td><td>_____</td><td>_____</td></tr><tr><td>7-8</td><td>900-1100 OHMS</td><td>_____</td><td>_____</td></tr><tr><td>1-4</td><td>0 OHMS (Short)</td><td>_____</td><td>_____</td></tr><tr><td>9-10</td><td>80-165 OHMS</td><td>_____</td><td>_____</td></tr><tr><td>11-12</td><td>60-135 OHMS</td><td>_____</td><td>_____</td></tr><tr><td>3-Other</td><td>Infinite (No Connection)</td><td>_____</td><td>_____</td></tr></table>	<u>Pins</u>	<u>Resistance</u>	<u>Sys "A"</u>	<u>Sys "B"</u>	1-2	71-87 OHMS (Solenoid PN 59600)	_____	_____	1-2	49-62 OHMS (Solenoid PN 45080 @ 77°F)	_____	_____	1-2	79-115 OHMS (Solenoid PN 45080-1 @ 77°F)	_____	_____	5-6	900-1100 OHMS	_____	_____	7-8	900-1100 OHMS	_____	_____	1-4	0 OHMS (Short)	_____	_____	9-10	80-165 OHMS	_____	_____	11-12	60-135 OHMS	_____	_____	3-Other	Infinite (No Connection)	_____	_____		
<u>Pins</u>	<u>Resistance</u>	<u>Sys "A"</u>	<u>Sys "B"</u>																																								
1-2	71-87 OHMS (Solenoid PN 59600)	_____	_____																																								
1-2	49-62 OHMS (Solenoid PN 45080 @ 77°F)	_____	_____																																								
1-2	79-115 OHMS (Solenoid PN 45080-1 @ 77°F)	_____	_____																																								
5-6	900-1100 OHMS	_____	_____																																								
7-8	900-1100 OHMS	_____	_____																																								
1-4	0 OHMS (Short)	_____	_____																																								
9-10	80-165 OHMS	_____	_____																																								
11-12	60-135 OHMS	_____	_____																																								
3-Other	Infinite (No Connection)	_____	_____																																								
11.C. Dielectric Strength	Slowly apply noted voltages and hold for a period of 5 seconds (Fig. 403), 1 min (Fig. 403A). There must be no arcing or insulation failure. 1500 VAC Body to Pin 2 (Fig. 403) 1500 VAC Body to Pin 1 (Fig. 403A) 1000 VAC Body and Pins 2,5,7 connected to common lead to Pin 9 (Fig. 403)	_____OK _____OK _____OK																																									



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☐ In-Service

Work Order _____

PART NO. 65-44861-9/65C37052- SERIAL NO. 1596A DATE OF TEST 8/29/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
11.C. Dielectric Strength (Continued)	1000 VAC Body and Pins 2,5,7 connected to common lead to Pin 11 (Fig. 403)	_____ OK		
	1000 VAC Body and Pins 1,5,7 connected to common lead to Pin 11.	_____ OK		
	1000 VAC Body and Pins 1,5,7 connected to common lead to Pin 9.	_____ OK		
	800 VAC between Pins 5 and 7	_____ OK		
	800 VAC between Pins 9 and 11 (Fig. 403A)	_____ OK		
11.D. Insulation Resistance	500 VDC between noted pins 100 Megohms min resistance 10 megohms min in-service. (Fig. 403)			
	<u>Pins</u>	<u>Sys "A"</u> <u>Sys "B"</u>		
	1,5,7,9 & 11 to Body	_____		
	1 to 5,7,9 & 11	_____		
	5 to 7,9, & 11	_____		
	7 to 9 & 11	_____		
	9 to 11	_____		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-Service

Work Order _____

PART NO. 65-44861-9/65C37052- SERIAL NO. 1596A DATE OF TEST 8/29/96PART NAME RUDDER ACTUATOR PCUINSPECTOR KOSKINEN☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.B. Return Pressure	No external leakage or permanent set, each test. No intersystem leakage.	3000 3 ± 2 Sys A _____ Sys B _____		
12.C.3 & .4 Secondary Stroke/Flow Test	Measure and record leakage at open ports Ra and Rb. The unit shall not move after 25 lbs. is applied to lever TF83300-53, and leakage at each return port must not exceed the following: (a) 300-700 cc/min for overhauled unit. (b) 300-1085 cc/min for unit in service. <i><u>NOTE:</u> Visual inspect lock to verify proper engagement.</i>	Extend (12.C.3) Ra _____ cc/min Rb _____ cc/min Retract (12.C.4) Ra _____ cc/min Rb _____ cc/min Movement _____ in.		
12.D. Proof Pressure	No external leakage or permanent set, each test. No intersystem leakage.	5400 3 ± 2 Sys A _____ Sys B _____		
✓ 12.E. Rig Neutral Cylinder Stroke and Clearance Test	Output Rig Pin must fit. (27.46 - 27.54 Ref.) No binding or interference at 3000 PSI. Stoke 26° ± ½° each direction. Visual snubbing. No binding or interference at 0 PSI.	Rig Pin <u>GO</u> Surface Indicator at 0° <u>0°</u> Binding Yes ☒ No ☐ Ext. <u>26°</u> Ret. <u>26°</u> Snubbing ☒ OK ☒ OK	CSO 22 ATO	



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-Service

Work Order _____

PART NO. <u>65-44861-9 / 65C37052-</u> SERIAL NO. <u>1596A</u> DATE OF TEST <u>8/29/96</u>				
PART NAME <u>RUDDER ACTUATOR PCU</u> INSPECTOR <u>KOSKINEN</u>				
☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680				
TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
✓ 12.F. Linkage Breakout Friction	19 oz. maximum to start extend. 1 oz. minimum in extend direction to start retract.	Ext. <u>14</u> Oz. Ret. <u>4</u> Oz.		
✓ 12.G. Input Force vs. Input Travel	Force plot must fall within limits shown on Fig. 723.	<u>OK</u> <u>LOW FORCE MOD,</u> <u>SHORT STROKE EXTEND</u>		
✓ 12.H. Cylinder Rod Leakage	1 drop/25 cycles max at each End Gland (In-Service 1 drop/5 cycles) 2 drops/25 cycles max. at Center Gland (In-Service 2 drops/5 cycles) 1 drop/100 cycles max at Input Shaft (In-Service 1 drop/25 cycles)	Rod-Gland <u>.5</u> drops Aft Gland <u>.5</u> drops Center <u>1.5</u> drops Gland Input Shaft <u>0</u> drops		
✓ 12.J. Internal Leakage	(1) Rig neutral leakage at RA & RB. 300 cc/min - overhaul. 3000 cc/min - In-Service. (2) & (3) Input lever at extend & retract stops 300-700 cc/min - overhaul. 300-1085 cc/min - In-Service.	Neutral RA RB <u>190</u> <u>200</u> Ext. RA RB <u>410</u> <u>420</u> Ret. <u>420</u> <u>360</u>		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-Service

Work Order _____

PART NO. 65-44861-9/65C37052-SERIAL NO. 1596ADATE OF TEST 8/29/96PART NAME RUDDER ACTUATOR PCUINSPECTOR KOSKINEN☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
✓ 12.J. Internal Leakage (Continued)	(4) 65-44861 and 65C37052 System A energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	Neutral RA RB ____		
	(5) 65-44861 and 65C37052 System A energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	Ext. RA RB ____		
	(6) 65-44861-5 thru -9,-11 and 65C37052-5 thru -9 System B energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	Ret. RB ____		
	(7) 65-44861-5 thru -9,-11 and 65C37052-5 thru -9 System B energized 1370 cc/min @ RB 2000 cc/min above leakage measured in step (1) (b) @ RB for In-Service	Neutral RB 660		
		Ext. RB 660		
		Ret. RB 680		





TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-Service

Work Order _____

PART NO. 65-44861-9/65C37052- SERIAL NO. 1596A DATE OF TEST 8/29/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
✓ 12.K. Intersystem Leakage	Combined leakage from PB and RB 10 cc/min maximum.	<u>1</u> cc/min		
✓ 12.L. Transducer Output	4.2-4.8 VAC 65-44861-2 and 65C37052-2 (Sys A & B) 1.95-2.55 VAC 65-44861-3,-4 and 65C37052-2,-3,-4 (Sys A & B) 1.95-2.55 VAC 65-44861-5,-8 and 65C37052-5,-8 (Sys B) 3.07-3.67 VAC 65-44861-6,-7,-9,-11 and 65C37052-6,-7,-9 (Sys B)	"A" Extend _____ VAC Retract _____ VAC "B" Extend <u>3.52</u> VAC Retract <u>3.51</u> VAC		
✓ 12.M. Transducer Null	50 MV maximum at null for each system - Overhaul. 150 MV maximum at null for each system In-Service.	"A" Null _____ VAC "B" Null <u>.059</u> VAC		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-Service

Work Order _____

PART NO. 65-44861-9/65C37052SERIAL NO. 1596ADATE OF TEST 8/29/96PART NAME RUDDER ACTUATOR PCUINSPECTOR KOSKINEN☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.N. Yaw Damper Authority	Per Figure 1, Ref. Test Data Sheet 10. Actuator must be stable and within .050" of neutral.	Ext. Ret. Sys "A" _____ Sys "B" <u>.231/.236</u> Sys "A & B" _____ Stable Yes No Position from "ZERO" _____ Ext. Ret. Stable Yes No Position from "ZERO" _____ Ext. Ret.		
12.P. Manual Hysteresis 4.3.14	Hysteresis shall not exceed .004 inch each direction - Overhaul. .006 inch each direction In-Service	Extend <u>.001</u> Inch Retract. <u>.0005</u> Inch		
12.Q. Yaw Damper System Phase Lag	Phase shift to be: 25 degrees (Sin Ø, 0.423) 30 degrees (Sin Ø, 0.500) for in-service units. No crossover in plot.	"A" sin Ø _____ "B" sin Ø <u>.311</u> Crossovers: Yes 		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-Service

Work Order _____

PART NO. 65-44861-9/65C37052 SERIAL NO. 1596A DATE OF TEST 8/29/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
✓ 12.R. Yaw Damper System Repeatability and Linearity	Pattern must repeat within 0.8" (.008" at actuator) - Overhaul. 1.2" (.012" at actuator) In-Service Overshoot after reversal must be 0.2" maximum (.002" at actuator) Average input/output slope of any 10% segment must fall within the slope limits shown.	"A" _____ in max "B" <u>.22</u> in max "A" _____ in max "B" <u>.01</u> in max "A" Yes No "B" <u>Yes</u> No	<u>GSO</u> <u>22</u> <u>FTO</u>	
✓ 12.S. Phase Check	Manual control "extend", actuator must extend. Manual control "retract", actuator must retract. Operation smooth and stable for A and B.	Extend "A" <u>EXT</u> "B" <u>EXT</u> Retract "A" <u>RET</u> "B" <u>RET</u> Stable: <u>Yes</u> No	<u>GSO</u> <u>22</u> <u>FTO</u>	
✓ 12.T. Yaw Damper Engage 4.3.17	.004" maximum movement-overhaul .010" maximum movement-In-Service.	"A" _____ in "B" <u>.003</u> in	<u>GSO</u> <u>22</u> <u>FTO</u>	
✓ 12.U. By-Pass Valve Operation	(4) No piston movement at 250 PSI differential for either system. (6a) Noticeable decrease in flow at less than 460 PSI differential. (8) Piston rod movement of 1.00 inch or more in either direction.	"A" Yes <u>No</u> "B" Yes <u>No</u> "A" <u>350</u> PSI "B" <u>360</u> PSI Ext. <u>✓</u> OK Ret. <u>✓</u> OK	<u>GSO</u> <u>22</u> <u>FTO</u>	



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☐ In-Service

Work Order _____

PART NO. 65-44861-9/65C37052- SERIAL NO. 1596A DATE OF TEST 8/29/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.V. Duty Cycle (optional) Not Required for In-Service Unless Actuator Seals Were Replaced	3.0 cc/8 hours maximum at each piston rod seal. 6.0 cc/8 hours at center gland - Overhaul. 1.8 cc/hr maximum at each piston rod seal. 3.6 cc/hr at center gland - In-Service.	Output End ____ cc ____ hrs Fixed End ____ cc ____ hrs Center ____ cc ____ hrs		
12.W. Low Pressure Leakage (not same as 12.V.)	No external leakage in 8 hours - overhaul. No external leaks in one hour In-Service.	____ cc ____ hrs		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-Service

Work Order

12

PART NO. 65-44861-9/65C37052 SERIAL NO. 1596A DATE OF TEST 8/29/96PART NAME RUDDER ACTUATOR PCU INSPECTOR KOSKINEN☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

OVERHAULED UNIT


PCU Assembly	Actuator Output Stroke (inches)		
	System A	System B	System AB
65-44861-2 65C37052-2	0.294 to 0.334	0.294 to 0.334	0.335 to 0.375
65-44861-3,-4 65C37052-3,-4	0.137 to 0.177	0.137 to 0.177	0.294 to 0.334
65-44861-5,-8 65C37052-5,-8	—	0.137 to 0.177	—
65-44861-6,-7,-9,-11 65C37052-6,-7,-9	—	0.215 to 0.255	—

IN-SERVICE UNIT

PCU Assembly	Actuator Output Stroke (inches)		
	System A	System B	System AB
65-44861-2 65C37052-2	0.274 to 0.354	0.274 to 0.354	0.315 to 0.394
65-44861-3,-4 65C37052-3,-4	0.117 to 0.197	0.117 to 0.197	0.274 to 0.354
65-44861-5,-8 65C37052-5,-8	—	0.117 to 0.197	—
65-44861-6,-7,-9,-11 65C37052-6,-7,-9	—	0.196 to 0.276	—

Actuator Output Stroke Limits
Figure 1

DRAWN: *n. m. m. m.* DATE: *12-2-80* ENG. APPR: *[Signature]* DATE: *12-2-80* TEST APPR: *[Signature]* DATE: *12-2-80*



PAGE 8 OF 10 ACCEPTANCE TEST DATA SHEETS

DATE TESTED: 12/29/80

SIZE
B

BERTEA CORPORATION
IRVINE, CALIFORNIA

INSP: *Roskner*

FSCM
NO.
02106

65-44861LG

REV
G

PART NO. 65-44861-9

PROJECT 737 PAGE 1, 743

UHM 21-20-01

DRAWN: 2-10-80DATE: 10-2-80 ENG. APPR: 10-2-80



DATE:

TEST APPR: 10-2-80DATE: 10-2-80SINE Ø MAXIMUM PER TEST REQ'T .423 OVERHAUL .500 IN SERVICE

65-44861LG

SERIAL NO. / 596A

$$2 \sqrt{\frac{C}{A} + \frac{D}{B}} = \text{SINE } \phi$$

CALCULATION

SYS A

TEST 12Q

SYS B

PHASE LAG

SINE Ø .

SINE Ø .311

(- 5 ASSY, 1 SYSTEM ONLY)

PAGE 9 OF 10 ACCEPTANCE TEST DATA SHEETS

DATE TESTED: 8/29/86SIZE
BBERTEA CORPORATION
IRVINE, CALIFORNIAINSP: KOSKINENFSCM
NO.
8210665-44861LG (2) REV
GPART NO. 65-44861-9
& DASH NO.

PROJECT 737

PAGE 750

OHM 27-20-OI

DRAWN: *n. m. m. m.*

DATE: 10-2-88

ENG. APPR: *n. m. m. m.*

DATE: 10-2-88


TEST APPR: *E. C. m. m.*

DATE: 10-2-88


DATE: 10-2-88

65-4486ILG

SERIAL NO. 1596A



SYSTEM A



SYSTEM B

TEST 12R
REPEATABILITY AND LINEARITY
(-5 ASSY, 1 SYSTEM ONLY)

PAGE 10 OF 10 ACCEPTANCE TEST DATA SHEETS			
DATE TESTED: 10/29/96	SIZE B	BERTEA CORPORATION DIVISION - CALIFORNIA	
INSP: <i>KOSKINEN</i>	FSCM NO. 02106	65-4486ILG (3)	REV G
PART NO. & DASH NO. 65-44861-9	PROJECT 737	PAGE 751	

OHM 27-20-01

CNGR UNIT

Parker

TEST DATA RECORD

Customer Support Operations

Rev. HDrawn U. D. P. H.Date 3/30/95Test Approval P. R. S. P.Date 3/30/95Eng. Approval P. R. S. P.Date 3-30-95Overhaul Manual 27-20-01☐ Overhaul ☒ In-ServiceWork Order 657 7672-100PART NO. 65-44861-1/65G37052 SERIAL NO. 2203 H DATE OF TEST 8-20-96PART NAME BUDDER ACTUATOR PCU INSPECTOR W. A. Smith☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.																																						
11.A. Continuity Check	Check Continuity per wiring diagram (Fig. 403, Fig. 403A).	_____OK																																								
11.B. Pin to Pin Resistance	Check pin to pin resistance at 70°F and record. Must comply with noted valve. <table><thead><tr><th>Pins</th><th>Resistance</th><th>Sys "A"</th><th>Sys "B"</th></tr></thead><tbody><tr><td>1-2</td><td>71-87 OHMS (Solenoid PN 59600)</td><td>_____</td><td>_____81</td></tr><tr><td>1-2</td><td>49-62 OHMS (Solenoid PN 45080 @ 77°F)</td><td>_____</td><td>_____</td></tr><tr><td>1-2</td><td>79-115 OHMS (Solenoid PN 45080-1 @ 77°F)</td><td>_____</td><td>_____</td></tr><tr><td>5-6</td><td>900-1100 OHMS</td><td>_____</td><td>_____1004</td></tr><tr><td>7-8</td><td>900-1100 OHMS</td><td>_____</td><td>_____1009</td></tr><tr><td>1-4</td><td>0 OHMS (Short)</td><td>_____</td><td>_____3</td></tr><tr><td>9-10</td><td>80-165 OHMS</td><td>_____</td><td>_____107</td></tr><tr><td>11-12</td><td>60-135 OHMS</td><td>_____</td><td>_____86</td></tr><tr><td>3-Other</td><td>Infinite (No Connection)</td><td>_____</td><td>_____</td></tr></tbody></table>	Pins	Resistance	Sys "A"	Sys "B"	1-2	71-87 OHMS (Solenoid PN 59600)	_____	_____81	1-2	49-62 OHMS (Solenoid PN 45080 @ 77°F)	_____	_____	1-2	79-115 OHMS (Solenoid PN 45080-1 @ 77°F)	_____	_____	5-6	900-1100 OHMS	_____	_____1004	7-8	900-1100 OHMS	_____	_____1009	1-4	0 OHMS (Short)	_____	_____3	9-10	80-165 OHMS	_____	_____107	11-12	60-135 OHMS	_____	_____86	3-Other	Infinite (No Connection)	_____	_____	_____ _____
Pins	Resistance	Sys "A"	Sys "B"																																							
1-2	71-87 OHMS (Solenoid PN 59600)	_____	_____81																																							
1-2	49-62 OHMS (Solenoid PN 45080 @ 77°F)	_____	_____																																							
1-2	79-115 OHMS (Solenoid PN 45080-1 @ 77°F)	_____	_____																																							
5-6	900-1100 OHMS	_____	_____1004																																							
7-8	900-1100 OHMS	_____	_____1009																																							
1-4	0 OHMS (Short)	_____	_____3																																							
9-10	80-165 OHMS	_____	_____107																																							
11-12	60-135 OHMS	_____	_____86																																							
3-Other	Infinite (No Connection)	_____	_____																																							

Rev. H☐ Overhaul ☒ In-Service

Work Order 657 7672-100

PART NO. <u>65-44861-III/65C37052</u>		SERIAL NO. <u>2203 A</u>		DATE OF TEST <u>8-20-96</u>	
PART NAME <u>RUDDER ACTUATOR PCU</u>			INSPECTOR <u>[Signature]</u>		
☒ PHOSPHATE ESTER		☐ MIL-H-5606		☐ MIL-H-83282	
☐ AIR		☐ PD680			

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
11.C. Dielectric Strength (Continued)	1000 VAC Body and Pins 2,5,7 connected to common lead to Pin 11 (Fig. 403)	_____ OK		
	1000 VAC Body and Pins 1,5,7 connected to common lead to Pin 11.	_____ OK		
	1000 VAC Body and Pins 1,5,7 connected to common lead to Pin 9.	_____ OK		
	800 VAC between Pins 5 and 7	_____ OK		
	800 VAC between Pins 9 and 11 (Fig. 403A)	_____ OK		
11.D. Insulation Resistance	500 VDC between noted pins 100 Megohms min resistance 10 megohms min in-service. (Fig. 403)			
	<u>Pins</u> 1,5,7,9 & 11 to Body 1 to 5,7,9 & 11 5 to 7,9, & 11 7 to 9 & 11 9 to 11	<u>Sys "A"</u> <u>Sys "B"</u> _____ _____ _____ _____ _____		

R'C'V'G' TEST



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☒ In-ServiceWork Order 6577672-100

PART NO. <u>65-44861-111/65C37052</u> SERIAL NO. <u>220314</u> DATE OF TEST <u>8-20-96</u>				
PART NAME <u>RUDDER ACTUATOR PCU</u> INSPECTOR <u>W. J. Smith</u>				
☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680				
TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.B. Return Pressure	No external leakage or permanent set, each test. No intersystem leakage.	3000 3 ± 2 Sys A <u>None</u> <u>None</u> Sys B <u>None</u> <u>None</u>	CSO 69 FTO	
12.C.3 & .4 Secondary Stroke/Flow Test	Measure and record leakage at open ports Ra and Rb. The unit shall not move after 25 lbs. is applied to lever TF83300-53, and leakage at each return port must not exceed the following: (a) 300-700 cc/min for overhauled unit. (b) 300-1085 cc/min for unit in service. <u>NOTE: Visual inspect lock to verify proper engagement.</u>	Extend (12.C.3) Ra <u>570</u> cc/min Rb <u>590</u> cc/min Retract (12.C.4) Ra <u>530</u> cc/min Rb <u>530</u> cc/min Movement, <u>0.00</u> in.	CSO 69 FTO	
12.D. Proof Pressure	No external leakage or permanent set, each test. No intersystem leakage.	5400 3 ± 2 Sys A <u>None</u> <u>None</u> Sys B <u>None</u> <u>None</u>	CSO 69 FTO	
12.E. Rig Neutral Cylinder Stroke and Clearance Test	Output Rig Pin must fit. (27.46 - 27.54 Ref.) No binding or interference at 8000 PSI. Stroke 26° ± 1° each direction. Visual snubbing. No binding or interference at 0 PSI.	Rig Pin <u>GO</u> Surface Indicator at 0° <u>Yes</u> Binding <u>No</u> Yes <u>No</u> Ext. <u>25.5°</u> Ret. <u>25.5°</u> Snubbing <u>OK</u> <u>OK</u>	CSO 69 FTO	



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☒ In-ServiceWork Order 6577672-100PART NO. 65-44861-11/65C37052 SERIAL NO. 2203A DATE OF TEST 8-20-91PART NAME RUDDER ACTUATOR PCUINSPECTOR [Signature]☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.F. Linkage Breakout Friction	19 oz. maximum to start extend. 1 oz. minimum in extend direction to start retract.	Ext. <u>14</u> Oz. Ret. <u>6</u> Oz.		
12.G. Input Force vs. Input Travel	Force plot must fall within limits shown on Fig. 723.	<u>✓</u> OK		
12.H. Cylinder Rod Leakage	1 drop/25 cycles max at each End Gland (In-Service 1 drop/5 cycles) 2 drops/25 cycles max. at Center Gland (In-Service 2 drops/5 cycles) 1 drop/100 cycles max at Input Shaft (In-Service 1 drop/25 cycles)	Rod Gland <u>0</u> drops Aft Gland <u>0</u> drops Center <u>0</u> drops Gland Input Shaft <u>0</u> drops		
12.J. Internal Leakage	(1) Rig neutral leakage at RA & RB. 300 cc/min - overhaul. 3000 cc/min - In-Service. (2) & (3) Input lever at extend & retract stops 300-700 cc/min - overhaul 300-1085 cc/min - In-Service	Neutral RA RB <u>260</u> <u>280</u> Ext. RA RB <u>540</u> <u>555</u> Ret. <u>540</u> <u>520</u>		


R/C/V/G TEST




TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01 ☐ Overhaul ☒ In-ServiceWork Order 6577672-100PART NO. 65-44861-1/65C37052 SERIAL NO. 2203 H DATE OF TEST 8-20-96PART NAME RUDDER ACTUATOR PCU INSPECTOR ~~Don Smith~~☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.J. Internal Leakage (Continued)	(4) 65-44861 and 65C37052 System A energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	Neutral RA RB  - //		
	(5) 65-44861 and 65C37052 System A energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	Ext. RA RB Ret.  - //		
	(6) 65-44861-5 thru -9, -11 and 65C37052-5 thru -9 System B energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	RB Neutral <u>670</u>		
	(7) 65-44861-5 thru -9, -11 and 65C37052-5 thru -9 System B energized 1370 cc/min @ RB 2000 cc/min above leakage measured in step (1) (b) @ RB for In-Service	Ext. RB <u>670</u> Ret. <u>650</u>		





TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☒ In-ServiceWork Order 6577672-100PART NO. 65-44861-1/1/65C37052 SERIAL NO. 2203A DATE OF TEST 8-20-90PART NAME RUDDER ACTUATOR PCU INSPECTOR 6577672-100☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.K. Intersystem Leakage	Combined leakage from PB and RB 10 cc/min maximum.	<u>1.4</u> cc/min	CSO 69 FTO	
12.L. Transducer Output	4.2-4.8 VAC 65-44861-2 and 65C37052-2 (Sys A & B) 1.95-2.55 VAC 65-44861-3,-4 and 65C37052-2,-3,-4 (Sys A & B) 1.95-2.55 VAC 65-44861-5,-8 and 65C37052-5,-8 (Sys B) 3.07-3.67 VAC 65-44861-6,-7,-9,-11 and 65C37052-6,-7,-9 (Sys B)	"A" Extend <u>3.3</u> VAC Retract <u>3.3</u> VAC "B" Extend <u>3.47</u> VAC Retract <u>3.54</u> VAC	CSO 69 FTO	
12.M. Transducer Null	50 MV maximum at null for each system - Overhaul. 150 MV maximum at null for each system In-Service.	CSO N.R. EXPLAIN BELOW Null <u>11</u> VAC "B" Null <u>.014</u> VAC	CSO 69 FTO	


R'C'V'G' TEST



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☒ In-ServiceWork Order 6577672-100PART NO. 65-44861-1/65C37052 SERIAL NO. 2203 A DATE OF TEST 8-20-96PART NAME RUDDER ACTUATOR PCU INSPECTOR ~~COA Smith~~☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.N. Yaw Damper Authority	Per Figure 1, Ref. Test Data Sheet 10. Actuator must be stable and within .050" of neutral.	Ext. Ret. Sys "A" <u>11</u> Sys "B" <u>237/241</u> Sys "A & B"  Stable Yes <u>No</u>  Position from "ZERO" Ext. Ret. Stable Yes No  Position from "ZERO" Ext. Ret. <u>- 11</u>		
12.P. Manual Hysteresis 4.3.14	Hysteresis shall not exceed .004 inch each direction - Overhaul. .006 inch each direction In-Service	Extend <u>.0000</u> Inch Retract <u>.0005</u> Inch 		
12.Q. Yaw Damper System Phase Lag	Phase shift to be: 25 degrees (Sin Ø, 0.423) 30 degrees (Sin Ø, 0.500) for in-service units No crossover in plot.	"A" Sin Ø <u>0-11</u> "B" Sin Ø <u>.444</u> Crossovers: Yes No		

R/C 'G' TEST



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. H

Overhaul Manual 27-20-01

☐ Overhaul☒ In-ServiceWork Order 6577672-100PART NO. 65-44861-11/65C37052 SERIAL NO. 2203A DATE OF TEST 8-20-96PART NAME RUDDER ACTUATOR PCUINSPECTOR W. A. Smith☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.R. Yaw Damper System Repeatability and Linearity	Pattern must repeat within 0.8" (.008" at actuator) - Overhaul. 1.2" (.012" at actuator) In-Service Overshoot after reversal must be 0.2" maximum (.002" at actuator) Average input/output slope of any 10% segment must fall within the slope limits shown.	350 33 NR EXPLAIN BELOW 350 33 NR EXPLAIN BELOW "A" <u>1</u> in max "B" <u>0.35</u> in max "A" <u>11</u> in max "B" <u>0.10</u> in max "A" Yes No "B" Yes No	015 69	
12.S. Phase Check	Manual control "extend", actuator must extend. Manual control "retract", actuator must retract. Operation smooth and stable for A and B.	Extend "A" <u>OK</u> "B" <u>OK</u> Retract "A" <u>OK</u> "B" <u>OK</u> Stable: Yes No	015 69	
12.T. Yaw Damper Engage 4.3.17	.004" maximum movement-overhaul .010" maximum movement-In-Service.	350 33 NR EXPLAIN BELOW "A" <u>11</u> in "B" <u>.001</u> in	60 69 FTC	
12.U. By-Pass Valve Operation	(4) No piston movement at 250 PSI differential for either system. (6a) Noticeable decrease in flow at less than 460 PSI differential. (8) Piston rod movement of 1.00 inch or more in either direction.	350 33 NR EXPLAIN BELOW "A" Yes <u>(NO)</u> "B" Yes <u>(NO)</u> "A" <u>345</u> PSI "B" <u>350</u> PSI Ext. <u>✓</u> OK Ret. <u>✓</u> OK	350 69 FTD	



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. H

Overhaul Manual 27-20-01

☐ Overhaul ☒ In-ServiceWork Order 657 7672-100PART NO. 65-44861- /65C37052- SERIAL NO. 2203 A DATE OF TEST 8-20-96PART NAME RUDDER ACTUATOR PCU INSPECTOR [Signature]☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.V. Duty Cycle (optional) Not Required for In-Service Unless Actuator Seals Were Replaced	3.0 cc/8 hours maximum at each piston rod seal. 6.0 cc/8 hours at center gland - Overhaul. 1.8 cc/hr maximum at each piston rod seal. 3.6 cc/hr at center gland - In-Service.	Output End ____ cc ____ hrs Fixed End ____ cc ____ hrs Center ____ cc ____ hrs		
12.W. Low Pressure Leakage (not same as 12.V.)	No external leakage in 8 hours - overhaul. No external leaks in one hour In-Service.	____ cc ____ hrs		

RCV'E



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☒ In-ServiceWork Order 6577672-100PART NO. 65-44861-1/65C37052 SERIAL NO. 2203 A DATE OF TEST 8-20-96PART NAME RUDDER ACTUATOR PCU INSPECTOR [Signature]☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

OVERHAULED UNIT			
PCU Assembly	Actuator Output Stroke (inches)		
	System A	System B	System AB
65-44861-2 65C37052-2	0.294 to 0.334	0.294 to 0.334	0.335 to 0.375
65-44861-3,-4 65C37052-3,-4	0.137 to 0.177	0.137 to 0.177	0.294 to 0.334
65-44861-5,-8 65C37052-5,-8	—	0.137 to 0.177	—
65-44861-6,-7,-9,-11 65C37052-6,-7,-9	—	0.215 to 0.255	—

IN-SERVICE UNIT			
PCU Assembly	Actuator Output Stroke (inches)		
	System A	System B	System AB
65-44861-2 65C37052-2	0.274 to 0.354	0.274 to 0.354	0.315 to 0.394
65-44861-3,-4 65C37052-3,-4	0.117 to 0.197	0.117 to 0.197	0.274 to 0.354
65-44861-5,-8 65C37052-5,-8	—	0.117 to 0.197	—
65-44861-6,-7,-9,-11 65C37052-6,-7,-9	—	0.196 to 0.276	—

Actuator Output Stroke Limits
Figure 1

SYS. "A" ☐ "B" ☒

FORCE AT
PILOT
INPUT

65-44861LG

SERIAL NO. 2203A

65-44861-3 THRU -9, -11
65C37052-3 THRU -9

65-44861-2
65C37052-2

WALKING
BEAM

65-44861-3 THRU -9, -11
65C37052-3 THRU -9

MOD.
PISTON

30 LBS

MOD.
PISTON

WALKING
BEAM

65-44861-2
65C37052-2

INSERVICE

RETRACT

SEC.

SEC.

INSERVICE

EXTEND

PRIMARY

.350 .300 .250 .200 .150 .100 .050 0 .050 .100 .150 .200 .250 .300 .350

INPUT LEVER TRAVEL FROM VALVE NULL, WITH CYLINDER ROD BOTTOMED

INPUT FORCE VS INPUT TRAVEL
TEST 12G (65 FTD)

R'C'V'G' TEST

R'C'V'G' TEST

PAGE 8 OF 10 ACCEPTANCE TEST DATA SHEETS

DATE TESTED: 8-20-56

SIZE
B

BERTEA CORPORATION
IRVINE, CALIFORNIA

INSP: W.A. Smith

FSOM
NO.
82106

65-44861LG (1)

REV
G

PART NO.
& DASH NO. 65-44861-11

PROJECT 737

PAGE 743

OHM 27-20-01

SINE Ø MAXIMUM PER TEST REQ'T .423 OVERHAUL .500 IN SERVICE

65-44861LG

SERIAL NO. 2203A

$2 \sqrt{\frac{C}{A} + \frac{D}{B}} = \text{SINE } \phi$
CALCULATION

D

C

A

$\frac{A}{2}$

R'C'V'G' TEST
PHASE LAG
EXAMPLE

$\frac{B}{2}$

B

SYS A

TEST 120
PHASE LAG

SYS B

SINE Ø

SINE Ø

.444



R'C'V'G' TEST

(-5 ASSY, 1 SYSTEM ONLY)


PAGE 9 OF 10 ACCEPTANCE TEST DATA SHEETS

DATE TESTED: 8-20-94	SIZE B	BERTEA CORPORATION FARMERS CALIFORNIA
INSP: LWA Smith	FSCM NO. 82106	REV G
657 7672-100		65-44861LG (2)
PART NO. 65-44861-11	PROJECT 737	PAGE 755
DASH NO.		

OHM 27-2Q-01

65-44861LG


SERIAL NO. 2253A



SYSTEM A

R'C'V'G' TEST

TEST 12R
REPEATABILITY AND LINEARITY
(-5 ASSY, 1 SYSTEM ONLY)



SYSTEM B

R'C'V'G' TEST

PAGE 10 OF 10 ACCEPTANCE TEST DATA SHEETS			
DATE TESTED: 8-20-76	SIZE B	BERTEA CORPORATION IRVINE, CALIFORNIA	
INSP: W.A. Smith	FSCM NO. 82106	65-44861LG (3)	REV G
PART NO. 65-37052 & DASH NO. 65-44861-11	PROJECT 737	PAGE 751	
OHM 27-20-01			



TEST DATA RECORD

Customer Support Operations

Rev. HDrawn H. L. P. H. Date 3/30/95Test Approval B. H. Spence Date 3/30/95Eng. Approval [Signature] Date 3-30-95Overhaul Manual 27-20-01☐ Overhaul ☐ In-Service

Work Order _____

PART NO. 65-44861-1/65C37052- SERIAL NO. 2203A DATE OF TEST 8-29-95PART NAME RUDDER ACTUATOR PCU INSPECTOR BIGGERSTAFF☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.																																							
11.A. Continuity Check	Check Continuity per wiring diagram (Fig. 403, Fig. 403A).	_____ OK																																									
11.B. Pin to Pin Resistance	Check pin to pin resistance at 70°F and record. Must comply with noted valve. <table border="1"><thead><tr><th>Pins</th><th>Resistance</th><th>Sys "A"</th><th>Sys "B"</th></tr></thead><tbody><tr><td>1-2</td><td>71-87 OHMS (Solenoid PN 59600)</td><td>_____</td><td>_____</td></tr><tr><td>1-2</td><td>49-62 OHMS (Solenoid PN 45080 @ 77°F)</td><td>_____</td><td>_____</td></tr><tr><td>1-2</td><td>79-115 OHMS (Solenoid PN 45080-1 @ 77°F)</td><td>_____</td><td>_____</td></tr><tr><td>5-6</td><td>900-1100 OHMS</td><td>_____</td><td>_____</td></tr><tr><td>7-8</td><td>900-1100 OHMS</td><td>_____</td><td>_____</td></tr><tr><td>1-4</td><td>0 OHMS (Short)</td><td>_____</td><td>_____</td></tr><tr><td>9-10</td><td>80-165 OHMS</td><td>_____</td><td>_____</td></tr><tr><td>11-12</td><td>60-135 OHMS</td><td>_____</td><td>_____</td></tr><tr><td>3-Other</td><td>Infinite (No Connection)</td><td>_____</td><td>_____</td></tr></tbody></table>	Pins	Resistance	Sys "A"	Sys "B"	1-2	71-87 OHMS (Solenoid PN 59600)	_____	_____	1-2	49-62 OHMS (Solenoid PN 45080 @ 77°F)	_____	_____	1-2	79-115 OHMS (Solenoid PN 45080-1 @ 77°F)	_____	_____	5-6	900-1100 OHMS	_____	_____	7-8	900-1100 OHMS	_____	_____	1-4	0 OHMS (Short)	_____	_____	9-10	80-165 OHMS	_____	_____	11-12	60-135 OHMS	_____	_____	3-Other	Infinite (No Connection)	_____	_____		
Pins	Resistance	Sys "A"	Sys "B"																																								
1-2	71-87 OHMS (Solenoid PN 59600)	_____	_____																																								
1-2	49-62 OHMS (Solenoid PN 45080 @ 77°F)	_____	_____																																								
1-2	79-115 OHMS (Solenoid PN 45080-1 @ 77°F)	_____	_____																																								
5-6	900-1100 OHMS	_____	_____																																								
7-8	900-1100 OHMS	_____	_____																																								
1-4	0 OHMS (Short)	_____	_____																																								
9-10	80-165 OHMS	_____	_____																																								
11-12	60-135 OHMS	_____	_____																																								
3-Other	Infinite (No Connection)	_____	_____																																								
11.C. Dielectric Strength	Slowly apply noted voltages and hold for a period of 5 seconds (Fig. 403), 1 min (Fig. 403A). There must be no arcing or insulation failure. 1500 VAC Body to Pin 2 (Fig. 403) 1500 VAC Body to Pin 1 (Fig. 403A) 1000 VAC Body and Pins 2,5,7 connected to common lead to Pin 9 (Fig. 403)	_____ OK _____ OK _____ OK																																									

TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul: Mar 2001 27-20-01☐ Overhaul☒ In-Service

Work Order

PART NO. 65-44861-1/165C37052 SERIAL NO. 2203A DATE OF TEST 8-29-28

PART NAME RUDDER ACTUATOR PCU INSPECTOR BIGGERSTAFF

☒ PHOSPHATE ESTER

MIL-H-5606

MIL-H-83282

☐ AIR

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
11.C. Dielectric Strength (Continued)	1000 VAC Body and Pins 2,5,7 connected to common lead to Pin 11 (Fig. 403) 1000 VAC Body and Pins 1,5,7 connected to common lead to Pin 11. 1000 VAC Body and Pins 1,5,7 connected to common lead to Pin 9. 800 VAC between Pins 5 and 7 800 VAC between Pins 9 and 11 (Fig. 403A)	_____ OK _____ OK _____ OK _____ OK _____ OK		
11.D. Insulation Resistance	500 VDC between noted pins 100 Megohms min resistance 10 megohms min in-service. (Fig. 403) <u>Pins</u> 1,5,7,9 & 11 to Body 1 to 5,7,9 & 11 5 to 7,9, & 11 7 to 9 & 11 9 to 11	<u>Sys "A"</u> <u>Sys "B"</u> _____ _____ _____ _____ _____		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01 ☐ Overhaul ☒ In-Service

Work Order _____

PART NO. 65-44861-1/165637052 SERIAL NO. 2203 A DATE OF TEST 8-29-86PART NAME RUDDER ACTUATOR PCU INSPECTOR BIGGERSTAFF☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.B. Return Pressure	No external leakage or permanent set, each test. No intersystem leakage.	3000 3 ± 2 Sys A _____ Sys B _____		
12.C.3 & .4 Secondary Stroke/Flow Test	Measure and record leakage at open ports Ra and Rb. The unit shall not move after 25 lbs. is applied to lever TF83300-53, and leakage at each return port must not exceed the following: (a) 300-700 cc/min for overhauled unit. (b) 300-1085 cc/min for unit in service. <i>NOTE: Visual inspect lock to verify proper engagement.</i>	Extend (12.C.3) Ra _____ cc/min Rb _____ cc/min Retract (12.C.4) Ra _____ cc/min Rb _____ cc/min Movement _____ in.		
12.D. Proof Pressure	No external leakage or permanent set, each test. No intersystem leakage.	5400 3 ± 2 Sys A _____ Sys B _____		
✓ 12.E. Rig Neutral Cylinder Stroke and Clearance Test	Output Rig Pin must fit. (27.46 - 27.54 Ref.) No binding or interference at 3000 PSI. Stroke 26° ± ½° each direction. Visual snubbing. No binding or interference at 0 PSI.	Rig Pin <u>YES</u> Surface Indicator at 0° <u>✓</u> Binding <u>No</u> Yes <u>No</u> Ext <u>25.5°</u> Ret <u>25.5°</u> Snubbing <u>✓</u> OK <u>✓</u> OK		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☒ In-Service

Work Order _____

PART NO. 65-44861-1/65C97052 SERIAL NO. 22031 DATE OF TEST 8-29-94PART NAME RUDDER ACTUATOR PCU INSPECTOR BIGGERSTAFF☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.F. Linkage Breakout Friction	19 oz. maximum to start extend. 1 oz. minimum in extend direction to start retract.	Ext. <u>9.75</u> Oz. Ret. <u>1.5</u> Oz.		
12.G. Input Force vs. Input Travel	Force plot must fall within limits shown on Fig. 723.	OK		
12.H. Cylinder Rod Leakage	1 drop/25 cycles max at each End Gland (In-Service 1 drop/5 cycles) 2 drops/25 cycles max. at Center Gland (In-Service 2 drops/5 cycles) 1 drop/100 cycles max at Input Shaft (In-Service 1 drop/25 cycles)	Rod Gland <u>0</u> drops Aft Gland <u>0</u> drops Center <u>TRACE</u> drops Gland Input Shaft <u>0</u> drops		
12.J. Internal Leakage	(1) Rig neutral leakage at RA & RB. 300 cc/min - overhaul. 3000 cc/min - In-Service. (2) & (3) Input lever at extend & retract stops 300-700 cc/min - overhaul. 300-1085 cc/min - In-Service.	Neutral RA RB <u>270</u> <u>280</u> Ext. RA RB <u>540</u> <u>550</u> Ret. <u>540</u> <u>520</u>		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☒ In-Service

Work Order _____

PART NO. 65-44861-1/65C37052 SERIAL NO. 220311 DATE OF TEST 8-29-84PART NAME RUDDER ACTUATOR PCU INSPECTOR BIGGERSTAFF☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.J. Internal Leakage (Continued)	(4) 65-44861 and 65C37052 System A energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	Neutral RA RB ____		
	(5) 65-44861 and 65C37052 System A energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	Ext. RA RB ____		
	(6) 65-44861-5 thru -9,-11 and 65C37052-5 thru -9 System B energized 1370 cc/min - overhaul 2000 cc/min above leakage measured in step (1) (b) In-Service	Ret. RB ____		
	(7) 65-44861-5 thru -9,-11 and 65C37052-5 thru -9 System B energized 1370 cc/min @ RB 2000 cc/min above leakage measured in step (1) (b) @ RB for In-Service	Neutral RB <u>670</u> Ext. RB <u>680</u> Ret. RB <u>690</u>		





TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☒ In-ServiceWork Order PART NO. 65-44861-11/65C37052- SERIAL NO. 2203A DATE OF TEST 8-29-86PART NAME RUDDER ACTUATOR PCUINSPECTOR BIGGERSTAFF☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.K. Intersystem Leakage	Combined leakage from PB and RB 10 cc/min maximum.	<u>1.1</u> cc/min		
12.L. Transducer Output	4.2-4.8 VAC 65-44861-2 and 65C37052-2 (Sys A & B) 1.95-2.55 VAC 65-44861-3,-4 and 65C37052-2,-3,-4 (Sys A & B) 1.95-2.55 VAC 65-44861-5,-8 and 65C37052-5,-8 (Sys B) 3.07-3.67 VAC 65-44861-6,-7,-9,-11 and 65C37052-6,-7,-9 (Sys B)	"A" Extend <u> </u> VAC Retract <u> </u> VAC "B" Extend <u>3.42</u> VAC Retract <u>3.45</u> VAC		
12.M. Transducer Null	50 MV maximum at null for each system - Overhaul. 150 MV maximum at null for each system In-Service.	"A" Null <u> </u> VAC "B" Null <u>0.15</u> VAC		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul☐ In-Service

Work Order _____

PART NO. 65-44861-1165C37052 SERIAL NO. 220311 DATE OF TEST 8-29-96PART NAME RUDDER ACTUATOR PCUINSPECTOR BIGGERSTAFF☒ PHOSPHATE ESTER☐ MIL-H-5606☐ MIL-H-83282☐ AIR☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.N. Yaw Damper Authority	Per Figure 1, Ref. Test Data Sheet 10. Actuator must be stable and within .050" of neutral.	Ext. Ret. Sys "A" _____ Sys "B" <u>236/.239</u> Sys "A & B" _____ Stable Yes No Position from "ZERO" _____ Ext. Ret. Stable Yes No Position from "ZERO" _____ Ext. Ret.		
12.P. Manual Hysteresis 4.3.14	Hysteresis shall not exceed .004 inch each direction - Overhaul. .006 inch each direction In-Service	Extend <u>.000</u> Inch Retract <u>.0005</u> Inch		
12.Q. Yaw Damper System Phase Lag	Phase shift to be: 25 degrees (Sin Ø, 0.423) 30 degrees (Sin Ø, 0.500) for in-service units. No crossover in plot.	"A" sin Ø _____ "B" sin Ø <u>.328</u> Crossovers: Yes		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☒ In-Service

Work Order _____

PART NO. <u>65-44861-11/65C37052</u> SERIAL NO. <u>220311</u> DATE OF TEST <u>8-29-74</u>				
PART NAME <u>RUDDER ACTUATOR PCU</u> INSPECTOR <u>BILGELSTADT</u>				
☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680				
TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.R. Yaw Damper System Repeatability and Linearity	Pattern must repeat within 0.8" (.008" at actuator) - Overhaul. 1.2" (.012" at actuator) In-Service Overshoot after reversal must be 0.2" maximum (.002" at actuator) Average input/output slope of any 10% segment must fall within the slope limits shown.	"A" _____ in max "B" <u>.0015</u> in max "A" _____ in max "B" <u>.000</u> in max "A" Yes No "B" <u>Yes</u> No		
12.S. Phase Check	Manual control "extend", actuator must extend. Manual control "retract", actuator must retract. Operation smooth and stable for A and B.	Extend "A" <u>EXT.</u> "B" <u>EXT.</u> Retract "A" <u>RET.</u> "B" <u>RET.</u> Stable: <u>Yes</u> No		
12.T. Yaw Damper Engage 4.3.17	.004" maximum movement-overhaul .010" maximum movement-In-Service.	"A" _____ in "B" <u>.0065</u> in		
12.U. By-Pass Valve Operation	(4) No piston movement at 250 PSI differential for either system. (6a) Noticeable decrease in flow at less than 460 PSI differential. (8) Piston rod movement of 1.00 inch or more in either direction.	"A" Yes <u>No</u> "B" Yes <u>No</u> "A" <u>.340</u> PSI "B" <u>.340</u> PSI Ext. <u>✓</u> OK Ret. <u>✓</u> OK		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. HOverhaul Manual 27-20-01☐ Overhaul ☐ In-Service

Work Order _____

PART NO. 65-44861-11/65C97052- SERIAL NO. 2203A DATE OF TEST 8-29-96PART NAME RUDDER ACTUATOR PCU INSPECTOR BIGGERSTAFF☒ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

TEST & REF.	REQUIREMENT	RESULTS	ACC	REJ.
12.V. Duty Cycle (optional) Not Required for In-Service Unless Actuator Seals Were Replaced	3.0 cc/8 hours maximum at each piston rod seal. 6.0 cc/8 hours at center gland - Overhaul. 1.8 cc/hr maximum at each piston rod seal. 3.6 cc/hr at center gland - In-Service.	Output End ____ cc ____ hrs Fixed End ____ cc ____ hrs Center ____ cc ____ hrs		
12.W. Low Pressure Leakage (not same as 12.V.)	No external leakage in 8 hours - overhaul. No external leaks in one hour In-Service.	____ cc ____ hrs		



TEST DATA RECORD (CONTINUATION)

Customer Support Operations

Rev. H

Overhaul Manual 27-20-01

☐ Overhaul ☐ In-Service

Work Order _____

PART NO. 65-44861- /65C37052- SERIAL NO. _____ DATE OF TEST _____

PART NAME RUDDER ACTUATOR PCU INSPECTOR _____

☐ PHOSPHATE ESTER ☐ MIL-H-5606 ☐ MIL-H-83282 ☐ AIR ☐ PD680

OVERHAULED UNIT

PCU Assembly	Actuator Output Stroke (inches)		
	System A	System B	System AB
65-44861-2 65C37052-2	0.294 to 0.334	0.294 to 0.334	0.335 to 0.375
65-44861-3,-4 65C37052-3,-4	0.137 to 0.177	0.137 to 0.177	0.294 to 0.334
65-44861-5,-8 65C37052-5,-8	_____	0.137 to 0.177	_____
65-44861-6,-7,-9,-11 65C37052-6,-7,-9	_____	0.215 to 0.255	_____

IN-SERVICE UNIT

PCU Assembly	Actuator Output Stroke (inches)		
	System A	System B	System AB
65-44861-2 65C37052-2	0.274 to 0.354	0.274 to 0.354	0.315 to 0.394
65-44861-3,-4 65C37052-3,-4	0.117 to 0.197	0.117 to 0.197	0.274 to 0.354
65-44861-5,-8 65C37052-5,-8	_____	0.117 to 0.197	_____
65-44861-6,-7,-9,-11 65C37052-6,-7,-9	_____	0.196 to 0.276	_____

Actuator Output Stroke Limits
Figure 1

DRAWN: *n. m. m.* DATE: *10-2-80* APPR: *W. J. J.* DATE: *10-2-80* TEST APPR: *E. J. J.* DATE: *10-2-80*

SYS. "A" ☐ "B" ☒

FORCE AT
PILOT
INPUT

65-44861LG

SERIAL NO. 2203A

65-44861-3 THRU -9, -11
65C37052-3 THRU -9

WALKING
BEAM

65-44861-2
65C37052-2

WALKING
BEAM

65-44861-2
65C37052-2

MOD.
PISTON

MOD.
PISTON

INSERVICE

RETRACT

SEC.

SEC.

INSERVICE

EXTEND

PRIMARY

INPUT LEVER TRAVEL FROM VALVE NULL, WITH CYLINDER ROD BOTTOMED

INPUT FORCE VS INPUT TRAVEL
TEST 12G

PAGE 8 OF 10 ACCEPTANCE TEST DATA SHEETS

DATE TESTED: *8-29-80*

INSP: *BILKERSTAFF*

PART NO.
& DASH NO. *65-44861-11*

SIZE
B

FSCM
NO.
82106

BERTEA CORPORATION
IRVING, CALIFORNIA

65-44861LG (1) REV
G

PROJECT 737 PAGE 743

OHM 27-20-01


DRAWN: 2 monthsDATE: 10-2-80 ENG. APPR: [Signature]DATE: 10-2-80TEST APPR: [Signature]DATE: 10-2-80SINE ϕ MAXIMUM PER TEST REQ'T .423 OVERHAUL .500 INSERVICE

65-44861LG

SERIAL NO. 22037

$$2 \sqrt{\frac{C}{A} + \frac{D}{B}} = \text{SINE } \phi$$

CALCULATION



SYS A

TEST 12Q

SYS B

PHASE LAG

SINE ϕ 1SINE ϕ .328

(-5 ASSY, 1 SYSTEM ONLY)

PAGE 9 OF 10 ACCEPTANCE TEST DATA SHEETS

DATE TESTED: 8-29-96SIZE
BBERTEA CORPORATION
IRVINE, CALIFORNIAINSP: BIGGERSTAFFFSCM
NO.
8210665-44861LG (2) REV
GPART NO.
& DASH NO. 65-44861-11

PROJECT 737

PAGE 750

OHM 27-20-01

DRAWN: *W. M. [signature]*

DATE: 10-2-82

ENG. APPR: *[signature]*


DATE: 10-2-82

TEST APPR: *[signature]*


DATE: 10-2-82

65-4486ILG

SERIAL NO. 2-203A



SYSTEM A



SYSTEM B

TEST 12R
REPEATABILITY AND LINEARITY
(-5 ASSY, 1 SYSTEM ONLY)

35
CTO

PAGE 10 OF 10 ACCEPTANCE TEST DATA SHEETS			
DATE TESTED: 8-29-80	SIZE B	BERTEA/CORPORATION	
INSP: <i>BIACERSTAFF</i>	FSCM NO. 82108	65-4486ILG (3)	REV G
PART NO. & DASH NO. 65-44861-11	PROJECT 737	PAGE 751	

OHM 27-20-01