



**MARQUETTE
TRANSPORTATION COMPANY**
150 Ballard Circle
Paducah, KY 42001

E475 Generator Electric End Maintenance - Monthly Marquette Warrior

Date Completed: 11/13/2021 5:27:02 PM

Generator Electric End

- Was the electrical cover on the generator electric end removed and all wires / connections checked for wire fray, chaffing and loose connections? Yes No N/A
- Were cooling air screens cleaned and free of oil and debris? Yes No N/A

Signature

- I certify that I have completed these tasks. Yes No N/A

Completed By crf
11/13/2021