

Appendix B

Relief Valve Group Factual Report

**Jacobs Engineering Group Contingency Analysis
Dated July 18, 1997**

Contingency Analysis

By: Terri Quintana

Date: July 18, 1997

System Protected: Product Inlet and Outlet Lines

P&ID: D-1902-D

Relief Device: RV-1919, 1923, 1932, 1941

Set Pressure: 740 psig

System MAWP: 740 psig @ 100 °F

The design of the relief system was examined for a total of 16 possible contingencies. The contingency(s) listed below apply to this system.

Surge

A surge from the Ferndale or Anacortes inlet or from Allen Station through the outlet lines potentially result in pressures exceeding the maximum allowable operating pressures for 300# rated piping. Full flow relief valves will be used to protect the piping during this condition.

The discharge of the relief valve will be piped to the transmix tank, TK-209. It is possible that the normal process operation of sending product to TK-209 may be occurring simultaneously with a surge relief condition on the other inlet line. This will result in a flowrate double the design flow through the process line. The transmix header was originally designed to be a 16-inch line. Due to the backpressure during a relief, either a pilot operated 8 X 10 valve would be required or if the transmix line is changed to 20-inch line a conventional 6 X 8 valve may be used.

Conclusions

1. The main limitations of pilot operated relief valves are viscous and dirty services which can clog pilots.
2. Diesel may be considered a dirty service.
3. Minimal price difference involved in installing 20" versus 16" line (approx. \$13,000).

Recommendations

1. Install 20" transmix line and install 6 x 8 conventional relief valve in this service.

From Bayview Products Terminal "Process Calculation Manual"
Jan. 1999.

~~CONFIDENTIAL~~
DO NOT COPY

Jacobs Engineering' 0001032

Jacobs Engineering Group Inc.
1670 Broadway, Suite 3200
Denver, Colorado 80202
303-830-6933 Fax 303-830-6911

MEMORANDUM

July 1997
~~April 7, 1998~~

TO: Ron Reed/ Karen Grauel
FROM: Terri Quintana
PROJECT NO. 05P88101
SUBJECT: Full Flow Surge Relief Requirement at Storage Tanks

During the Process Safety Review meeting it was recommended that full flow relief valves be considered for the inlet/outlet lines to the storage tanks. The scenarios that I looked at for these relief valves are the following: 1) product being pumped into the storage tank from Ferndale or Anacortes and tank inlet valve in the closed position, and 2) surge with tank inlet valve closed. The event of having the inlet valve closed and the manifold valve open may happen if the inlet valve is put into manual mode.

For the first scenario, Ferndale and Anacortes pump curves were evaluated to see if their shut in pressure is greater than the allowable working pressure for 150# piping flange class of 285 psig. There are three pumps at Ferndale, 2 of the 3 have shut in pressures greater than 285 psig (Ferndale #2 and #3). Both pumps at Anacortes have shut in pressures less than 285 psig. A relief valve is required to protect the line from overpressure in this scenario due to the pumps shut in pressure at Ferndale. The relief valve needs to be sized for the design flow rate of 12,000 BPH

For the second scenario, the surge may have been caused by the tank inlet valve closing which would result in the same shut in pressure as the first scenario. Therefore, using the same convention for scenario one sizing for surge relief, a full flow relief valve would be required.

Added RV-2065
RV-2082
RV-2072
RV-2077
RV-2088

~~CONFIDENTIAL~~
~~DO NOT COPY~~

0001033



0001034 4

To learn about this application press F5 then type INFO

TAG/EQUIP. NUMBER	Various	UNIT SERVICE:	Surge protection for 300d pipeline	P&ID:	D-1002	LOCATION:		COST CENTER:		
EQUIPMENT PROTECTED	Pipeline 300d rating			SET PRESS:	740 PSIG	BASIS:	Surge	Ksh(Vap)=	1.000	
EXISTING RV AREAS:	1.0	2.0	3.0	4.0	DISCHARGE DISPOSITION:	RELIEF HEADER				
CALCULATION METHOD (ASME OR API), 1 OR 2 =				2	Multiple Valves, (2=YES)	1.0	CONSTANT BACKPRESSURE:	PSIG	VARIABLE BACK PRESS:	PSIG
EQUIPMENT DESIGN CONDITIONS: () MAWP (X) DESIGN () OTHER				Is this a steam vlv, y/n :	N	BUILT-UP BACKPRESSURE:	38.0 PSIG	TOTAL BACKPRESSURE:	38.0 PSIG	Kb = 1.000
NORMAL OPER.	PSIG	*F	Rupture Disk, Y/N	N	FIRE SUMMARY	WETTED AREA:	FT ²	Is This a Belows Type y/n =	N	
MAX OPER.	PSIG	*F	Derating Factor =	0.9	INSULATION	N	TYPE	HC	THCKNS	IN.
DESIGN	740 PSIG	100 *F			Q = Note from fire case	MM blw/tw			Insd lectr, 1=none	1.000
CONN: RATING, FACING	300 #		PIPE SPEC:		ATTACH SKETCH FOR AREA CALCULATION: (Note: see back up material)					

EXIST. RV	MFG	Type	Size	CONTINGENCY ANALYSIS CHECKLIST				FLUID PHYSICAL PROPERTIES AT RELIEF CONDITIONS.										
				RELIEF LOAD		RELIEF (2) CONDITIONS		FLUID TYPE	VAPOR MOL WT	SP GRAVITY LIQUID	COMPR FACTOR Z	LATENT HEAT L	SP HEAT RATIO k	LIQUID VISC LCP	VAPOR VISC VCP	VAPOR AREA V IN ²	LIQUID AREA L IN ²	TOTAL AREA T IN ²
				VAPOR MI/HR	LIQUID GPM	PRESS PSIG	TEMP *F											
(REFER TO API RPS20 & RPS21 AND JACOBS SAFETY MANUAL)				Comments NA, etc	% OV PR													
1. BLOCKED OUTLETS					10.0													
2. ABNORMAL HEAT INPUT				Not Applicable	10.0													
3. EXCHANGER TUBE BREAKAGE				Not Applicable	10.0													
4. AUTO CONTROL FAILURE - surge				Controlling	10.0	8,400.0	740.0	75.0	Diesel	0.870	1.000		3.70			15.783	15.783	
5. REFLUX FAILURE				Not Applicable	10.0													
6. FIRE				Not Applicable	21.0													
7. TEMPERED WATER FAILURE				Not Applicable	10.0													
8. POWER FAILURE					10.0													
9. INSTR. AIR FAILURE				Not Applicable	10.0													
10. INADVERTENT VA. OPEN				Not Applicable	10.0													
11. MECH. EQUIP. FAILURE				Not Applicable	10.0													
12. HEAT LOSS (SERIES FRAC.)				Not Applicable	10.0													
13. THERMAL				Not Applicable	10.0													
14. LOSS OF QUENCH/COLD FEED				Not Applicable	10.0													
15. CHEMICAL REACTION				Not Applicable	10.0													
16. STEAM OUT				Not Applicable	10.0													
17. STEAM VALVE (ASME) EQUATION				Not Applicable	10.0													
18. PRD'S CAPACITY					10.0													

NOTES:	(1)		GENERAL DATA	BY/DATE	TO/	4/7/88
	(2)		PROCESS DATA	BY/DATE	TO/	4/7/88
			VALVE SIZING	BY/DATE	TO/	4/7/88
Ver. 2.8 10/27/83 com/tw						

SIZING CASE SELECTED A, IN ² :	Surge	15.783	RELIEF DEVICE ORIFICES TYPE:	R	TOTAL ORIFICE AREA REQD:	18.000 SQUARE INCHES	Olympic Pipe Line
DEVICES SELECTED:	QTY:	1	INLET	6"	OUTLET	8"	ORIFICE/AREA (1): 18.000
	QTY:		INLET		OUTLET		SET PRESS: 740 PSIG
	QTY:		INLET		OUTLET		PSIG Pressure Relief Device
							Process Selection Basis Surge
							Devic: Various Rev. 0

CONFIDENTIAL
DO NOT COPY

TAG/EQUIP. NUMBER	Various		UNIT SERVICE:	Surge protection for 3000 pipeline		PSID:	D-1902		LOCATION:	COST CENTER:									
EQUIPMENT PROTECTED	Pipeline 3000 rating					SET PRESS:	740 PSIG		BASIS:	Surge		K _h (Vap) = 1.000							
EXISTING RV AREAS:	1.0	2.0	3.0	4.0	DISCHARGE DISPOSITION:	RELIEF HEADER				K _d (Sg) = 0.740									
CALCULATION METHOD (ASME OR API), 1 OR 2 =	2		Multiple Valves, (2=YES)		1.0	CONSTANT BACKPRESSURE:	PSIG		VARIABLE BACK PRESS.:	PSIG		K _d (vap) = 0.950							
EQUIPMENT DESIGN CONDITIONS: () MAWP (X) DESIGN () OTHER			Is this a steam vlv, y/n :		N	BUILT-UP BACKPRESSURE:	61.7 PSIG		TOTAL BACKPRESSURE:	61.7 PSIG		K _b = 1.000							
NORMAL OPER.	PSIG	320	°F	Rupture Disk, Y/N	N	FIRE SUMMARY	WETTED AREA:		FT ²		Is This a Bellows Type y/n =		N						
MAX OPER.	PSIG		°F	Derating Factor =	0.9	INSULATION	N		TYPE	HC		THICKNS	IN.						
DESIGN	740	PSIG	400	°F		Q = Note from fire case		MM bruh		Certified Valve? Y/N =		n							
CONP. RATING, FACING	300 #		PIPE SPEC:	ATTACH SKETCH FOR AREA CALCULATION:				(Note: see back up material)											
Exist. RV	MFG	Type	Size	RELIEF LOAD		RELIEF (2) CONDITIONS		FLUID PHYSICAL PROPERTIES AT RELIEF CONDITIONS.											
CONTINGENCY ANALYSIS CHECKLIST				VAPOR	LIQUID	PRESS	TEMP	FLUID	VAPOR	SP	COMPR	LATENT	SP HEAT	LIQUID	VAPOR	VAPOR	LIQUID	TOTAL	
(REFER TO API RP520 & RP521 AND JACOBS SAFETY MANUAL)				M ³ /H ¹	GPM	PSIG	°F	TYPE	MOL WT	GRAVITY	FACTOR	HEAT	RATIO	VISC	VISC	AREA	AREA	AREA	
Comments NA, etc				% OV PR															
1. BLOCKED OUTLETS				10.0															
2. ABNORMAL HEAT INPUT				10.0															
3. EXCHANGER TUBE BREAKAGE				10.0															
4. AUTO CONTROL FAILURE - surge				Controlling	10.0	8,400.0	740.0	75.0	Diesel	0.870	1.000			3.70			15.989	15.989	
5. REFLUX FAILURE				Not Applicable	10.0														
6. FIRE				Not Applicable	21.0														
7. TEMPERED WATER FAILURE				Not Applicable	10.0														
8. POWER FAILURE				10.0															
9. INSTR. AIR FAILURE				Not Applicable	10.0														
10. INADVERTENT VA. OPEN				Not Applicable	10.0														
11. MECH. EQUIP. FAILURE				Not Applicable	10.0														
12. HEAT LOSS (SERIES FRAC.)				Not Applicable	10.0														
13. THERMAL				Not Applicable	10.0														
14. LOSS OF QUENCH/COLD FEED				Not Applicable	10.0														
15. CHEMICAL REACTION				Not Applicable	10.0														
16. STEAM OUT				Not Applicable	10.0														
17. STEAM VALVE (ASME) EQUATION				Not Applicable	10.0														
18. PRD'S CAPACITY				10.0															
NOTES:	(1)																		
	(2)																		
GENERAL DATA										BY/DATE	TQ/ 4/7/98		JE Jacobs Engineering Group Inc. Houston, Texas 77030-2298						
PROCESS DATA										BY/DATE	TQ/ 4/7/98								
VALVE SIZING										BY/DATE	TQ/ 4/7/98								
Ver. 2.6 10/27/93 con/hw																			
SIZING CASE SELECTED A, N ^o 2:	Surge		15.989	RELIEF DEVICE ORIFICES TYPE:	R		TOTAL ORIFICE AREA REQD:	16,000 SQUARE INCHES				Olympic Pipe Line							
DEVICES SELECTED:	QTY:	1	INLET	6"	OUTLET	8"	ORIFICE/AREA (1):	16,000	SET PRESS:	740	PSIG	Pressure Relief Device							
	QTY:		INLET		OUTLET		ORIFICE/AREA (1):		SET PRESS:		PSIG	Process Selection Basis Surge							
	QTY:		INLET		OUTLET		ORIFICE/AREA (1):		SET PRESS:		PSIG	Device:	Various		Rev. 0				

0001035

~~CONFIDENTIAL~~
DO NOT COPY