



**Stoner Associates**  
Suite 900  
5177 Richmond Ave.  
Houston, TX 77056-6736  
Tel. 713 626 1600  
Fax. 713 622 7832

**TRANSIENT REPORT FOR**  
**OLYMPIC PIPE LINE COMPANY**  
**SURGE ANALYSIS OF THE OLYMPIC PIPE LINE**  
**ARCO PUMP STATION to**  
**RENTON TERMINAL and**  
**SEATTLE DELIVERIES**  
**16 INCH LINE ONLY**

**STONER PROJECT NO. MAR9916**

**STONER ASSOCIATES, INC.**  
**HOUSTON, TEXAS**

**DATE:** September 21, 1999

**PREPARED BY:** Gerald T. Moreland, P.E., Chief Engineer  
Jim McIvor, Senior Pipeline Engineer

**SA 002969**

## TABLE OF CONTENTS

- 1.0 INTRODUCTION
- 2.0 RESULTS of SIMULATIONS
  - 2.1 Inlet Valve Closures – Four Cases
  - 2.2 Event of June 10, 1999 – Five Cases
- 3.0 ANALYSIS SUMMARY
- 4.0 MODELING PARAMETERS AND ASSUMPTIONS
  - 4.1 Pipeline Data and Properties
  - 4.2 Fluid Properties and Characteristics
  - 4.3 Pump Performance Data
  - 4.4 Control Valves
  - 4.5 Block Valves and Relief Valves

## APPENDIX A – MODEL INPUT LISTING

### FIGURES 1 to 10 – Schematic Diagrams

- Appendix 1: CASE 1 - Closure of Inlet Valve – Bayview Terminal, Q=9117 bbl/hr
- Appendix 2: CASE 2 - Closure of Inlet Valve – Bayview Terminal, Q=9228 bbl/hr
- Appendix 3: CASE 3 - Closure of Inlet Valve – Ferndale Pump Sta., Q=9117 bbl/hr
- Appendix 4: CASE 4 - Closure of Inlet Valve – Allen Pump Station, Q=9117 bbl/hr
- Appendix 5: CASE 5 – Event of June 10, 1999, Original Sequence,  
Mal-Function of RV1919
- Appendix 6: CASE 6 - Event of June 10, 1999, Original Sequence,  
Proper Function of RV1919
- Appendix 7: CASE 7 - Event of June 10, 1999, Trip of ARCO first,  
Mal-Function of RV1919
- Appendix 8: CASE 8 - Event of June 10, 1999, Original Sequence,  
NEW RV2229 @ 1000 psig, Flow Switch Trips  
Ferndale with 45 seconds delay, Mal-Function  
of RV1919, New Set Points - CV1904 @  
500 psig, RV1919 @ 580psig, No Mechanical  
Stop on CV1904
- Appendix 9: CASE 9 - Event of June 10, 1999, Original Sequence,  
Proper Function of RV1919, NO Flow Switch  
to Ferndale, Mal-Function of RV2229, New Set  
Points - CV1904 @ 500 psig, RV1919 @  
580 psig, No Mechanical Stop on CV1904

SA 002970

**1.0 INTRODUCTION**

This final report is issued to summarize and outline the hydraulic transient study on the Olympic Pipe Line from ARCO to Renton/Seattle Terminals, herein referred to as the Olympic System in this document. The scope of work was authorized by Subcontract Agreement with MARMAC Engineering on behalf of Olympic Pipe Line Company.

**2.0 RESULTS of SIMULATIONS**

The results of the transient simulations are presented in two parts. The first part is a set of simulations for closure of inlet valves in 4.0 seconds at four critical points. The second part is a set of simulations for the events of June 10, 1999, which resulted in a release at Milepost 15.9 on Olympic's 16-inch pipeline.

The maximum pressures at the following four locations on the 16-inch mainline based on these simulations were:

**REFERENCE LOCATION**

<b>CASE Number</b>	<b>DISCHARGE FERNDALE V.327</b>	<b>RELEASE POINT MP 15.9</b>	<b>ALLEN JUNCTION MP 37.4</b>	<b>INLET BAYVIEW MV.1902</b>
<b>MAOP</b>	<b>1370 psig</b>	<b>1456 psig</b>	<b>1419 psig</b>	<b>1440 psig</b>
<b>MASP</b>	<b>1507 psig</b>	<b>1602 psig</b>	<b>1560 psig</b>	<b>1584 psig</b>
<b>1</b>	<b>1400 psig</b>	<b>1424 psig</b>	<b>1532 psig</b>	<b>1520 psig</b>
<b>2</b>	<b>1400 psig</b>	<b>1424 psig</b>	<b>1532 psig</b>	<b>1520 psig</b>
<b>3</b>	<b>1051 psig</b>	<b>608 psig</b>	<b>437 psig</b>	<b>434 psig</b>
<b>4</b>	<b>1262 psig</b>	<b>1040 psig</b>	<b>847 psig</b>	<b>810 psig</b>
<b>5</b>	<b>1402 psig</b>	<b>1422 psig</b>	<b>1521 psig</b>	<b>1515 psig</b>
<b>6</b>	<b>1283 psig</b>	<b>1108 psig</b>	<b>989 psig</b>	<b>962 psig</b>
<b>7</b>	<b>1081 psig</b>	<b>752 psig</b>	<b>456 psig</b>	<b>411 psig</b>
<b>8</b>	<b>1296 psig</b>	<b>1154 psig</b>	<b>1034 psig</b>	<b>1006 psig</b>
<b>9</b>	<b>1399 psig</b>	<b>1382 psig</b>	<b>1475 psig</b>	<b>1466 psig</b>

**MAOP = Maximum Allowable Operating Pressure**

**MASP = Maximum Allowable Surge Pressure (MAOP \* 1.1)**

**SA 002971**

## 2.1 INLET VALVE CLOSURE CASES

The four cases described below were simulated for the maximum flow rate for gasoline:

**CASE 1 - Closure of Inlet Valve – Bayview Terminal, Q=9117 bbl/hr**

**CASE 2 - Closure of Inlet Valve – Bayview Terminal, Q=9228 bbl/hr**

**CASE 3 - Closure of Inlet Valve – Ferndale Pump Sta., Q=9117 bbl/hr**

**CASE 4 - Closure of Inlet Valve – Allen Pump Station, Q=9117 bbl/hr**

## 2.2 EVENT of JUNE 10, 1999

The five cases described below were simulated for the flow rate on June 10, 1999 and the pressure conditions at 15:03:00 hours from Arco to Renton-Seattle Terminals.

**CASE 5 – Event of June 10, 1999, Original Sequence,  
Mal-Function of RV1919**

**CASE 6 - Event of June 10, 1999, Original Sequence,  
Proper Function of RV1919**

**CASE 7 - Event of June 10, 1999, Trip of ARCO first,  
Mal-Function of RV1919**

**CASE 8 - Event of June 10, 1999, Original Sequence,  
NEW RV2229 @ 1000 psig, Flow Switch  
Trips Ferndale with 45 seconds delay,  
Mal-Function of RV1919, New Set Points  
CV1904 @ 500 psig, RV1919 @ 580psig,  
No Mechanical Stop on CV1904**

**CASE 9 - Event of June 10, 1999, Original Sequence,  
Proper Function of RV1919,  
NO Flow Switch to Ferndale,  
Mal-Function of RV2229, New Set Points  
CV1904 @ 500 psig, RV1919 @ 580psig,  
No Mechanical Stop on CV1904**

SA 002972



### 3.0 ANALYSIS SUMMARY

The system was simulated using the Stoner Pipeline Simulator (SPS) computer package. The numerical models emulated the piping, pumps, valves and the physical pipe profile. Using the input requirements for SPS, information from drawings and piping data provided by MARMAC Engineering and Olympic Pipe Line Company, several hydraulic models were developed for the Olympic System.

The naming convention of the model for the Olympic Pipe Line 16-inch system is primarily based on the station numbers and the pump station designation number. The 16" main line devices were named based on milepost (location). All block and control valves were named based on the flow diagrams and P&IDs provided ("device name"). The data sets reflect the device names used in the drawings and field tags. The variable naming convention is as follows:

<u>NAME CONVENTION</u>	<u>MEANING</u>
"device name":P-	Upstream Pressure - psig
"device name":P+	Downstream Pressure - psig
"device name":Q-	Upstream Flow – bbl/hr
"device name":Q+	Downstream Flow – bbl/hr
"device name":RPM	Rotational Speed – rpm
"device name":FR	Fraction Open
'device name':CF	Accumulative Volume – mbbl

**Example:**

MV.1902:P-                      Block Valve MV1902 at Bayview  
Inlet, Upstream Pressure in psig

The schematic diagrams for the model with device names and selected data are provided in the section labeled "FIGURES".

The SPS computer simulations assume primed systems (systems which are completely filled with liquid). Additional details on modeling parameters and assumptions are outlined in Section 4 and Appendix A.

Each section of the appendix corresponds to a particular case and consists of a table and reference to several plots in the corresponding appendix. The plots in the appendix include maximum pressure envelope for the modeled pipelines, pressure-time curves for selected pipeline locations, and flow-time curves for selected locations. Time plots show time on the x-axis versus one or more parameter(s), such as pressure or flow rate, on the y-axis. These plots illustrate the change with respect to time for the selected parameter(s).

SA 002973

**MATRIX OF CASE STUDIES FOR OLYMPIC PIPE LINE  
 MAR9916**

CASE DESCRIPTION	CASE 1	CASE 2	CASE 3	CASE 4	CASE 5	CASE 6	CASE 7	CASE 8	CASE 9	NOTES
Closure of Inlet valve at Bayview in 4 seconds; Flow Rate = 9117 bbl/hr										All Models / Cases on this page include the following: PUMPS: ARCO Pumps Cherry Point Pumps Ferndale Booster Pumps Ferndale Pumps Bayview Pumps Allen Pumps Woodinville Pumps PIPELINE: Pipe - Allen to Woodin. Pipe - Cherry Pt to Fern. Pipe - Fern. To Bayview Pipe - Bayview to Allen Pipe - Allen to Woodin. Pipe - Woodin. To Renton Pipe - Renton to Seattle Pipe - Renton to Tosco VALVES: Switching Valves - Renton ESD Valves Suction/Discharge Control Mainline Block Valves RELIEF VALVES: Bayview - 8" Brooks RV1919, RV1932, New RV2229 Renton - 12" Brodie
Closure of Inlet valve at Bayview in 4 seconds; Flow Rate = 9228 bbl/hr	CASE 1	CASE 2	CASE 3	CASE 4						
Closure of Inlet valve at Ferndale in 4 seconds; Flow rate = 9117 bbl/hr										
Closure of Inlet valve at Allen in 4 seconds; Flow rate = 9117 bbl/hr										
June 10, 1989 - Original Sequence Commanded Trip ALLEN P2; Mal-Function of RV1919; CV1904 @ 600 psig; MV9102 triggered @ 730 psig; Flow rate = 8748 bbl/hr					JUNE 10, 1989 CASE - Actual Flow Rate CASE 5 CASE - EVENT with failed RV					
June 10, 1989 - Original Sequence Commanded Trip ALLEN P2; Functional RV1919; CV1904 @ 600 psig; MV9102 triggered @ 730 psig; Flow rate = 8748 bbl/hr						CASE 6 CASE - NORMAL with working RV				
June 10, 1989 - Trip ARCO Pumps First Allen on High Discharge Trip Control (1600 psig); Mal-Function of RV1919; CV1904 @ 600 psig; MV9102 triggered @ 730 psig; Flow rate = 8748 bbl/hr							CASE 7 ARCO Trip Instead of ALLEN			
June 10, 1989 - Original Sequence New RV2229 upstream MV1902 @ 1000 psig; Mal-Function of RV1919; CV1904 @ 500 psig; MV9102 triggered @ 700 psig; Flow rate = 8748 bbl/hr Mechanical Stop on CV1904 removed								CASE 8 NEW RV2229 RV1919 fails		
June 10, 1989 - Original Sequence New RV2229 upstream MV1902 @ 1000 psig Mal-functions; Functional; RV1919 @ 580 psig & CV1904 @ 500 psig (maximum pressure) MV9102 triggered @ 700 psig; Flow rate = 8748 bbl/hr Mechanical Stop on CV1904 removed									CASE 9 FAIL NEW RV RV1919 working RV2229 fails	

The following is a summary of the starting conditions at the start of the transient for Cases 1 to 4:

<u>LOCATION</u>	<u>MODEL DATA</u> Case 1, 3, and 4	<u>MODEL DATA</u> Case 2
Cherry Point Discharge	267 psig	264 psig
Ferndale Flow Rate	9117 bbl/hr	9228 bbl/hr
Ferndale Suction	106 psig	103 psig
Ferndale Discharge	1051 psig	1039 psig
Bayview Suction	45 psig	10 psig
Bayview Discharge	111 psig	To Tanks
Allen Suction	60 psig	-----
Allen Discharge	1152 psig	-----

The following is a summary of the starting conditions at the start of the transient for Cases 5 to 9 (Event of June 10, 1999):

<u>LOCATION</u>	<u>OLYMPIC DATA</u> June 10, 1999 at 15:03	<u>MODEL DATA</u>	<u>Error</u>
Cherry Point Suction	19.0 psig	20.9 psig	+10.0%
Cherry Point Discharge	211.0 psig	212.8 psig	+0.8%
Ferndale Flow Rate	8748 bbl/hr	8748 bbl/hr	+0.0%
Ferndale Suction	65.0 psig	65.2 psig	+0.3%
Ferndale Discharge	993.0 psig	994.2 psig	+0.1%
Bayview Suction	72.0 psig	70.0 psig	-1.4%
Bayview Discharge	217.0 psig	219.0 psig	+0.9%
Allen Suction	173.0 psig	173.0 psig	+0.0%
Allen Discharge	1437.0 psig	1437.3 psig	+0.0%
Woodinville Suction	419.0 psig	419.2 psig	+0.0%
Woodinville Discharge	552.0 psig	553.5 psig	+0.3%
Renton Inlet	248.0 psig	249.0 psig	+0.4%
Tosco Terminal	35.0 psig	35.0 psig	+0.0%
Seattle Terminal	40.0 psig	40.0 psig	+0.0%

**SA 002975**

3.2.1 CASE 1 - Closure of Inlet Valve – Bayview Terminal in 4.0 seconds  
Flow Rate = 9117 bbl/hr

Summary of Results

**MAXIMUM PRESSURES -**

<u>Location</u>	<u>Maximum Pressure</u>
Ferndale Discharge	1400 psig
Release Point (MP 15.9)	1424 psig
Allen Junction (MP 37.4)	1532 psig
Inlet – Bayview	1520 psig

**RELIEF OPERATION –**

<u>Device</u>	<u>Operation</u>
RV1919	Closed
RV1932	Closed

**PUMP OPERATION -**

<u>Device</u>	<u>Operation</u>
ARCO Pumps	No Trip
Cherry Point	No Trip
Ferndale	No Trip
Bayview	Trip - Low Suction
Allen	Trip - Low Suction

Detailed Results

Appendix 1 contains plots of selected parameters versus time and distance

SA 002976

3.3.2 CASE 2 - Closure of Inlet Valve - Bayview Terminal in 4.0 seconds  
Flow Rate = 9228 bbl/hr

Summary of Results

**MAXIMUM PRESSURES -**

<u>Location</u>	<u>Maximum Pressure</u>
Ferndale Discharge	1400 psig
Release Point (MP 15.9)	1424 psig
Allen Junction (MP 37.4)	1532 psig
Inlet - Bayview	1520 psig

**RELIEF OPERATION -**

<u>Device</u>	<u>Operation</u>
RV1919	Closed
RV1932	Closed

**PUMP OPERATION -**

<u>Device</u>	<u>Operation</u>
ARCO Pumps	No Trip
Cherry Point	No Trip
Ferndale	No Trip
Bayview	Trip - Low Suction
Allen	Trip - Low Suction

Detailed Results

Appendix 2 contains plots of selected parameters versus time and distance

SA 002977

3.2.3 CASE 3 - Closure of Inlet Valve - Ferndale Pump Station in 4.0 seconds  
Flow Rate = 9117 bbl/hr

**Summary of Results**

**MAXIMUM PRESSURES -**

<u>Location</u>	<u>Maximum Pressure</u>
Ferndale Discharge	1051 psig
Release Point (MP 15.9)	608 psig
Allen Junction (MP 37.4)	437 psig
Inlet - Bayview	434 psig

**RELIEF OPERATION -**

<u>Device</u>	<u>Operation</u>
RV1919	Closed
RV1932	Closed

**PUMP OPERATION -**

<u>Device</u>	<u>Operation</u>
ARCO Pumps	No Trip
Cherry Point	No Trip
Ferndale	Trip - Low Suction
Bayview	CV.1963 closed

**Detailed Results**

Appendix 3 contains plots of selected parameters versus time and distance

3.2.4 CASE 4 - Closure of Inlet Valve - Allen Pump Station in 4.0 seconds  
Flow Rate = 9117 bbl/hr

Summary of Results

**MAXIMUM PRESSURES -**

<u>Location</u>	<u>Maximum Pressure</u>
Ferndale Discharge	1262 psig
Release Point (MP 15.9)	1040 psig
Allen Junction (MP 37.4)	847 psig
Inlet - Bayview	810 psig
Inlet - Allen	620 psig

**RELIEF OPERATION -**

<u>Device</u>	<u>Operation</u>
RV1919	Opened
RV1932	Closed

**PUMP OPERATION -**

<u>Device</u>	<u>Operation</u>
ARCO Pumps	No Trip
Cherry Point	No Trip
Ferndale	No Trip
Bayview	Trip - High Discharge CV.1963 closed
Allen	Trip - Low Suction

Detailed Results

Appendix 4 contains plots of selected parameters versus time and distance

**3.2.5 CASE 5 – Event of June 10, 1999, Original Sequence,  
Mal-Function of RV1919**

CASE 5 was the simulation of the event on June 10, 1999 for the Olympic Pipe Line System from the 16-inch segment at ARCO / Cherry Point to the suction of Woodinville Station.

This case outlines the results for the simulation of the surge event of June 10, 1999 based on data and timeline of actions provided to Stoner by Olympic Pipe Line. The event of June 10, 1999 has simulation by the switching of flow at Renton from delivery to Tosco to Seattle. The simulation used the time sequence of valve operations and set point ramps provided by Olympic Pipe Line. The temporary flow reduction/stoppage at Renton caused the flow to “back-up” in the 16-inch line between Allen Pump Station and Renton. With this flow “back-up” and the increase in pressure at Allen, pump #2 at Allen Pump Station was commanded to shutdown at 15:23:35. The Bayview pump (P.301) had shutdown 35 seconds earlier (15:23:00) for unknown reasons. The simulation modeled all these events.

After the trip of Allen and Bayview pumps, CV1904 reacted to the pressure increase and started closing to hold the set point of 600 psig. CV1904 could not close completely due to mechanical stop on the operator at about 10% rotation (Valve Cv of 135).

RV1919 was set to open at 650 psig; however, it did not response as programmed. RV1919 failed to open fast enough or failed to open wide enough. Some mechanism or other malfunction prevented RV1919 from operating properly. It is not the purpose of this report to investigate the mechanical reasons for the malfunction. This case was to investigate the hydraulic response of the Olympic Pipe Line after the malfunction of RV1919. Regardless of how or why RV1919 malfunctioned, the pressure continued to rise between CV1904 and RV1919 after CV1904 was closed against its mechanical stop.

When the pressure between CV1904 and RV1919 exceeded 730 psig, MV1902 was commanded to close (set for 730 psig closure) in 62 seconds. After closure of MV1902, the pressure at the inlet (upstream of MV1902) to Bayview rose to a predicted 1515 psig (based on the simulation) due to effect of surge and line pack. This is 1.0% of the recorded pressure rise ( 1515/1500). The 1500 psig maximum pressure was the maximum pressure reported from a 1-second scan of the Olympic PLC records of the event.



**Summary of Results**

**MAXIMUM PRESSURES -**

<u>Location</u>	<u>Maximum Pressure</u>
Ferndale Discharge	1402 psig
Release Point (MP 15.9)	1422 psig
Allen Junction (MP 37.4)	1521 psig
Inlet – Bayview	1515 psig
Allen Discharge	1450 psig

**RELIEF OPERATION –**

<u>Device</u>	<u>Operation</u>
RV1919	Mal-Function
RV1932	Closed
RV682	Closed

**PUMP OPERATION -**

<u>Device</u>	<u>Operation</u>
ARCO Pumps	No Trip
Cherry Point	No Trip
Ferndale	No Trip
Bayview	P.201 tripped – Unknown cause at 15:23:00
Allen	Unit 2 – manual trip at 15:23:35
Woodinville	No Trip

**Detailed Results**

Appendix 5 contains plots of selected parameters versus time and distance.

**3.2.6 CASE 6 – Event of June 10, 1999, Original Sequence,  
 Proper Function of RV1919**

CASE 6 was the simulation of the event on June 10, 1999 with a properly functioning RV1919 for the Olympic Pipe Line System from the 16-inch segment at ARCO / Cherry Point to the suction of Woodinville Station. This case outlines the results for the simulation of the surge event of June 10, 1999 based on data and timeline of actions provided to Stoner by Olympic Pipe Line. All sequences of events were the same as CASE 5.

After the trip of Allen and Bayview pumps, CV1904 reacted to the pressure increase and started closing to hold the set point of 600 psig. CV1904 could not close completely due to mechanical stop on the operator at about 10% rotation (Valve Cv of 135). RV1919 was set to open at 650 psig and responded as programmed. The pressure between CV1904 and RV1919 did exceed 730 psig; therefore, MV1902 did not close (set for 730 psig closure).

**Summary of Results**

**MAXIMUM PRESSURES -**

<u>Location</u>	<u>Maximum Pressure</u>
Ferndale Discharge	1283 psig
Release Point (MP 15.9)	1108 psig
Allen Junction (MP 37.4)	989 psig
Inlet – Bayview	962 psig
Allen Discharge	1450 psig

**RELIEF OPERATION –**

<u>Device</u>	<u>Operation</u>
RV1919	Opened – Maximum Flow 5700 bbl/hr
RV1932	Closed
RV682	Closed

**PUMP OPERATION -**

<u>Device</u>	<u>Operation</u>
ARCO Pumps	No Trip
Cherry Point	No Trip
Ferndale	No Trip
Bayview	P.201 tripped – Unknown cause at 15:23:00
Allen	Unit 2 – manual trip at 15:23:35
Woodinville	No Trip

**Detailed Results**

Appendix 6 contains plots of selected parameters versus time and distance.

3.2.7 CASE 7 - Event of June 10, 1999, Trip of ARCO first,  
Mal-Function of RV1919

CASE 7 was the simulation of the event on June 10, 1999 with the trip of ARCO pumps instead of Allen Unit #2 for the Olympic Pipe Line System from the 16-inch segment at ARCO / Cherry Point to the suction of Woodinville Station.

This case outlines the results for the simulation of the surge event of June 10, 1999 based on data and timeline of actions provided to Stoner by Olympic Pipe Line. The only change was the call for shutdown Allen Unit #2. The different sequence was to call for shutdown of ARCO pump instead. The event of June 10, 1999 has simulation by the switching of flow at Renton from delivery to Tosco to Seattle. The simulation used the time sequence of valve operations and set point ramps provided by Olympic Pipe Line. The temporary flow reduction/stoppage at Renton caused the flow to "back-up" in the 16-inch line between Allen Pump Station and Renton. With this flow "back-up" and the increase in pressure at Allen, the pumps (both) at ARCO Pump Station were commanded to shutdown at 15:23:35. The Bayview pump (P.301) had shutdown 35 seconds earlier (15:23:00) for unknown reasons. The simulation modeled all these events.

After the trip of ARCO, the inflow was stopped. CV1904 had no high pressure to react on and remained open. RV1919 did not need to open and was not a factor in the transient. Because the pressure at Bayview did not exceed 730 psig, MV1902 was not triggered and remained open.

**Summary of Results**

**MAXIMUM PRESSURES -**

<u>Location</u>	<u>Maximum Pressure</u>
Ferndale Discharge	1081 psig
Release Point (MP 15.9)	752 psig
Allen Junction (MP 37.4)	456 psig
Inlet - Bayview	411 psig
Allen Discharge	1450 psig

**RELIEF OPERATION -**

<u>Device</u>	<u>Operation</u>
RV1919	Mal-Function - Not a factor
RV1932	Closed
RV682	Closed

**PUMP OPERATION -**

<u>Device</u>	<u>Operation</u>
ARCO Pumps	Both Units – manual trip at 15:23:35
Cherry Point	No Trip
Ferndale	No Trip
Bayview	P.201 tripped – Unknown cause at 15:23:00
Allen	No Trip
Woodinville	No Trip

**Detailed Results**

Appendix 7 contains plots of selected parameters versus time and distance.

**3.2.8 CASE 8 – Event of June 10, 1999, Original Sequence,  
NEW RV2229 @ 1000 psig, Flow Switch  
Trips Ferndale with 45 seconds delay,  
Mal-Function of RV1919, New Set Points  
CV1904 @ 500 psig, RV1919 @ 580psig,  
No Mechanical Stop on CV1904**

CASE 8 was the simulation of the event on June 10, 1999 with a new relief valve upstream of MV1902 for the Olympic Pipe Line System from the 16-inch segment at ARCO / Cherry Point to the suction of Woodinville Station. This case outlines the results for the simulation of the surge event of June 10, 1999 based on data and timeline of actions provided to Stoner by Olympic Pipe Line. All sequences of events were the same as CASE 5. The new relief valve (RV2229) upstream of MV1902 was the same as RV1919 and was set to open at 1000 psig. A flow switch was modeled downstream of RV2229 to trigger the shutdown of all Ferndale pumps after a 45 seconds time delay.

After the trip of Allen and Bayview pumps, CV1904 reacted to the pressure increase and started closing to hold the set point of 500 psig. CV1904 closed completely trying to hold a downstream pressure of 500 psig. The mechanical stop on CV1904 was removed for this case.

RV1919 was set to open at 580 psig; however, it did not response as programmed. RV1919 failed to open fast enough or failed to open wide enough. Regardless of how or why RV1919 malfunctioned, the pressure rose above 500 psig and CV1904 completely closed.

MV1902 was not triggered and commanded to close (set for 700 psig closure) because the Bayview inlet pressure did not exceed 700 psig. After closure of Cv1904, the pressure at the inlet (upstream of MV1902) to Bayview rose to over 1000 psig and triggered the opening of the new relief valve (RV2229).

**Summary of Results**

**MAXIMUM PRESSURES -**

<u>Location</u>	<u>Maximum Pressure</u>
Ferndale Discharge	1296 psig
Release Point (MP 15.9)	1154 psig
Allen Junction (MP 37.4)	1034 psig
Inlet – Bayview	1006 psig
Allen Discharge	1450 psig

**RELIEF OPERATION –**

<u>Device</u>	<u>Operation</u>
RV2229 (new)	Opened – Maximum flow was 5100 bbl/hr
RV1919	Mal-Function
RV1932	Closed
RV682	Closed

**PUMP OPERATION -**

<u>Device</u>	<u>Operation</u>
ARCO Pumps	No Trip
Cherry Point	No Trip
Ferndale	Trip by signal for Flow Switch on RV2229
Bayview	P.201 tripped – Unknown cause at 15:23:00
Allen	Unit 2 – manual trip at 15:23:35
Woodinville	No Trip

**Detailed Results**

Appendix 8 contains plots of selected parameters versus time and distance.

- 3.2.9 CASE 9 – Event of June 10, 1999, Original Sequence,  
Proper Function of RV1919,  
NO Flow Switch to Ferndale,  
Mal-Function of RV2229, New Set Points  
CV1904 @ 500 psig, RV1919 @ 580psig,  
No Mechanical Stop on CV1904**

CASE 9 was the simulation of the event on June 10, 1999 with a mal-function of the new relief valve upstream of MV1902 for the Olympic Pipe Line System from the 16-inch segment at ARCO / Cherry Point to the suction of Woodinville Station. This case outlines the results for the simulation of the surge event of June 10, 1999 based on data and timeline of actions provided to Stoner by Olympic Pipe Line. All sequences of events were the same as CASE 5. The new relief valve (RV2229) upstream of MV1902 was the same as RV1919

and was set to open at 1000 psig. No flow switch was modeled downstream of RV1919 to trigger the shutdown of all Ferndale pumps. RV2229 failed to operate and did not open as programmed.

After the trip of Allen and Bayview pumps, CV1904 reacted to the pressure increase and started closing to hold the set point of 500 psig. CV1904 closed completely trying to hold a downstream pressure of 500 psig. The mechanical stop on CV1904 was removed for this case. RV1919 was set to open at 580 psig and responded as programmed.

MV1902 was not triggered and commanded to close (set for 700 psig closure) because the Bayview inlet pressure did not exceed 700 psig.

### Summary of Results

#### MAXIMUM PRESSURES -

<u>Location</u>	<u>Maximum Pressure</u>
Ferndale Discharge	1399 psig
Release Point (MP 15.9)	1382 psig
Allen Junction (MP 37.4)	1475 psig
Inlet – Bayview	1466 psig
Allen Discharge	1450 psig

#### RELIEF OPERATION –

<u>Device</u>	<u>Operation</u>
RV2229 (new)	Mal-Function
RV1919	Opened – Maximum flow was 1600 bbl/hr
RV1932	Closed
RV682	Closed

#### PUMP OPERATION -

<u>Device</u>	<u>Operation</u>
ARCO Pumps	No Trip
Cherry Point	No Trip
Ferndale	No Trip
Bayview	P.201 tripped – Unknown cause at 15:23:00
Allen	Unit 2 – manual trip at 15:23:35
Woodinville	No Trip

### Detailed Results

Appendix 9 contains plots of selected parameters versus time and distance.

**4.0 MODELING PARAMETERS AND ASSUMPTIONS**

**4.1 MODELING ASSUMPTIONS for PIPES**

The following assumptions were used in the simulations for the above cases. The Stoner Pipeline Simulator (SPS) was used for all simulations.

**Pipe Conditions (Mainline) -**

- Nominal Size = 16 inch
- Outside Diameter = 16.0 inch
- Wall Thickness = 0.312 inch (nominal thickness)
- Internal Diameter = 15.376 inch
- Roughness = 0.0003 inch
- MAOP = Maximum Allowable Operating Pressure
- MASP = Maximum Allowable Surge Pressure (1.1 \* MAOP)

Elevation Profiles = As provided by and modified by Olympic Pipe Line

<b>LOCATION POINT</b>	<b>MAOP Psig</b>	<b>MASP Psig</b>
Cheery Point Discharge	716.0	788.0
Ferndale Discharge		
Actual	1394.0	1533.0
Procedural	1370.0	1507.0
Release Point (MP 15.9)	1456.0	1602.0
Allen Junction Tie-in		
MP37.4	1419.0	1560.0
Bayview Inlet	1440.0	1584.0
Bayview Discharge	740.0	814.0
Allen Discharge	1440.0	1584.0
Woodinville Discharge	1298.0	1427.0
Renton Inlet	1440.0	1584.0

**APPENDIX A contains a complete, detail listing of all model input data.**

**4.2 FLUID PROPERTIES AND CHARACTERISTICS**

**Fluid Properties –**

- Weight Density = 47.07 lbs/cf. @ 60 °F
- Dynamic Viscosity = 0.55 centipoise @ 60 °F

Dynamic Viscosity = 0.50326 centipoise @ 70 °F  
Bulk Modulus = 150000 psi @ 60 °F  
Nominal Flowing Temperature = 70 °F  
Vapor Pressure = 8.7 psia @ 70 °F

#### 4.3 PUMP PERFORMANCE DATA

##### 4.3.1 Equipment –

Pumps = Curves As provided by Olympic Pipe Line  
All pump performance curves were  
at 100% manufacturer's stated performance.

##### 4.3.2 Controls –

ARCO Pumps were used in the model in this case.

Cherry Point Pump Shutdown - Pump Suction Pressure less than or equal 5 psig  
Pump Discharge Pressure greater than 575 psig  
Pump High Case shutdown greater than 600 psig

Ferndale Pump Shutdown - Suction Pressure less than 20 psig  
Discharge Pressure greater than or equal 1400 psig  
Pump High Case shutdown greater than 1500 psig

Bayview Pump Shutdown - Low Flow less than or equal 37.15 gpm  
Pump Suction Pressure less than or equal 2 psig  
Pump High Case shutdown greater than 700 psig  
CV1963 Pressure greater than 600 psig

Allen Pump Station: Suction Pressure less than 20 psig  
Discharge Pressure greater than or equal 1550 psig  
Pump High Case shutdown greater than 1600 psig

Woodinville Pump Sta. Suction Pressure less than 20 psig  
Discharge Pressure greater than or equal 1400psig  
Pump High Case shutdown greater than 1500 psig

#### 4.4 CONTROL VALVES

Control Valves (CV) = As provided by Olympic Pipe Line

APPENDIX A contains additional information.



**4.5 BLOCK VALVES and RELIEF VALVES**

Motor Valves (MV) = As provided by Olympic Pipe Line

Relief Valves (RV) = As provided by Olympic Pipe Line

APPENDIX A contains additional information.

	ARCO		TOSCO		CHERRY POINT		FERRIDALE		BAYVIEW		ALLEN		WOODRVILLE		RENTON		SEATTLE		
	PUMP STATION	SERIES	PUMP STATION	SERIES	PUMP STATION	SERIES	PUMP STATION	SERIES	PUMP STATION	SERIES	PUMP STATION	SERIES	PUMP STATION	SERIES	PUMP STATION	SERIES	PUMP STATION	SERIES	
PUMP CONFIGURATION																			
PUMP #1	ARCO P1	ARCO P1	P.300A	P.301	CP PUMP	P.301	P.301	P.201	ALLEN P1	WOODINVILLE P1	NONE	NONE							
SUCTION BLOCK	ARCO P1.SB	V.301	V.1412	C.373	V.1414	V.323	MV.1981	MV.1983	V.521	V.1510	V.521	V.1510							
DISCHARGE BLOCK	ARCO P1.DB	V.307	V.1414	V.323	V.1414	V.323	MV.1983	MV.1983	V.520	V.1511	V.520	V.1511							
BYPASS CHECK	ARCO P1.CK	NONE	CP PUMP.BC	CV.300	CP PUMP.BC	CV.300	CK.1982	CK.1982	CK.506	CK.1501	CK.506	CK.1501							
PUMP #2	ARCO P2	NONE	NONE	P.302	NONE	P.302	P.202	P.202	ALLEN P2	WOODINVILLE P2	ALLEN P2	WOODINVILLE P2							
SUCTION BLOCK	ARCO P2.SB			V.324		V.324	MV.1986	MV.1986	V.519	V.1516	V.519	V.1516							
DISCHARGE BLOCK	ARCO P2.DB			V.325		V.325	MV.1990	MV.1990	V.518	V.517	V.518	V.517							
BYPASS CHECK	ARCO P2.CK			CV.301		CV.301	MV.1985	MV.1985	CK.506	CK.1500	CK.506	CK.1500							
PUMP #3	NONE	NONE	NONE	P.303	NONE	P.303	NONE	NONE	ALLEN P3	NONE	ALLEN P3	NONE							
SUCTION BLOCK				V.360		V.360			V.566		V.566								
DISCHARGE BLOCK				V.361		V.361			V.565		V.565								
BYPASS CHECK				CV.302		CV.302			CK.508		CK.508								
STATION BYPASS	NONE	NONE	NONE	NONE	NONE	NONE	NONE	NONE	CK.515	CK.1503	CK.515	CK.1503							
PUMP STATION CONTROL	UNKNOWN	UNKNOWN	OFF	ON	ON	ON	ON	ON	ON	ON	ON	ON							
LOW SUCTION TRIP			5	5	2	2	2	2	20	20	20	20							
HIGH DISCHARGE TRIP			575	1400	NONE	1400	NONE	NONE	1550	1400	1550	1400							
HIGH CASE TRIP			800 (EVENT)	1500 (EVENT)	700	1500 (EVENT)	700	700	1600	1500	1600	1500							
LOW FLOW SWITCH - gpm			NONE	NONE	26	NONE	26	26	NONE	NONE	NONE	NONE							
INLET BLOCK VALVE	UNKNOWN	UNKNOWN	CLOSED	V.373	NOT MODELED	V.373	MV.1902	MV.1902	MV.503	MV.1501	MV.503	MV.1501							
SET POINT							700	700											
STATION CONTROL VALVE	ARCO.FCV	ARCO.FCV	NONE	V.1408	V.1408	V.327	CV.1963	CV.1963	CV.517	CV.1508	CV.517	CV.1508							
SUCTION CONTROL	FLOW	CLOSED	CLOSED	20	20	60	45	45	60	60	60	60							
DISCHARGE CONTROL	8748 BBL/HR	CLOSED	CLOSED	450	450	1320	230 (EVENT)	230 (EVENT)	1440	1320	1440	1320							
							CV.1904	CV.1904											
							600 (EVENT)	600 (EVENT)											
DISCHARGE CHECK VALVE	ARCO.CK	ARCO.CK	CV.352	CP.CHK	CP.CHK	CV.303	NONE	NONE	CK.516	CK.1502	CK.516	CK.1502							
DISCHARGE BLOCK VALVE	ARCO.BD	ARCO.BD		V.1409	V.1409	V.330	NOT MODELED	NOT MODELED	MV.509	MV.1504	MV.509	MV.1504							
RELIEF VALVE	NONE	NONE	NONE	NONE	NONE	NONE	RV.1919	RV.1919	NONE	NONE	NONE	NONE							
SET POINT							650 (EVENT)	650 (EVENT)											
							RV.1932	RV.1932											
							650	650											
							RV.2229	RV.2229											
							(PROPOSED)	(PROPOSED)											

**APPENDIX A**  
**MODEL INPUT LISTING**

**Properties of Gasoline**

- density @ 60°F = 47.07 pounds per cubic foot
- bulk modulus = 150,000 psi
- viscosity @ 60°F = 0.55 centipoise
- viscosity @ 71°F = .50326 centipoise
- vapor pressure = 8.7 psia

**Default pipe roughness = 0.00025 inches**

**All block valves, Cv = 41,551 gallons per minute**

**All check valves, Cv = 6,061 gallons per minute**

**ARCO, 2 pumps in series, same data for both pumps**

- pump suction fixed at 19 psig
- pump motor power = 350 horsepower
- pump motor speed = 1150 rpm
- pump speed = 1150 rpm
- pump head at best efficiency point = 163 feet
- pump power at best efficiency point = 401.6 horsepower based on water
- pump flow rate at best efficiency point = 8500 gallons per minute
- station suction/discharge pressure control valve Cv = 3100 gallons per minute
- control valve used equal percentage curve
- control valve actuator speed, full travel = 4 seconds

**Pipe from ARCO to Cherry Point**

- length = 4.0 miles
- inlet elevation = 102 feet
- outlet elevation = 119 feet
- outer diameter = 16.0 inch
- wall thickness = 0.312 inch
- pipe roughness = 0.0018 inch

**Cherry Point**

- United 14X24 DVS
- pump motor power = 1000 horsepower
- pump motor speed = 1782 rpm, pump speed = 1782 rpm
- pump head at best efficiency point = 568.3 feet
- pump power at best efficiency point = 1415 horsepower based on water
- pump flow rate at best efficiency point = 8500 gallons per minute
- station suction/discharge pressure control valve Cv = 3100 gallons per minute
- control valve used equal percentage curve and Set Pressure = 450 psig
- control valve actuator speed, full travel = 4 seconds
- suction controller set point = 19 psig
- discharge controller set point = 450 psig

**SA 002992**

**Pipeline from Cherry Point to TOSCO**

- length = 5.0695 miles
- inlet elevation = 119 feet
- outlet elevation = 180 feet
- outer diameter = 16.0 inch
- wall thickness = 0.312 inch

**Pipeline from TOSCO to Ferndale**

- length = 0.07575 miles, 400 feet
- inlet elevation = 180 feet
- outlet elevation = 180 feet
- outer diameter = 16.0 inch
- wall thickness = 0.312 inch

**FERNDALE UNIT #1**

- United 10 DVS, EX single stage
- pump motor power = 800 horsepower
- pump motor speed = 1782 rpm, pump speed = 1782 rpm
- pump head at best efficiency point = 481 feet
- pump power at best efficiency point = 691 horsepower based on water
- pump flow rate at best efficiency point = 4900 gallons per minute
- head curve correction = 0.8896
- flow correction = 0.9432
- power curve correction = 0.8390
- impeller changed from 22-inch to 20.75-inch diameter

**FERNDALE UNIT #2**

- United 10 x 19 DVS single stage
- General Electric, 2000-horsepower, 3600 RPM
- pump motor power = 2000 horsepower
- pump motor speed = 3570 rpm, pump speed = 3570 rpm
- pump head at best efficiency point = 1296 feet
- pump power at best efficiency point = 2994 horsepower based on water
- pump flow rate at best efficiency point = 8000 gallons per minute
- head curve correction = 0.9452
- flow correction = 0.9722
- power curve correction = 0.9190
- impeller changed from 18-inch to 17.5-inch diameter

**FERNDALE UNIT #3**

- United 10 x 19 DVS single stage
- General Electric, 2000-horsepower, 3600 RPM
- pump motor power = 2000 horsepower
- pump motor speed = 3570 rpm, pump speed = 3570 rpm
- pump head at best efficiency point = 1296 feet
- pump power at best efficiency point = 2994 horsepower based on water
- pump flow rate at best efficiency point = 8000 gallons per minute
- head curve correction = 0.9318
- flow correction = 0.9653
- power curve correction = 0.8994
- impeller changed from 18-inch to 17.375-inch diameter

**Ferndale Pump Station**

- station suction/discharge pressure control valve  $C_v = 4480$  gallons per minute
- control valve used equal percentage curve
- control valve actuator speed, full travel = 4 seconds
- suction controller set point = 63 psig
- discharge controller set point = 1320 psig

**Pipeline from Ferndale to Line Break location**

- length = 15.9199 miles
- inlet elevation = 180 feet
- outlet elevation = 255 feet
- outer diameter = 16.0 inch
- wall thickness = 0.312 inch

**Pipeline from Line Break location to Bayview**

- length = 23.25774 miles
- inlet elevation = 255 feet
- outlet elevation = 60 feet
- outer diameter = 16.0 inch
- wall thickness = 0.312 inch

**SA 002994**

**Bayview Pump Station/Terminal**

- MV.1902
  - set to close at downstream pressure (downstream of CV.1904) > 700 psig
  - Cv closed = 0.001
  - Cv open = 41551
  - linear operator
  - closing/opening time = 60-62 seconds
- inlet control valve, CV.1904,
  - Cv open = 6778 gallons per minute
  - Cv closed = 300 gallons per minute
  - control valve used equal percentage curve
  - control valve actuator speed, full travel = 4 seconds
  - valve controlled on downstream pressure
  - set to close when pressure > 600 psig
  - pressure above set point to cause valve to fully close = 120 psig

**Bayview Pump #202**

- BAYVIEW PUMP P-202, SULZER 14 X 14 X 26 HSA
- TECO, 1250 HP, 1800 RPM
- pump motor power = 1250 horsepower
- pump motor speed = 1780 rpm, pump speed = 1780 rpm
- pump head at best efficiency point = 500 feet
- pump power at best efficiency point = 1139 horsepower based on water
- pump flow rate at best efficiency point = 7500 gallons per minute

**Bayview Pump #201**

- BAYVIEW PUMP P-201, SULZER 14 X 14 X 26 HSA
- TECO, 1250 HP, 1800 RPM
- pump motor power = 1250 horsepower
- pump motor speed = 1800 rpm, pump speed = 1780 rpm
- pump head at best efficiency point = 495 feet
- pump power at best efficiency point = 1148 horsepower based on water
- pump flow rate at best efficiency point = 7500 gallons per minute

**Bayview Discharge (CV.1963)**

- station suction/discharge pressure control valve Cv = 3100 gallons per minute
- control valve used equal percentage curve
- control valve actuator speed, full travel = 4 seconds
- suction controller set point = 66 psig

**Brooks surge relief valve RV.1919**

- Cv = 1296 gallons per minute
- set point = 650 psig
- lag time between set point recognition and valve action = 1.5 seconds
- pressure above set point to cause valve to fully open = 17.5 psig
- control valve actuator speed, full travel = 0.5 seconds

RV1919 was model to malfunction and only crack open (lift disk).  
Therefore, the Cv was limited to about 40-50 maximum.  
The total relieved volume was about 42+/- barrels

**Brooks surge relief valve RV.1932**

- Cv = 1296 gallons per minute
- set point = 650 psig
- lag time between set point recognition and valve action = 1.5 seconds
- pressure above set point to cause valve to fully open = 17.5 psig
- control valve actuator speed, full travel = 0.5 seconds

RV1932 did not operate in the simulation of the June 10, 1999 event

**RELIEF HEADER**

- relief header from surge relief valve to 16" line
- length = 28 feet
- inlet elevation = 60 feet
- outlet elevation = 60 feet
- outer diameter = 8.625 inch
- wall thickness = 0.25 inch
  
- relief header from 16" line to check valve
- length = 0.0481 miles, 254 feet
- inlet elevation = 60 feet
- outlet elevation = 60 feet
- outer diameter = 16.0 inch
- wall thickness = 0.375 inch
  
- relief header from check valve to tk-209
- length = 0.05833 miles, 308 feet
- inlet elevation = 60 feet
- outlet elevation = 60 feet
- outer diameter = 16.0 inch
- wall thickness = 0.375 inch
- tank 209 constant pressure = 12.625 psig

**SA 002996**



**Pipeline from Line Bayview to Allen**

- length = 2.026 miles
- inlet elevation = 60 feet
- outlet elevation = 25 feet
- outer diameter = 16.0 inch
- wall thickness = 0.312 inch
- roughness = 0.0018 inches

**Allen Pump #1**

- United, 10x19 DVS, single stage
- General Electric, 3600 RPM, 2500 horsepower
- pump motor power = 2500 horsepower
- pump motor speed = 3560 rpm, pump speed = 3560 rpm
- pump head at best efficiency point = 1454.67 feet
- pump power at best efficiency point = 3579.8 horsepower based on water
- pump flow rate at best efficiency point = 8500 gallons per minute
- head curve correction = 0.9467
- flow correction = 0.9730
- power curve correction = 0.9211
- impeller changed from 18.5-inch to 18.0-inch diameter

**Allen Pump #2**

- United, 10x16 DVS, single stage
- General Electric, 3600 RPM, 1500 horsepower
- pump motor power = 1500 horsepower
- pump motor speed = 3560 rpm, pump speed = 3560 rpm
- pump head at best efficiency point = 992.07 feet
- pump power at best efficiency point = 2199.35 horsepower based on water
- pump flow rate at best efficiency point = 7500 gallons per minute

**Allen Pump #3**

- United, 10x19 DVS, single stage
- General Electric, 3600 RPM, 2500 horsepower
- pump motor power = 2500 horsepower
- pump motor speed = 3560 rpm, pump speed = 3560 rpm
- pump head at best efficiency point = 1449.27 feet
- pump power at best efficiency point = 3561.29 horsepower based on water
- pump flow rate at best efficiency point = 8500 gallons per minute
- head curve correction = 0.9732
- flow correction = 0.9865
- power curve correction = 0.9600
- impeller changed from 18.5-inch to 18.25-inch diameter

**SA 002997**

**Pipeline from Allen to Woodinville**

- Friction factor adjusted to match delta p from recorded data
- length = 49.53 miles
- inlet elevation = 5 feet
- outlet elevation = 430 feet
- outer diameter = 16.0 inch
- wall thickness = 0.312 inch
- the friction factor has been adjusted to model the effects of DRA in this section of line

**Woodinville Pump #1**

- United, 10x16 DVS, single stage
- General Electric, 3600 RPM, 2500 horsepower
- pump motor power = 1000 horsepower
- pump motor speed = 3560 rpm, pump speed = 3560 rpm
- pump head at best efficiency point = 618.18 feet
- pump power at best efficiency point = 1389.8 horsepower based on water
- pump flow rate at best efficiency point = 7750 gallons per minute

**Woodinville Pump #2**

- United, 10x19 DVS, single stage
- General Electric, 3600 RPM, 1500 horsepower
- pump motor power = 2000 horsepower
- pump motor speed = 3560 rpm, pump speed = 3560 rpm
- pump head at best efficiency point = 1302.57 feet
- pump power at best efficiency point = 2155.2 horsepower based on water
- pump flow rate at best efficiency point = 8000 gallons per minute

**Pipeline from Woodinville to Renton**

- Friction factor adjusted to match delta p from recorded data
- length = 26.10 miles
- inlet elevation = 430 feet
- outlet elevation = 10 feet
- outer diameter = 16.0 inch
- wall thickness = 0.312 inch
- the friction factor has been adjusted to model the effects of DRA in this section of line

**Surge Relief Valve at Renton**

- Brodie 16-inch, Cv = 5360

**Renton Station**

- Renton station has been modeled to allow switching and flow/pressure control to either TOSCO or Seattle

**SA 002998**


**Pipeline from Renton to Seattle**

- Friction factor adjusted to match delta p from recorded data
- length = 12.27 miles
- inlet elevation = 10 feet
- outlet elevation = 4 feet
- outer diameter = 12.75 inch
- wall thickness = 0.281 inch
- the friction factor has been adjusted to model the effects of DRA in this section of line

**Seattle**

- Seattle terminal has been modeled as an external with a flow/pressure control valve

**FIGURES 1 to 10**  
**SCHEMATIC DIAGRAMS**




ARCO PUMP STATION

\* NOTE: For control of  
ARCO pumps only;  
Model requirement

**OLYMPIC PIPELINE**  
ARCO Pump Station  
FIGURE 1  
September 1999 #MAR9916

SA 003001



**CHERRY POINT  
PUMP STATION**


Control set points  
are maximum values.

**OLYMPIC PIPELINE**

Cherry Point Pump Station  
FIGURE 2

September 1999 #MAR9916

FIGURE 2



SA 003003

Normal Shutdown  
Does Not Close:  
V.322, V.323  
V.324, V.325  
V.360, V.361




**M** - Motor Operator

Control set points  
are maximum values.

**OLYMPIC PIPELINE**

Ferndale Pump Station  
FIGURE 3

September 1999 #MAR9916



**M** - Motor Operator


**T** - Hand Operator

**OLYMPIC PIPELINE**

Ferndale to Bayview  
**FIGURE 4**

September 1999 MAR9916





**BAYVIEW  
PUMP STATION  
Mile Post 39.39**

SA 003005

All Shutdowns  
Close:  
MV.1986, MV.1990  
MV.1981, MV.1983


**M** - Motor Operator

Control set points  
are maximum values.  
"Incident" means June 10, 1999 event.

**OLYMPIC PIPELINE**

Bayview Terminal  
FIGURE 5

September 1999 #MAR9916



SA 003006

Normal Shutdown  
Does Not Close:  
V.521, V.520  
V.519, V.518  
V.566, V.565


**M** - Motor Operator

Control set points  
are maximum values.

**OLYMPIC PIPELINE**

Allen Pump Station  
FIGURE 6

September 1999 #MAR9916




**M** - Motor Operator

**T** - Hand Operator

**OLYMPIC PIPELINE**  
Allen to Woodinville  
**FIGURE 7**  
September 1999 #MAR9916

SA 003007



**WOODINVILLE  
PUMP STATION**  
Mile Post 86.87

Normal Shutdown  
Does Not Close:  
V.510, V.511  
V.516, V.517

 - Motor Operator



 - Hand Operator

Control set points  
are maximum values.

**OLYMPIC PIPELINE**

Woodinville Pump Station  
**FIGURE 8**

September 1999 #MAR9916



**M** - Motor Operator

**T** - Hand Operator


**OLYMPIC PIPELINE**

Woodinville to Renton  
 FIGURE 9

September 1999 #MAR9916

SA 003009

RENTON TERMINAL



**M** - Motor Operator

**T** - Hand Operator

**OLYMPIC PIPELINE**  
 Renton Station to Seattle  
 FIGURE 10  
 September 1999 #MAR9916


**APPENDIX 1**

**CASE 1 - Closure of Inlet Valve – Bayview Terminal**

**Flow Rate = 9117 bbl/hr**

**SA 003011**


CASE 1, FIGURE 1, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT BAYVIEW TERMINAL  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE WITHIN BELLINHAM CITY LIMITS



SA 003012




CASE 1, FIGURE 2, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT BAYVIEW TERMINAL  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM FERNDALE TO BAYVIEW




SA 003013

CASE 1, FIGURE 3, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT BAYVIEW TERMINAL  
FERNDALE, V.330, DOWNSTREAM PRESSURE AT DISCHARGE BLOCK VALVE




SA 003014

CASE 1, FIGURE 4, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT BAYVIEW TERMINAL  
PRESSURE AT LINE BREAK LOCATION, 15.9 MILES DOWNSTREAM OF FERNDALE



SA 003015

CASE 1, FIGURE 5, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT BAYVIEW TERMINAL  
BAYVIEW, MV.1902, UPSTREAM PRESSURE AT INLET BLOCK VALVE



SA 003016


**APPENDIX 2**

**CASE 2 - Closure of Inlet Valve – Bayview Terminal**

**Flow Rate = 9228 bbl/hr**


**SA 003017**

CASE 2, FIGURE 1, GASOLINE FLOW RATE 9228 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT BAYVIEW TERMINAL  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE WITHIN BELLINGHAM CITY LIMITS




SA 003018

CASE 2, FIGURE 2, GASOLINE FLOW RATE 9228 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT BAYVIEW TERMINAL  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM FERNDAL TO BAYVIEW



SA 003019


CASE 2, FIGURE 3, GASOLINE FLOW RATE 9228 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT BAYVIEW TERMINAL  
FERNDAL, V.330, DOWNSTREAM PRESSURE FOR DISCHARGE BLOCK VALVE



SA 003020




CASE 2, FIGURE 4, GASOLINE FLOW RATE 9228 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT BAYVIEW TERMINAL  
PRESSURE AT LINE BREAK LOCATION, 15.9 MILES DOWNSTREAM OF FERNDAL



SA 003021

CASE 2, FIGURE 5, GASOLINE FLOW RATE 9228 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT BAYVIEW TERMINAL  
BAYVIEW, MV.1902, UPSTREAM PRESSURE FOR INLET BLOCK VALVE



SA 003022


**APPENDIX 3**

**CASE 3 - Closure of Inlet Valve – Ferndale Pump Station**

**Flow Rate = 9117 bbl/hr**


**SA 003023**

CASE 3, FIGURE 1, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT FERNDALE PUMP STATION  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE WITHIN BELLINGHAM CITY LIMITS




SA 003024

CASE 3, FIGURE 2, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT FERNDALE PUMP STATION  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM CHERRY POINT TO FERNDALE




SA 003025

CASE 3, FIGURE 3, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT FERNDALE PUMP STATION  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM FERNDALE TO BAYVIEW




SA 003026

CASE 3, FIGURE 4, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT FERNDALE PUMP STATION  
CHERRY POINT, V.1408, DOWNSTREAM OF DISCHARGE CONTROL VALVE



SA 003027


CASE 3, FIGURE 1, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT FERNDALE PUMP STATION  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE WITHIN BELLINGHAM CITY LIMITS



SA 003024




CASE 3, FIGURE 5, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT FERNDALE PUMP STATION  
FERNDALE, V.373, UPSTREAM & DOWNSTREAM PRESSURES FOR INLET BLOCK VALVE




SA 003028

CASE 3, FIGURE 6, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT FERNDALE PUMP STATION  
PRESSURE AT LINE BREAK LOCATION, 15.9 MILES DOWNSTREAM OF FERNDALE



SA 003029

CASE 3, FIGURE 7, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT FERNDALE PUMP STATION  
BAYVIEW, MV.1902, UPSTREAM OF INLET BLOCK VALVE



SA 003030


**APPENDIX 4**

**CASE 4 - Closure of Inlet Valve – Allen Pump Station**

**Flow Rate = 9117 bbl/hr**


**SA 003031**

CASE 4, FIGURE 1, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT ALLEN PUMP STATION  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE WITHIN BELLINGHAM CITY LIMITS




SA 003032

CASE 4, FIGURE 2, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT ALLEN PUMP STATION  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM FERNDALE TO BAYVIEW




SA 003033

CASE 4, FIGURE 3, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT ALLEN PUMP STATION  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM BAYVIEW TO ALLEN



SA 003034


CASE 4, FIGURE 4, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT ALLEN PUMP STATION  
FERNDALE, V.330, DOWNSTREAM PRESSURE AT DISCHARGE BLOCK VALVE



SA 003035




CASE 4, FIGURE 5, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT ALLEN PUMP STATION  
PRESSURE AT LINE BREAK LOCATION, 15.9 MILES DOWNSTREAM OF FERNDALE




SA 003036

CASE 4, FIGURE 6, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT ALLEN PUMP STATION  
BAYVIEW, MV.1902, UPSTREAM OF INLET BLOCK VALVE




SA 003037

CASE 4, FIGURE 7, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT ALLEN PUMP STATION  
BAYVIEW, CV.1904, UPSTREAM & DOWNSTREAM PRESSURE OF INLET CONTROL VALVE




SA 003038

CASE 4, FIGURE 8, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT ALLEN PUMP STATION  
BAYVIEW, RV.1919, UPSTREAM PRESSURE & FLOW OF INLET RELIEF VALVE



SA 003039


CASE 4, FIGURE 9, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT ALLEN PUMP STATION  
BAYVIEW, P.201, PUMP SPEED OF BAYVIEW UNIT #1



SA 003040



CASE 4, FIGURE 10, GASOLINE FLOW RATE 9117 BBL/HR FROM ARCO, 10 SEP 1999  
EVENT CAUSED BY CLOSURE OF INLET BLOCK VALVE AT ALLEN PUMP STATION  
ALLEN, MV.502, UPSTREAM PRESSURE OF INLET BLOCK VALVE




SA 003041

**APPENDIX 5**

**CASE 5 – Event of June 10, 1999, Original Sequence,  
Mal-Function of RV1919**


CASE 5, FIGURE 1, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, MAL-FUNCTION OF RV.1919 AT BAYVIEW  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE WITHIN BELLINGHAM CITY LIMITS



SA 003043




CASE 5, FIGURE 2, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, MAL-FUNCTION OF RV.1919 AT BAYVIEW  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM FERNDAL TO BAYVIEW




SA 003044

CASE 5, FIGURE 3, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, MAL-FUNCTION RV.1919 AT BAYVIEW  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM ALLEN TO RENTON




SA 003045

CASE 5, FIGURE 4, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, MAL-FUNCTION OF RV.1919 AT BAYVIEW  
FERNDALE, V.327, PUMP DISCHARGE CONTROL VALVE PRESSURE & FLOW




SA 003046

CASE 5, FIGURE 5, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, MAL-FUNCTION OF RV.1919 AT BAYVIEW  
PRESSURE AT LINE BREAK LOCATION, 15.9 MILES DOWNSTREAM OF FERNDALE




SA 003047

CASE 5, FIGURE 6, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, MAL-FUNCTION OF RV.1919 AT BAYVIEW  
PRESSURE AT ALLEN JUNCTION



SA 003048


CASE 5, FIGURE 7, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, MAL-FUNCTION OF RV.1919 AT BAYVIEW  
BAYVIEW, MV.1902, UPSTREAM PRESSURE & FLOW AT INLET BLOCK VALVE



SA 003049




CASE 5, FIGURE 8, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, MAL-FUNCTION OF RV.1919 AT BAYVIEW  
 BAYVIEW, CV.1904, UPSTREAM PRESSURE & FLOW AT INLET CONTROL VALVE



SA 003050


CASE 5, FIGURE 9, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, MAL-FUNCTION OF RV.1919 AT BAYVIEW  
BAYVIEW, RV.1919, UPSTREAM PRESSURE & FLOW AT INLET RELIEF VALVE



SA 003051




CASE 5, FIGURE 10, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, MAL-FUNCTION OF RV.1919 AT BAYVIEW  
BAYVIEW, CV.1963, UPSTREAM PRESSURE & FLOW AT DISCHARGE CONTROL VALVE



SA 003052

CASE 5, FIGURE 11, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, MAL-FUNCTION OF RV.1919 AT BAYVIEW  
 ALLEN PUMP STA., PUMP SPEEDS & CV.517 DISCHARGE CONTROL VALVE




SA 003053

**APPENDIX 6**


**CASE 6 - Event of June 10, 1999, Original Sequence,  
Proper Function of RV1919**

CASE 6, FIGURE 1, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION OF RV.1919 AT BAYVIEW  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE WITHIN BELLINGHAM CITY LIMITS




SA 003055

CASE 6, FIGURE 2, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION OF RV.1919 AT BAYVIEW  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM FERNDAL TO BAYVIEW




SA 003056

CASE 6, FIGURE 3, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION OF RV.1919 AT BAYVIEW  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM ALLEN TO RENTON



SA 003057


CASE 6, FIGURE 4, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION OF RV.1919 AT BAYVIEW  
FERNDALE, V.327, PUMP DISCHARGE CONTROL VALVE PRESSURE & FLOW



SA 003058




CASE 6, FIGURE 5, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION OF RV.1919 AT BAYVIEW  
PRESSURE AT LINE BREAK LOCATION, 15.9 MILES DOWNSTREAM OF FERNDALE



SA 003059




CASE 6, FIGURE 6, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION OF RV.1919 AT BAYVIEW  
PRESSURE AT ALLEN JUNCTION




SA 003060

CASE 6, FIGURE 7, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION OF RV.1919 AT BAYVIEW  
BAYVIEW, MV.1902, UPSTREAM PRESSURE & FLOW AT INLET BLOCK VALVE




SA 003061

CASE 6, FIGURE 8, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION OF RV.1919 AT BAYVIEW  
BAYVIEW, CV.1904, UPSTREAM PRESSURE & FLOW AT INLET CONTROL VALVE



SA 003062


CASE 6, FIGURE 9, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION OF RV.1919 AT BAYVIEW  
BAYVIEW, RV.1919, UPSTREAM PRESSURE & FLOW AT INLET RELIEF VALVE



SA 003063




CASE 6, FIGURE 10, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION OF RV.1919 AT BAYVIEW  
BAYVIEW, CV.1963, UPSTREAM PRESSURE & FLOW AT DISCHARGE CONTROL VALVE



SA 003064

CASE 6, FIGURE 11, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, PROPER FUNCTION OF RV.1919 AT BAYVIEW  
 ALLEN PUMP STA., PUMP SPEEDS & CV.517 DISCHARGE CONTROL VALVE




SA 003065

**APPENDIX 7**

**CASE 7 - Event of June 10, 1999, Trip of ARCO first,  
Mal-Function of RV1919**

**SA 003066**


CASE 7, FIGURE 1, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE WITHIN BELLINGHAM CITY LIMITS



SA 003067




CASE 7, FIGURE 2, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM FERNDALE TO BAYVIEW




SA 003068

CASE 7, FIGURE 3, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM ALLEN TO RENTON




SA 003069

CASE 7, FIGURE 4, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
 FERNDALE, V.327, PUMP DISCHARGE CONTROL VALVE PRESSURE & FLOW




SA 003070

CASE 7, FIGURE 5, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
PRESSURE AT LINE BREAK LOCATION, 15.9 MILES DOWNSTREAM OF FERNDAL




SA 003071

CASE 7, FIGURE 6, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
PRESSURE AT ALLEN JUNCTION



SA 003072


CASE 7, FIGURE 7, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
BAYVIEW, MV.1902, UPSTREAM PRESSURE & FLOW AT INLET BLOCK VALVE



SA 003073




CASE 7, FIGURE 8, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
 BAYVIEW, CV.1904, UPSTREAM PRESSURE & FLOW AT INLET CONTROL VALVE



SA 003074


CASE 7, FIGURE 9, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
 BAYVIEW, RV.1919, UPSTREAM PRESSURE & FLOW AT INLET RELIEF VALVE



SA 003075




CASE 7, FIGURE 10, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
 BAYVIEW, CV.1963, UPSTREAM PRESSURE & FLOW AT DISCHARGE CONTROL VALVE




SA 003076

CASE 7, FIGURE 11, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
 ALLEN PUMP STA., PUMP SPEEDS & CV.517 DISCHARGE CONTROL VALVE




SA 003077

CASE 7, FIGURE 12, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
ARCO PUMP STA., PUMP SPEEDS & FLOW RATE



SA 003078


CASE 7, FIGURE 13, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
CHERRY POINT PUMP STA., PUMP SPEEDS & FLOW RATE



SA 003079



CASE 7, FIGURE 14, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, TRIP OF ARCO PUMPS FIRST & MAL-FUNCTION RV.1919  
 FERNDALE PUMP STA., PUMP SPEEDS & FLOW RATE




SA 003080

**APPENDIX 8**

**CASE 8 - Event of June 10, 1999, Original Sequence,  
NEW RV2229 @ 1000 psig, Flow Switch  
Trips Ferndale with 45 seconds delay,  
Mal-Function of RV1919, New Set Points  
CV1904 @ 500 psig, RV1919 @ 580psig,  
No Mechanical Stop on CV1904**


**SA 003081**

CASE 8, FIGURE 1, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE WITHIN BELLINGHAM CITY LIMITS



SA 003082


CASE 8, FIGURE 2, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM FERNDAL TO BAYVIEW



SA 003083




CASE 8, FIGURE 3, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM ALLEN TO RENTON




SA 003084

CASE 8, FIGURE 4, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
 FERNDALE, V.327, PUMP DISCHARGE CONTROL VALVE PRESSURE & FLOW




SA 003085

CASE 8, FIGURE 5, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
PRESSURE AT LINE BREAK LOCATION, 15.9 MILES DOWNSTREAM OF FERNDALE




SA 003086

CASE 8, FIGURE 6, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
PRESSURE AT ALLEN JUNCTION



SA 003087


CASE 8, FIGURE 7, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
 BAYVIEW, MV.1902, UPSTREAM PRESSURE & FLOW AT INLET BLOCK VALVE



SA 003088




CASE 8, FIGURE 8, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
 BAYVIEW, CV.1904, UPSTREAM PRESSURE & FLOW AT INLET CONTROL VALVE




SA 003089

CASE 8, FIGURE 9, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
 BAYVIEW, CV.1963, UPSTREAM PRESSURE & FLOW AT DISCHARGE CONTROL VALVE



SA 003090


CASE 8, FIGURE 10, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
 ALLEN PUMP STA., PUMP SPEEDS & CV.517 DISCHARGE CONTROL VALVE



SA 003091




CASE 8, FIGURE 11, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
CHERRY POINT PUMP STATION., PUMP SPEED & FLOW RATE




SA 003092

CASE 8, FIGURE 12, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
FERNDALE PUMP STA., PUMP SPEEDS & FLOW RATE




SA 003093

CASE 8, FIGURE 13, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
BAYVIEW, RV.2229, PRESSURE & FLOW IN NEW RELIEF VALVE UPSTREAM OF MV.1902



SA 003094

CASE 8, FIGURE 14, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, NEW RELIEF VALVE (RV.2229) @ 1000 PSIG & MAL-FUNCTION RV.1919  
BAYVIEW, TK.209, RELIEF VOLUME FROM RV.2229




SA 003095

**APPENDIX 9**

**CASE 9 - Event of June 10, 1999, Original Sequence,  
Proper Function of RV1919,  
NO Flow Switch to Ferndale,  
Mal-Function of RV2229, New Set Points  
CV1904 @ 500 psig, RV1919 @ 580psig,  
No Mechanical Stop on CV1904**


**SA 003096**

CASE 9, FIGURE 1, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE WITHIN BELLINGHAM CITY LIMITS




SA 003097

CASE 9, FIGURE 2, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM FERNDALE TO BAYVIEW



SA 003098


CASE 9, FIGURE 3, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
MAXIMUM TRANSIENT PRESSURE PROFILE FOR PIPELINE FROM ALLEN TO RENTON



SA 003099




CASE 9, FIGURE 4, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
FERNDALE, V.327, PUMP DISCHARGE CONTROL VALVE PRESSURE & FLOW




SA 003100

CASE 9, FIGURE 5, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
PRESSURE AT LINE BREAK LOCATION, 15.9 MILES DOWNSTREAM OF FERNDALE




SA 003101

CASE 9, FIGURE 6, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
PRESSURE AT ALLEN JUNCTION



SA 003102


CASE 9, FIGURE 7, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
BAYVIEW, MV.1902, UPSTREAM PRESSURE & FLOW AT INLET BLOCK VALVE



SA 003103




CASE 9, FIGURE 8, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
BAYVIEW, CV.1904, UPSTREAM PRESSURE & FLOW AT INLET CONTROL VALVE




SA 003104

CASE 9, FIGURE 9, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
BAYVIEW, RV.1919, UPSTREAM PRESSURE & FLOW AT INLET RELIEF VALVE



SA 003105


CASE 9, FIGURE 10, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
BAYVIEW, CV.1963, UPSTREAM PRESSURE & FLOW AT DISCHARGE CONTROL VALVE



SA 003106




CASE 9, FIGURE 11, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
 ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
 ALLEN PUMP STA., PUMP SPEEDS & CV.517 DISCHARGE CONTROL VALVE



SA 003107




CASE 9, FIGURE 12, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
CHERRY POINT PUMP STATION, PUMP SPEEDS & FLOW RATE




SA 003108

CASE 9, FIGURE 13, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
BAYVIEW, TK.209, RELIEF VOLUME FROM RV.1919



SA 003109

CASE 9, FIGURE 14, EVENT OF JUNE 10, 1999, FLOW RATE 8748 BBL/HR, 10 SEP 1999  
ORIGINAL SEQUENCE, PROPER FUNCTION RV.1919 @ 580 PSIG & MAL-FUNCTION RV.2229  
BAYVIEW, MV.1902, CV.1904 AND RV.1919 FRACTION OPEN



SA 003110