

Appendix J

Todd Smith, Olympic – Interview Transcript

Pipeline Rupture and Fire
Bellingham, Washington
June 10, 1999
DCA-99-MP-008

UNITED STATES OF AMERICA
NATIONAL TRANSPORTATION SAFETY BOARD

In the Matter of:
PIPELINE ACCIDENT AND FIRE
BELLINGHAM, WASHINGTON
JUNE 1999

Wednesday,
October 4, 2000

Statement of TODD VICTOR SMITH

BEFORE:

ALLEN BESHORE, Lead Investigator
CLIFF ZIMMERMAN, NTSB
PETER KATCHMARE, DOT
LINDA PILKE-JARVIS, WA State
ANTHONY BARBER, EPA
JAMES CASH, NTSB
ERIC SAGER, NTSB
GEOFFREY SMYTH, City of Bellingham
DIONE MAZZOLINI, Ecology & Environmental

APPEARANCES:

MICHAEL MARTIN, ESQUIRE
Counsel for Todd Smith

ALSO PRESENT:

ALFRED WHITE
GERRY SCHAU
PATTI IMHOF
JOHN PARRISH
LLOYD HARRISON TIEKEN

TABLE OF CONTENTS

STATEMENT OF: BESHORE/ZIMMERMAN/SCHAU/MAZZ.
TODD SMITH 5 & 112 53 61 69

KATCHMARE/SMYTH/PILKE/IMHOFF/
 103 103 107 116.

CASH/PILKE/
 118 250

LLOYD TIEKEN: BESHORE/ZIMMERMAN/KATCHMARE
 177 230 232

KATCHMARE/CASH/SAGER
 227 258 273

EXHIBITS:

PAGE

TODD SMITH:

No. T. Smith 1	5
No. T. Smith 2	35
No. T. Smith 3	35
No. T. Smith 4	67
No. T. Smith 5	70
No. T. Smith 6	72
No. T. Smith 7	111

LLOYD TIEKEN:

No. Tieken 1	285
--------------	-----

P R O C E E D I N G S1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

INVESTIGATOR BESHORE: Mr. Smith, my name is Allen Beshore. And I'm the Lead Investigator with National Transportation Safety Board into the pipeline accident and fire that occurred in Bellingham, Washington in June of 1999.

I want to thank you for coming in today and answering some of the questions that we have about the accident. And we're going to start out, I'm going to lead off, ask you some questions. Then, when I run out of questions or when I just need some time to collect my thoughts and relook through my notes, I'm going to kind of hand it off and we're going to go around the table.

All of these people may have some follow-up questions for you. Since they'll be asking questions also, I want to go around the room and introduce them to you so you know who they are and who they're with.

MR. ZIMMERMAN: I'm Cliff Zimmerman. I'm also an investigator for the NTSB.

MR. WHITE: Your last name, sir?

MR. ZIMMERMAN: Zimmerman.

MR. SCHAU: I'm Gerry Schau, with B.P.

MR. DANIEL: I'm Johnny B. Richmond, Daniel... Rosemont Petroleum.

1 MS. MAZZOLINI: I'm Dione Mazzolini, with
2 Ecology and Environment.

3 MR. KATCHMARE: Peter Katchmare, Office of
4 Pipeline Safety.

5 MR. SMYTH: Jeff Smyth, City of Bellingham.

6 MS. PILKE-JARVIS: Linda Pilke-Jarvis with
7 the Department of Ecology.

8 MS. IMHOF: I'm Patti Imhof with IMCO General
9 Construction.

10 MR. CASH: I'm Jim Cash, with the Safety
11 Board.

12 MR. SAGER: Eric Sager with the Safety Board.

13 INVESTIGATOR BESHORE: And, Mr. Smith, you
14 have a representative here with you today.

15 Can you identify him?

16 MR. MARTIN: Michael Martin, appearing with
17 Todd Smith.

18 INVESTIGATOR BESHORE: And you've given your
19 contact information to our court reporter?

20 MR. SMYTH: I'll do that at the break.

21 INVESTIGATOR BESHORE: Okay.

22 MR. MARTIN: Just before we start, could we
23 also include as part of the record the transcript copy
24 of the Compulsion Order for...

25 INVESTIGATOR BESHORE: Certainly, we'll

1 identify this as ~~Smith~~^{SMITH} Exhibit 1.

2 MR. MARTIN: That's fine.

3 INVESTIGATOR BESHORE: And attach it to the
4 record. It's the Compulsion Order from the NTSB
5 compelling testimony here today.

6 MR. MARTIN: Thank you.

7 (Whereupon, the previously-
8 identified document, marked as
9 Exhibit T. Smith No. 1 for
10 identification, was received
11 into the record.)

12 Whereupon,

13 TODD VICTOR SMITH
14 was called for statement and was examined, and
15 testified as follows:

16 E X A M I N A T I O N

17 BY INVESTIGATOR BESHORE:

18 Q Mr. Smith, if you could, just state your full
19 name for us, please?

20 A Todd Victor Smith.

21 Q And, if you could, just describe briefly your
22 educational background?

23 A High school, some college. I don't have a
24 college degree. And that's pretty much my educational
25 background.

1 Q What were your college studies? Were they in
2 some --

3 A Math and Science.

4 Q If you could, just recount your history with
5 Olympic Pipeline, when you were hired and went through
6 your various duties since you worked for them.

7 A I've been with Olympic Pipeline for fifteen
8 years. So I hired on as a Utility Pipeliner.
9 Transferred into Operations. I've worked from there
10 into the Control Center as a Utility Operations
11 Controller, and then to an Operations Controller.
12 Then, to the Level I Operations Controller.

13 And started working in the computer side of
14 the business and currently hold the title of Systems
15 Engineer.

16 Q Okay, can we just kind of go through and get
17 a little bit of time frames on some of these roles, if
18 we could.

19 When did you transfer into the Operations
20 Center as a Controller, approximately?

21 A Thirteen years ago.

22 Q That would have been 1987? Eighty-six?

23 A Eighty-seven, '88, something like that. I
24 don't know.

25 Q And then how long were you in the control

1 center as a controller? Well, I guess various levels
2 of responsibility as a controller? Is that my correct
3 understanding? You went through two or three titles.

4 A Right. You usually start out as what they
5 call the utility operations controller. It's the entry
6 level position. You come in, start doing the paperwork
7 and learning about how to, you know, do the various
8 switches and batch changes.

9 And get some hydraulic background and then
10 gradually work into actually operating the pipeline.

11 At some point, they get enough confidence in
12 you where you become a, you know, you're able to take a
13 shift, share the responsibility with the partner
14 controller.

15 Q Okay, and then you moved into a system
16 programmer role. When was that?

17 A I've been doing that on special assignment
18 from the control center since about 1995.

19 Q And did that become a full time role at some
20 point since the accident?

21 A Since the accident, it's become a full time
22 role.

23 Q But, prior to June of '99, you fulfilled that
24 role at certain times depending upon a special
25 assignment or need that they had for you?

1 A Right. Initially, I was brought into the
2 computer side to work with the PLES^D leak detection
3 model to try and tune that up. And make it a
4 functional tool for the control center.

5 And then from there I started moving into
6 doing maintenance on the "SCADA^D system". Eventually,
7 it just worked into a full time position; with the
8 retirement of Duane Whitlow, I think, is what made that
9 more or less a full time position.

10 Q Oh, okay, and that was after the accident in
11 June? When was that? Do you recall?

12 A That would have been -- no, Duane Whitlow
13 retired before the incident in June. But I just ended
14 up, you know, spending more time with the computers,
15 you know, after he retired.

16 I didn't actually get a title until after the
17 incident. It's just my responsibility shifted more and
18 more toward maintenance of the SCADA^D system in
19 computers.

20 Q But you were still operating at some points
21 in time as a regular controller after the accident?

22 A Yes. I was doing occasional work in the
23 control center.

24 Q And so you would get some shifts as an
25 operations controller?

1 A Right, mainly in a vacation or relief type
2 capacity.

3 Q At that point in time, most of your duties
4 were spent in the programming role, you would say?

5 A Yes.

6 Q And then I guess in 1995, you had said your
7 first assignment was to work on a PL^DBS system, right?

8 A Yes.

9 Q Was that the first time that the leak
10 detection software had been introduced into the Olympic
11 system?

12 A They started working on that I believe in
13 1994 and '95. Shortly after it was installed, then I
14 was asked to come over and, you know, work on getting
15 it tuned up.

16 Q I guess my question, was there another leak
17 detection software that existed in the system prior to
18 that that was replaced by this software package? Or
19 was this kind of a new product that was being
20 introduced into...?

21 A This would be the addition of a new tool.
22 Previous to that, we -- and continue to this day -- to
23 do our hourly line balance and weighter change
24 monitoring, things like that.

25 So this would just be another tool that was

1 added to that.

2 Q And those other things you mentioned are hand
3 calculations that --

4 A Yes.

5 Q -- that the controllers do throughout the
6 shift?

7 A Yes.

8 Q Who do you report to? Or who did you report
9 to -- excuse me -- on June 10th of '99?

10 A Ron Brenson.

11 Q Did you report to Ron throughout the process
12 in '95 up until --

13 A Yes.

14 Q My question is for both purposes, of being a
15 controller and for being a programmer, you reported to
16 Ron Brenson; correct?

17 A Yes.

18 Q And did you have any input into the design of
19 the Bay View Terminal facility?

20 A Nothing specific. My role was to configure
21 the data bases in the SCAFA system based on a point
22 list that was provided to me.

23 Q Okay, so the design team gave you a list of
24 data that they wanted to monitor and then you
25 programmed the SCAFA system to take that into

1 consideration?

2 A Yes. The programming is not the appropriate
3 tone. It's basically just data base entry. I have
4 done some programming, but I am not a programmer, per
5 se. I have never done any programming with the SCATA^D
6 system, or programming with the leak detection is
7 basically hardware maintenance, system maintenance,
8 data base maintenance kind of thing.

9 Q Okay, so the programming is actually the
10 product you purchase as a program.

11 A Yes.

12 Q And then you're setting up the data that goes
13 into that program's calculations.

14 A Correct.

15 Q Let's talk about as Bay View was being
16 commissioned. Or should I say after it was
17 commissioned.

18 Were you aware of any operational issues that
19 arose as a result of the installation of the new
20 station?

21 A The only issue that I was aware of was the --
22 I guess they would call them unscheduled shutdowns of
23 the facility caused by safety devices within the
24 facility to protect it for overpressure.

25 Q So, specifically, that would be the block

1 valve coming into the Bay View Station closing?

2 A No, that would be a result of the pressure
3 switch detecting the high pressure situation at its
4 location.

5 Q Okay, the pressure switch at Bay View
6 terminal would get a pressure that would then trigger
7 that valve to close; is that correct?

8 A Right.

9 Q and would you guys also receive signals about
10 a relief valve relieving in Bay View? Do you recall?

11 A The designer of Bay View never included any
12 indications that were direct to the surge relief valves
13 at Bay View. There were no electrical switches
14 attached to the relief valves, or no electrical
15 indications attached to the relief valves.

16 Q So the only indication you received was that
17 there was flow into tank 209; is that correct?

18 A That's correct.

19 Q And that could have been from either a sump
20 discharge or from the relief valve function?

21 A That's correct, or a tank tracks rockers. It
22 detects movement in that pipe section where that device
23 was located.

24 Q And that's been changed, I understand, since
25 then.

1 A The device is still there. It's still
2 active. They have added ~~an~~^{IN} addition to that,
3 indicators for each of the relief valves in the
4 facility.

5 Q So you'll be able to in the future, assuming
6 that terminal is back in operation, hopefully, will be
7 able to see each individual relief valve?

8 A Yes, they are identified individually and
9 brought into the SCA~~A~~^D system individually.

10 Q Now did you develop the screens or the
11 picture styles for the SCA~~A~~^D system that were used for
12 the Bay View terminal once it was brought on line?

13 A I probably had some input into it but Lloyd
14 Tieken did the lion's share of the development of the
15 screen work.

16 Q Did the problems that occurred, well, the
17 issues that arose at Bay View, did they affect both
18 sets of operations, whether it be the line and
19 informatic orders, or whether it would be a line down
20 from burndown?

21 A They could. If you know both systems went
22 through Bay View, they could have each experienced the
23 same types of problems.

24 Q Well, they were pretty much identical setups;
25 is that correct? Well, that's probably too broad a

1 term. But, in terms of the relief valving and the
2 incoming closures, that specific piece of it?

3 A They should have been pretty much identical.

4 Q Did you experience operational problems as a
5 controller with operating either of those two lines
6 personally?

7 A Not that I can recall. I can't recall any
8 specific incidents. And because it was all the work
9 that I've done, you know, providing information for the
10 various agencies, and so forth, I can't clearly say
11 whether or not when I became aware of the problems, or
12 if I actually experienced them myself.

13 I just know that they were having problems.

14 Q Okay, so you don't recall any specific
15 instance where you were operating the line and this
16 pressure indication reached in and closed the block
17 valve on you?

18 A Right. Right.

19 Q All right, there ^{WERE} was a few emails. And maybe
20 you can help me understand the scenario on there.
21 There was a control valve there that was...

22 INVESTIGATOR BESHORE: Off the record.

23 (Record paused.)

24 INVESTIGATOR BESHORE: Okay, we're talking
25 about issues within the Bay View station facility after

1 it was brought on line.

2 MR. SMITH: Correct.

3 BY INVESTIGATOR BESHORE:

4 Q Do you recall any issues surrounding the
5 control valve that was controlling I believe it was the
6 discharge side and set point reductions?

7 Can you explain to me what that issue was?
8 Do you recall that?

9 A I don't recall any specific issue with the
10 control valves.

11 Q Okay. I've got a couple of emails here that
12 we'll talk about in a few minutes that maybe will help
13 you, jog your memory on that.

14 A Sure.

15 Q And try and help understand that issue.

16 Do you recall having any discussions in
17 general with the other controllers about any of these
18 issues or concerns that people had prior to the
19 accident about some of these operational issues they
20 were experiencing?

21 A I don't recall any specific conversations,
22 but I know there was a concern. I know that there were
23 issues that were talked about. The high-pressure
24 facility shutdowns and those types of issues.

25 Q High-pressure facilities shut down?

1 A The things we've talked about with the valve,
2 the pressure switches, and those types of things.

3 Q Oh, okay. By high pressure, you mean
4 exceeding those pressure settings?

5 A Right.

6 Q And so you know it was an issue to some
7 people but you don't specifically remember any
8 conversations?

9 A I don't remember any specific conversations
10 with anybody. I know that it was talked about.

11 Q Was it pretty much a uniformed or universal
12 issue of concern to the controllers, would you --?

13 A Well, you know, any time that the facility
14 shuts down and then closes the valves, it interrupts
15 the pipeline and the flow of work. And it was a
16 concern, yes.

17 Q And so was it a major concern, you would say?

18 A Well, it was a concern.

19 Q Was it a safety concern?

20 A I would say it could have been a safety
21 concern. But I think that it was more of the
22 discussion revolved around being more of just a
23 nuisance or inconvenience.

24 Q It caused the controller work, extra work.

25 A Right.

1 Q Now would that be something that would be
2 considered an abnormal operation to you, that valve
3 closing?

4 A The valve closure itself would not be an
5 abnormal condition because it was programmed to close
6 with the station shut down.

7 Q So, because of the design, you didn't
8 consider that to be an abnormal condition? An abnormal
9 operation, I guess?

10 A Well, no. I mean, yes, it's an abnormal
11 condition but are we asking is it an abnormal condition
12 under the operations and procedures manual or is it
13 just would be my opinion that it was an abnormal?

14 Because if you're asking my opinion, yes, I
15 would consider that an abnormal operation, and so would
16 any other reasonable person would consider that to be
17 abnormal.

18 Q But, in the context of your procedures, you
19 would not consider it to be something that needed to be
20 logged or reported or the procedure needed to be looked
21 at?

22 A No, because the facility was just basically
23 brand-new. All those types of issues needed to be
24 brought up to the engineering department. And, they
25 needed to be, you know, worked out because, regardless

1 of your point of view, it was something that you
2 wouldn't want to be going on, you know, at all.

3 So it was something that needed to be worked
4 on.

5 Q Did you bring it up to these folks?

6 A To which folks?

7 Q The engineering department, I think you
8 mentioned, to be resolved?

9 A The engineering department was well aware of
10 the problems that were going on with the things at Bay
11 View.

12 Q I mean, did you, yourself, or Ron Brenson or,
13 I mean, how were they made aware of? Do you know?

14 A I don't know.

15 Q But, you know that they were well aware of
16 them?

17 A Right.

18 Q And do you know what they were doing to try
19 and resolve those issues?

20 A I don't know the details.

21 Q Did you, in your understanding of the design
22 of the station, did you understand that there was, you
23 know, relief valves that were set to relieve pressure
24 at a lower set point than the pressure reached to close
25 the block valve?

1 A I don't know. I don't have an understanding
2 of that. It would have been laid out in the operations
3 procedures manual what the set points were. I don't
4 know off the top of my head what they were set at.

5 Q So you don't --

6 A Typically, you would want the relief valve to
7 go before the station would shut down, the activation
8 of the switch.

9 Q I guess I'm kind of asking about what your
10 understanding was at the time. I guess my question
11 goes to was it your understanding that this block valve
12 closing was actually kind of a secondary level of
13 protection over and above a lower level of protection
14 provided by relief valves?

15 A The block valve closing was a sequencing that
16 occurred on a station shutdown, which one of the causes
17 would be activation of the high-pressure switch.
18 Typically, your relief valve would be set at some value
19 lower than the switch.

20 So, yes, my understanding would have been
21 that the set point would have been lower than the
22 switch.

23 Q All right. Now do you recall any
24 conversations where there was some concern about maybe
25 the relief valves were not functioning properly?

1 A I don't recall any specific conversation on
2 that. And then again my recollection is kind of
3 tainted because I've done a lot of research into those
4 types of issues.

5 Q Let's go back to before the Bay View Station
6 was installed. You were an operations controller for
7 some time. Did you experience any other block valves
8 that might have closed in an uncommanded fashion while
9 you were operating the system?

10 A If you're going to go with the strict term of
11 "block valve", the valve at Bay View was a dual
12 function valve. People call it a block valve. In
13 fact, it is a receiver inlet valve.

14 It's as opposed to a mainline block valve,
15 which is, you know, standing out there by itself.

16 The function of this block valve was to
17 protect a facility and, in that capacity, all of our
18 facilities have that feature. Any delivery facility,
19 for example, if you exceed a pressure switch inside,
20 the facility will close their incoming valve.

21 So, in that capacity, yes, I have experienced
22 that.

23 Q How frequently? Do you recall?

24 A It would not be frequent. Occasionally.

25 Q Once or twice a year?

1 A I can't put a number on it right now.

2 Q Once or twice in your career?

3 A Oh, no, it would be more than that. I think
4 you probably could find a couple of times a year that,
5 you know, things would happen to cause that type of an
6 occurrence.

7 Q Was there any facility in particular aside
8 from Bay View that you could think of when I asked that
9 question?

10 A Any of our -- it could happen at any delivery
11 facility.

12 Q Mainly, down -- end-user delivery facilities,
13 or are these pumping station facilities on the line?
14 Or is there a distinction in your mind there?

15 A There is a distinction. Typically, a
16 mainline pumping station does not have launcher
17 receivers. And so they would just have a block valve.

18 Typically, the function at a mainline station
19 where the pressure switch is activated would be to drop
20 the units, sequence the units down, and not have any
21 valves closed.

22 At a delivery facility, it's at the end of
23 the line and at those points the facility would be
24 isolated from the system.

25 Q Okay, so in your mind when you're thinking

1 back on times when block valves are closed, are you
2 thinking mostly of down delivery facilities --

3 A Uh-huh.

4 Q -- of the end user and not necessarily
5 affecting the rest of the main line, I guess?

6 A Well, it could affect the whole system. It
7 could affect the whole system or a whole system.

8 Because it's not uncommon for us to pump fuel
9 line into a delivery facility. So, therefore, if it
10 were to shut down, it would cause shutdown of the
11 entire system.

12 Q Okay, I understand now. Okay. All right,
13 let's talk a little bit about training after the Bay
14 View station was brought on line. I guess there was a
15 general concern that there were some issues here.

16 Was there any training that was provided to
17 the controllers to try and help them understand what
18 was going on?

19 A I don't recall any formal training as far as
20 Bay View was concerned. It was more or less felt to be
21 just another facility, delivery facility, pump station
22 facility. And designed to operate like any of the
23 other facilities that we have.

24 Q Okay, but if I understood what you answered,
25 the last answer, it was not necessarily like the other

1 pumping stations you had on the main line, for at least
2 a couple of reasons you mentioned. Is that correct?

3 A I can clarify on that a little bit, if I
4 could.

5 Q Sure.

6 A Bay View is the same as a delivery facility
7 in that it has the terminal facility, or products are
8 brought into Bay View. And then, separate from that
9 but at the same time along with that is the pumping
10 station where they're actually lifting out of tanks.

11 So it actually has both the features of a
12 delivery facility and a pumping station.

13 Q Is that the only facility in Olympics' system
14 that has that dual capability?

15 A I would answer that strictly no. For
16 example, at our Allen Station, we have a delivery
17 facility there. It's not up the same way. And then
18 our Renton facility, we have a delivery facility there
19 as well.

20 At Ta^cloma Station, we have a delivery
21 facility. So the main difference is having the low
22 pressure piping system inserted in line with the high-
23 pressure pipeline, you know, on the other side of that.

24 Q And that's what requires the extra
25 protections for relief valves and what not?

1 A Yes.

2 Q Because of the 300 --

3 A Well, for example, Portland, our delivery
4 facility at Portland, we have a main line coming into
5 that delivery facility. It has a receiver, a scraper
6 receiver. It can receive tools, just like Bay View.

7 It has a scraper inlet, bypass and outlet.

8 The receiver inlet is the same thing that you would
9 call the block valve at Bay View. It serves the exact,
10 same function.

11 There are the same pressure switches. You
12 know, it's all pretty much the same stuff. And both
13 are subjected to the same types of issues as far as
14 pressure.

15 Q Well, I mean just for future reference when
16 I'm asking about block valve, I'm generally meaning the
17 valve that it shuts, stops the flow of fuel through the
18 main pipeline on down the mainline pipeline.

19 That could be a receiver... as you say, or
20 just about the pipeline. I guess that's what I'm
21 thinking of. So, thank you.

22 A Well, the main difference is that a block
23 valve would not be necessarily programmed to close with
24 a pressure switch.

25 Q Do you mean out on the pipeline somewhere?

1 A Right. Right.

2 Q Okay, and those are closed by either
3 operation by hand or by some input from you guys, but
4 not necessarily an automatic sequence?

5 A No automatic sequence.

6 Q All right, thank you.

7 Now do you recall any other issues that
8 arose, aside from the valves and these other things?
9 Do you recall any other specific issues that were of a
10 concern to folks as a result of the Bay View terminal
11 installation?

12 A Well, there was a concern about, you know,
13 how to do batch changes and, you know, different
14 things; how to start up... tanks, different operational
15 issues that hadn't had an opportunity to mature and be
16 formally worked out?

17 Q Would you consider those accounting issues,
18 or are those operational issues?

19 A Well, both. You know, how do I transition
20 from, you know, just bypassing the facility to going
21 into a tank, for example. You know, where do I make my
22 cut? Coming out of the tank, how do I transition from
23 going through the station, or just coming out of the
24 tank, and those types of things.

25 Q And those things were never really well-

1 defined by anyone?

2 A That facility never had the opportunity to
3 mature to the point where those things could be -- I
4 mean the number of permutations for operations there
5 was, you know, too many to just start writing them all
6 down. It needed to be defined, what the operation of
7 the facility was going to be.

8 Basically, it was at sea trials, you know.
9 It had gone through the point by point and the station
10 facility checks, and now the facility was running and
11 they were trying to work out, you know, the problems
12 that would occur under normal operations.

13 Q Okay, so you feel like, as time went on,
14 these things would have been better-defined?

15 A Yes.

16 Q But, as of the point of the accident in June,
17 had not really been -- because of the short history of
18 it. I mean, my understanding of it --

19 A Right. We had, you know, a number of
20 procedures that were rickling, but we hadn't had a
21 chance to try them all out. They hadn't been tuned
22 specifically.

23 Q In terms of procedures for these operations,
24 did you have any responsibilities for developing O&M
25 procedures associated with the station?

1 A No.

2 Q Or with any other procedures?

3 A I'd written procedures for other facilities,
4 but not for Bay View.

5 Q And that wasn't something that was a general
6 responsibility for you? I mean somebody assigns you to
7 write a procedure for a specific station? It wasn't
8 your responsibility to maintain the overall manual, or
9 anything like that, I guess my question is?

10 A No. No, the way things typically work,
11 dispatchers would think of, you know, perhaps a better
12 way to do something. You know, it would be proposed
13 and passed around and then, the sense would I guess be
14 either adopt it or discard it.

15 Q And that would be proposed -- I'm assuming at
16 your control center to Ron Brenson, and then he would
17 make that decision on whether it should be?

18 A All the dispatchers would have him put on
19 those types of changes. It would be kind of "What do
20 you think about this guy's? Why don't we try doing it
21 this way," type of a thing.

22 Q But, ultimately, it would be his decision?

23 A Ultimately, yes.

24 Q How long has Ron Brenson been the supervisor
25 there?

1 A He's been supervisor there for, oh, a long
2 time. A long time.

3 Q Was he a supervisor when you first became a
4 controller?

5 A I don't know when he was officially promoted
6 to that position.

7 Q He's been in the control room ever since
8 you've been in the control room. Was he another
9 controller at the time?

10 A He came from that background. I would defer
11 you to his personnel file to nail down those dates and
12 things.

13 Q To characterize your statement, he's been
14 there a long time.

15 A He hasn't always been my supervisor. Prior
16 to Ron, there was a gentleman named Will Hood, who was
17 my initial supervisor in the control center.

18 Q There were some changes made to the O&M
19 manual we understand in March of '98, shortly before
20 inspection by the Office of Pipeline Safety.

21 Are you familiar with the changes? I'm
22 talking about the operations maintenance procedure
23 manual. Are you familiar with those changes or with
24 that process?

25 A I am not familiar with that. I'm not

1 familiar with that. It's just a general update?

2 Q Well, the report we had was that the manual
3 from Texaco was basically updated and became the manual
4 for the Olympic Pipeline System shortly prior to an OPS
5 inspection.

6 A I don't know that that would be the
7 Operations and Procedures Manual because it's pretty
8 much been Olympic's document since the inception.

9 So maybe we're talking about two different
10 documents.

11 Q Actually, I meant March of '99, so my mistake
12 here.

13 A I don't recall any specific changes,
14 especially regarding Texaco.

15 Q Well, I don't know that -- okay, let's talk
16 about manuals just for a minute, if we could.

17 A Sure.

18 Q Because I'm a little confused on how many
19 manuals we have here.

20 There's an operations manual for controllers;
21 correct?

22 A The only manual that is in effect, to my
23 knowledge has ever been in effect, is the operations
24 procedures manual that contains, you know, section one
25 as outlined by the part 49.145 operations procedures

1 manual, General Operating Procedures Manual.

2 There have been other documents. There was a
3 manual that was given as a reference for controllers
4 that basically talked about the same types of things.
5 But it was never an official, or never meant to be an
6 official operations and procedures manual.

7 Q So that was more of a guidance document; is
8 that right?

9 A More of a training document.

10 Q And that's operations --

11 A That's the one right there.

12 Q Okay, I'm not going to mark it as an exhibit
13 but it's page 715 that we were provided earlier with a
14 bunch of stuff.

15 A Right. And some of those things have been
16 incorporated in here recently. There is also on the
17 back side of that another manual that was within the
18 same volume.

19 Q Okay, it was like volume one and two of the
20 same. Okay. And then there was also referenced in
21 somebody's previous testimony a standard operations
22 procedure manual.

23 Are you familiar with that?

24 Q SOP?

25 A SOP, okay. Yes, in conjunction with the

1 general operating procedures, each facility maintains a
2 volume that they call their SOP, or standard operating
3 procedures, that are specific to the operations at the
4 individual facilities.

5 For example, the control center would have an
6 SOP. It would have information about how to do
7 specific batch changes and general information, like
8 line fields and things like that.

9 Q Okay, so that's a facility-specific --

10 A Yes.

11 Q -- type of a document. So there's one in the
12 control center for --

13 A Correct.

14 Q There would be one at Bay View, I'm assuming,
15 for station operations...

16 A Yes. Typically, each facility would have one
17 of those that would pertain specifically to the
18 operations at that location.

19 Q There is also something, and I don't recall
20 the reference, that mentioned a DOT compliance manual.
21 Now is there a separate document that that's manual, or
22 is that --

23 A I wouldn't know what that is.

24 Q Okay, so you've not heard of that?

25 A No.

1 Q Are there any other manuals in the control
2 room for you guys to review or that you're familiar
3 with that provide direction to your operations?

4 A There are.

5 Q What might those be?

6 A There is a document that required I guess by
7 the Department of Ecology for how to respond to
8 reported incidents, which made up several volumes.

9 Q Is that like the contingency plan --

10 A The contingency plan, and stuff like that,
11 correct.

12 Q Are there any others that you can think of?

13 A No, not off the top of my head.

14 Q Okay. I think maybe this email here, if you
15 could just take a look at that, I would appreciate it.
16 Yes, I will probably enter that into an exhibit.

17 Maybe, this one here will help, too. I think
18 that's on the same issue, but maybe you can help me
19 understand the issue better.

20 Have you seen either of those? Take your
21 time reading it.

22 A Yes, let me take a look here.

23 (Perusing documents.)

24 Okay. And your question?

25 Q Are you familiar with those emails?

1 A Not specifically these emails, but I'm
2 familiar with what they're talking about in this
3 particular situation.

4 Q Okay, so now you recall the issue?

5 A Sure.

6 Q Can you explain to us what the issue was?

7 A Right. On the incoming side of Bay View,
8 there are actually two control valves. One would
9 control the amount of pressure allowed into the
10 facility; and the control valve just downstream of that
11 and downstream of the meter run was designed to hold a
12 certain amount of back pressure on the meter.

13 Each meter installation requires, you know, a
14 certain amount of back pressure. This was apparently
15 set at 10 pounds to 20 pounds, or something like that.

16 And what was happening was is if the flow
17 rate downstream of Bay View got to be too high such
18 that the flow rate coming into the facility couldn't
19 keep up with it that the downstream control valve would
20 close and cause a suction problem downstream at Allen.

21 Q Okay, would it cause a problem at Allen or
22 Bay View?

23 A It would cause a problem at Allen.

24 Q Would it knock down the pump at Bay View, or
25 am I confused in my logic?

1 A It could knock down the pump at Bay View. It
2 would affect all downstream operations --

3 Q Because of all the suction from then on?

4 A Well, it would depend on the configuration of
5 Bay View, whether or not you were tight-lined through
6 Bay View or floating on a tank at Bay View. You know,
7 the situation.

8 Q Okay, and they were having problems here.
9 They were tight-lined through?

10 A Yes.

11 Q So do you remember how that issue was
12 resolved?

13 A I believe that the initial thing was to lower
14 the set point because we don't do custody transfer at
15 that facility. I think the choice or the temporary
16 work around would be to allow a degradation in
17 measurement there to allow more throughput through the
18 facility.

19 Q Okay, so they reduced the set point in there
20 in order to operate on a lower suction?

21 A Right.

22 Q Was that issue there somehow associated with
23 the issue of pressure increases that would ultimately
24 result in the incoming valve closing?

25 A It could. If suction at Allen were to be,

1 you know, low enough to cause the Units[†] to shut down, it
2 could cause a surge back through the Bay View facility.

3 INVESTIGATOR BESHORE: Would somebody go
4 ahead and enter those in as exhibits, and hand those
5 back?

6 There's an email, 3/2/99, and I'll date that
7 exhibit from Ron Brenson[†]. That will be Exhibit 2 --
8 Exhibit-Smith 2 -- excuse me.

9 (Whereupon, the previously-
10 identified document, marked as
11 Exhibit T. Smith 2 for
12 identification, was received
13 into record.)

14 INVESTIGATOR BESHORE: And then Exhibit Smith
15 No. 3 will be the date is 3/10/99 from Craig^H Lammet.

16 (Whereupon, the previously-
17 identified document, marked as
18 Exhibit T. Smith 3 for
19 identification, was received
20 into record.)

21 INVESTIGATOR BESHORE: Actually, I want to
22 make these T. Smith, in case we talk with Mr. Smyth.

23 MR. SMITH: What's the chance of that?

24 INVESTIGATOR BESHORE: Okay, I think we
25 covered manuals. Let's go to the date of June 10, to

1 the accident day.

2 BY INVESTIGATOR BESHORE:

3 Q Were you on duty on that day?

4 A I was.

5 Q Were you at the Renton headquarters?

6 A I was.

7 Q What were you doing that day?

8 A Just a typical day. I was working with the
9 computer system that day, special assignment.

10 Q Do you remember what you were doing that day?

11 A Not specifically, no.

12 Q Do you remember -- all right, let me just go
13 to the gist of this. Let's go to the afternoon of June
14 10. Can you recall? Run me through the afternoon.

15 You ate some lunch and then what happened?

16 A I went home.

17 Q Okay, you went home. What time did you leave
18 the Renton office?

19 A Two or 2:30. I don't recall the specific
20 time.

21 Q Did you have vacation or just personal
22 business you left the office?

23 A I just took some time off.

24 Q And you were enjoying your time off, I'm
25 assuming, and then what happened?

1 A I talked to -- I had a conversation with
2 Lloyd Tieken. I don't remember whether he paged me or
3 he called me. But, anyway, I talked to Lloyd Tieken.
4 And he had told me about that he had had some problems
5 with the computers. And that the system had, you know,
6 been down.

7 Basically, when the whole thing was over with
8 and now he was up and running, he was giving a
9 reoccurring entry in an error log on the SCADA system.
10 And was wanting to know if I couldn't help him to clear
11 that up.

12 Q What advice did you give him?

13 A There was a process that wasn't being used
14 any longer that had not been ginned out of the system
15 that at the time had just, you know, manually -- was
16 just manually shutting off.

17 Of course, when the system started back up,
18 the process started back up with it and it would
19 occasionally put an entry in the error log.

20 So that the remedy was to shut that process
21 off, and the error went away.

22 Q All right, so he called you. He's in the
23 midst of this.

24 A I was over.

25 Q Okay, so he was done with -- when he called

1 Q But he didn't say anything about such a
2 release?

3 A No.

4 Q And then you were called back by whom?

5 A Lloyd called me back.

6 Q Okay, and he reported to you that there was a
7 release?

8 A Yes. He told me that they wanted me to come
9 into the office because there was a release.

10 Q Did you go back to the office?

11 A Yes, I did.

12 Q And what happened when you got there?

13 A I became a part of the team that, you know,
14 the ICS I guess they call it.

15 Q Had ignition occurred by that point when you
16 arrived?

17 A Yes.

18 Q Did you ever dial up your modem to get in
19 to...?

20 A I did.

21 Q Did you do it that afternoon?

22 A I may have. I don't recall specifically if I
23 did or I didn't.

24 Q So you don't recall after talking to Lloyd
25 whether you did that, or before you talked to Lloyd

1 whether you did that?

2 A I'm sure that I did, but I don't recall where
3 in the sequence that I did, whether it was before or
4 after.

5 Q Okay, but you're sure you did dial it at some
6 point?

7 A Yes.

8 Q Do you recall what you saw?

9 A No, I don't. I don't recall the session
10 specifically.

11 Q When you dial in, what do you get access to?

12 A I have access to -- it's just like being at
13 work, terminal session. I have access to the full
14 system.

15 Q Okay. In terms of not necessarily the SCATA^D
16 screens and what not you can see in the system, or can
17 you access all that, too?

18 A I can now. And I don't know when the time
19 line was that I installed the capability of being able
20 to see the SCATA^D screens.

21 Q Before or after the accident?

22 A I can't recall.

23 Q Okay, so then you went in and you became part
24 of the incident commands. Did you make any
25 notifications to any of the... or any other response?

1 A No.

2 Q Was any of that your responsibility?

3 A No.

4 Q What did you do in that structure at that
5 point in time?

6 A I just helped out wherever I could. I don't
7 have -- my official title is liaison, but there wasn't
8 a whole lot of liaisoning to do at that point, so...

9 Q Did you go to look at --

10 A I went and looked at my system. I --

11 Q Were you trying to look at -- I'm sorry. Go
12 ahead. I didn't mean to interrupt you.

13 A Checking out my system to make sure that, you
14 know, everything was working okay. I started to look
15 around to see what may have occurred with the system,
16 you know, and stuff like that.

17 Q Would this be the computer system or --

18 A Computer system.

19 Q SCATA^D system?

20 A Well, one was -- SCATA^D computers to make sure
21 that they running heathily.

22 Q Did you pull up any trends, take a look at
23 what might have happened from data?

24 A No, I didn't do any trending.

25 Q What did you find based on your review of the

1 status in the system?

2 A I didn't make any conclusion at that time. I
3 mean, other than that the system was running and it was
4 running fine at that point.

5 Q Okay, so you assessed the system as it was
6 running at the time you were there, assessing the
7 system? Is that a correct understanding?

8 A Correct.

9 Q Did you look at historical stuff to try to
10 determine what had functioned -- how the system had
11 functioned throughout the afternoon?

12 A At some point, I'm sure that I did. But, I
13 don't recall the specific line of events of that
14 period.

15 Q Do you recall what you found?

16 A What I found was that everything was fine at
17 that point in time.

18 Q Okay, let's talk about abnormal operations
19 just a little bit more. I know you defined personally
20 what you felt was abnormal operations. Obviously,
21 there's the technical definition of abnormal
22 operations.

23 Do you recall ever reporting on the outage
24 log or in any other fashion any kind of an issue with
25 valve closures, or experienced, maybe?

1 A I don't recall any specific incidents or any
2 specific report, no.

3 Q If you had been operating the system when
4 that valve closed and the line went down, would you
5 have entered that on to the outage report?

6 A The function of the outage report would be to
7 report a shutdown or more for reporting broken
8 equipment. You know, maintenance type of issues.

9 Q But, this would be a shutdown.

10 A Yes.

11 Q So you would report it, wouldn't you, on the
12 outage report?

13 A Not necessarily, no.

14 Q Okay, why would you not? I mean I guess
15 there's an outage in service; right? So that wouldn't
16 be something entered on the outage sheet report?

17 A Not necessarily, no.

18 Q And how would you make that distinction?

19 A In particular, like the baby thing there, we
20 would probably want to talk to a mechanic or David
21 Justice, or whoever, you know, directly and see if we
22 could get something going on that.

23 And, in that case, there would be an entry in
24 the outage log. If a person chose to just ignore it
25 and start things back up, then there may not be.

1 Q Would that be a good idea to ignore it and
2 start things back up, go on?

3 A From my own point of view?

4 Q Yes, I'm asking your opinion. What would you
5 do if you experienced that and you were going to start-
6 - what would be the types of things you were looking
7 for?

8 A Well, I would want to -- it would not
9 necessarily keep me from starting the line back up, but
10 I would want to make sure that people were aware that
11 it had occurred again.

12 Q So you would report it to at least your
13 supervisor?

14 A Probably, more specifically to field people.

15 Q Okay, so you would go more straight to the
16 people that would be out there trying to fix it?

17 A Uh-huh. Typically, that would be the
18 situation. And then, if you don't get any results,
19 then you elevate it to the next level.

20 Q But, you don't recall ever doing that,
21 personally?

22 A No, I don't.

23 Q Do you recall anybody else doing that, or
24 telling you they've done that?

25 A I don't have any knowledge of that.

1 Q In any of the conversations you had with
2 anybody else, did they indicate they had done that?

3 A I don't have a specific recollection, but I
4 know that they were aware of it. I don't know how they
5 were aware of it specifically but I know they were
6 aware of it.

7 Q It sounds like it was a topic of
8 conversation.

9 A It was a topic of conversation.

10 Q So I'm just trying to understand the sense of
11 frustration that people were experiencing.

12 A It was such a topic of conversation that it's
13 really hard to remember any specific conversation about
14 it.

15 Q So there was volume and you're kind of having
16 a hard time picking out those specific details.

17 Have you looked at the event log from June
18 10th? This is obviously since after the accident, not
19 before.

20 A Yes, I've been over that.

21 Q As far as your duties in preparing responses
22 and what not, have you gone through in detail and had
23 an opportunity to look at it?

24 A Yes, I have.

25 Q Did you draw any conclusions from reviewing

1 the event log?

2 A No.

3 Q So you have no personal opinions as to what
4 might have happened in this event sequence?

5 A My personal opinion, yes.

6 Q What might that be?

7 A My personal opinion is that there was a
8 problem with the computer system. We went from one
9 computer to the other computer and back.

10 The communications problems were caused more
11 by -- in fact, communications problems, they were
12 caused more by the sequencing of the computers when
13 they went down and came back up.

14 That's about the only conclusions that I've
15 been able to make on it.

16 Q Okay, by "communications problem", you're
17 talking about when the system started back up, there
18 was a whole series of communication alarms that came
19 back on?

20 A When they went from No. 2 to No. 1 and then
21 they went back to No. 2, there was a massive
22 communications outage, which was caused by the No. 2
23 computer coming back up. Not because there was a
24 communications issue.

25 Q Have you reviewed the event log that went on

1 through that sequence of events then and included the
2 time when the pipeline was restored?

3 A I've been through the whole sequence, line by
4 line.

5 Q And did you draw any opinions as to that
6 event?

7 A I have no opinion.

8 Q You have no opinion as to whether or not the
9 lines should have been restored?

10 A With hindsight? No, I'm not going to go back
11 to hindsight and make an opinion on that until all the
12 facts are in.

13 I don't know what went on in the control
14 center. I don't know what they saw in the control
15 center. So I can't have an opinion on that right now.

16 Q Based on your review of the event log, I mean
17 you obviously, you're an experienced control and you've
18 obviously had an opportunity to review this event log.

19 I'm just wondering if there was something in
20 there that, you know. It seems like you would have
21 some conclusion as to whether or not that line should
22 have been restored.

23 I'm just asking you to share that with us.
24 In your personal opinion as a controller for thirteen
25 years or whatever.

1 A Like I said, having not been in the control
2 center, you can't just go and look at these lists of
3 events and come up with a conclusion. You need to have
4 the full scope of the picture.

5 In my particular case, what I would do before
6 I were to start the line up is I would want to do a
7 complete review of the event history, my review
8 trending and those types of things.

9 At that point, you have to decide, you know,
10 what caused the pipeline to shut down -- was it high
11 pressure? Was it low suction? Many, many issues.

12 So looking at it, I cannot sit here and tell
13 you that starting up the pipeline was the wrong thing
14 to do at the time.

15 Q Doesn't the event log give you some
16 indication of why things shut down in terms of
17 pressures, suction pressures, discharge pressures? Can
18 you get a picture?

19 A Sure. The way that the eventing is done in
20 our SCA^DA system is there are two files. One is the
21 long-term file and it's on disk. And the other is a
22 continuous -- there are 10,000 events and it's
23 contained in memory on the primary machine.

24 When an event occurs, the message is written
25 to the following memory. The same message is written

1 on to disk.

2 What we are looking at with these is the
3 long-term disk file. What they are seeing in the
4 control center is what was held in memory, a completely
5 separate file.

6 The way that those computers run up and down,
7 you cannot guarantee that what they saw in the control
8 center is what is on that file.

9 Q Can you tell from your review of whatever you
10 reviewed whether anybody did any trending before
11 restarting?

12 A I have no way to know that.

13 Q Okay, so they could have done that. You
14 don't know whether or not they did it.

15 A No, I do not.

16 Q Have you reviewed trends of the data taken
17 during that event?

18 A I have looked at trends. The problem though
19 is that because of the way that the computers were
20 failed over, you would only -- the event occurred while
21 they were on the No. 1 machine, which was the backup
22 machine.

23 So they went from No. 2 to No. 1 back to No.
24 2. Anything that happened on No. 1 was not available
25 after the incident for them to see.

1 Q No. 1 being the one that was operating--

2 A The one that was operating when the release
3 occurred.

4 Q Why would they not be able to see that
5 information?

6 A Because the information is only available
7 from the primary machine.

8 Q Based on -- all right -- the trends that were
9 pulled up?

10 A Right, because under normal operations, the
11 information is being shadowed over the backup computer.
12 But, if I shut this computer off here, the backing up
13 stops. And when this guy gets started back up,
14 normally, they'll be synchronized and be back up
15 together.

16 But, in the situation, what we had here, this
17 computer was -- the primary computer was just shut off.
18 The No. 1 computer takes up. He's got the data because
19 it's been shadowing it over. Okay?

20 But, now No. 2 is started back up. It comes
21 up thinking it's primary, which causes that massive
22 communications outage. Well, it came up with the same
23 information that it had when it went down. It came up
24 stupid as far as what was going on while it was down.

25 Q How long did it take to synchronize data?

1 A Under this situation, it never would have
2 synchronized the data because that's a function of the
3 startup. It would, in fact, start writing over data on
4 the next -- on the No. 1 machine. The primary always
5 writes to the backup.

6 Q Okay, but the data that was produced to us,
7 how was that derived then if this data was --

8 A That was derived from the long-term event
9 disk files. They're actually -- what you've got is two
10 sets of documents. You've got the stuff from ~~OLEO-2~~^{OLY#2}
11 and the stuff from 01. And, you know, since then the
12 pages may have been merged but they are actually the
13 files from two separate machines.

14 Q Okay, in the event log they're separate.
15 What about in the trends?

16 A The trends, same story. Each machine has a
17 historical file for that day. And what you would do,
18 if you start a machine up, you have the option of doing
19 a file transfer or not. If you don't, it doesn't make
20 any difference because it's going to synch itself up.

21 But, in this particular situation, because of
22 the way they were shut down and then restarted, the
23 information was not there. You can look at those
24 trends and you can see where the one machine has the
25 data that was missing from the other machine.

1 Q And that's shown in the trends that you guys
2 provided to us?

3 A Yes.

4 Q I guess the point as far as the event summary
5 goes, if you want to have a better idea of what they
6 might have known in the control center, you take out
7 the ~~OLEO-1~~^{oly 01} stuff and look at the events without that.

8 Q And that applies to both the event log and
9 the trending charts that you're providing?

10 A Yes.

11 Q Why don't we just run through that exercise.
12 Bear with me and I'll try to find some...

13 (A pause.)

14 All right, what I'm going to do is I've got
15 page one through -- this is pages one through three as
16 originally provided by... and pages 46 through 61.

17 I think I'm going to go ahead and enter this
18 as an exhibit, those pages. But this is excerpts I
19 guess from the event log that were provided by Olympic.
20 And I'll just go ahead and give that -- ignore the
21 yellow highlight on there. I did that, and a very long
22 time ago. I should make another copy.

23 If you look through there, the first three
24 pages is from which computer?

25 A This would be ~~OLEO-1~~^{oly 01}, I believe, the backup

1 computer, the event, the thing started.

2 Q You're saying that the operators would not
3 have seen that information on the day of the accident?

4 A My belief is that they would have seen this
5 as it was occurring because, as I said, one is placed
6 into memory, which is what is displayed on the screens,
7 and a duplicate message is put on the long-term disk
8 file.

9 So, therefore, this would have been available
10 as it was occurring but not necessarily after the
11 system had straightened back up and had gone back to
12 the No. 2 machine.

13 Q Okay, so then the rest of those pages, if you
14 could just look through those then?

15 A This is taken out of context. It would be
16 better if you had the whole set.

17 Q Those three pages fit into the time frame.
18 The other pages are a few pages back.

19 A Right. Now this definitely was the secondary
20 computer, or ~~OLEO~~^{OLY}-1.

21 Q I don't know what time that says. What's the
22 first time entry on that fourth page?

23 A It's 1310.

24 Q Which was?

25 A On June 10.

1 INVESTIGATOR BESHORE: Peter, did you have a
2 question?

3 MR. KATCHMARE: Do you need the other pages?

4 INVESTIGATOR BESHORE: Do you need the other
5 pages?

6 MR. SMITH: Well, the full set would be
7 better if you're going to enter it into the record.

8 INVESTIGATOR BESHORE: Well, it's in the
9 record but I mean in terms of our discussion with you,
10 that's just a few.

11 MR. KATCHMARE: It's front and back. But I
12 think it starts on page 52, and that's where it goes,
13 back to --

14 INVESTIGATOR BESHORE: Yes, let's go off the
15 record.

16 (Record paused.)

17 BY MR. BESHORE:

18 Q Todd, you've had an opportunity to review the
19 event log and now you're clear on what I've provided
20 there with the event summary?

21 A Yes.

22 Q How that fits together?

23 A Uh-huh.

24 Q Maybe you could just kind of explain that to
25 us.

1 A Well, the general flow was that we started
2 ~~OLEO-2~~^{OLY #2}. And at sometime around 1524 or so,
3 we failed over to ~~OLEO-1~~^{OLY #1}. And then at approximately
4 1544, we started the No. 2 machine back up.

5 What we have here is an excerpt of the total
6 long-term archive of event history for both computers.

7 Q Okay.

8 A Okay?

9 Q The first three pages are from which one?
10 I'm sorry.

11 A The first three pages are from ~~OLEO-1~~^{OLY #1}. And
12 they begin at 1527, 47 and continue -- the last entry
13 is at 1534.17.

14 Q Okay, so there's a short gap in the data --

15 A Which could be the clocks weren't typically
16 kept right, you know, together. There could be a four
17 or five minutes difference in the time on the two
18 systems.

19 Q Oh, so the clocks didn't automatically synch
20 together on these systems similar to the data?

21 A Not on June 10, no. I mean not at that time.

22 Q They do now?

23 A They do now.

24 Q All right, and then there's a longer gap as
25 it's failing back over. So let's see. If there's a

1 time discrepancy, then either the first gap could be
2 shorter and the second gap longer or vice-versa.

3 Would that be correct?

4 A Well, depending on the way that this machine
5 was shut down, it could have an impact on why there is
6 a time discrepancy here.

7 For example, if they had tried to do a normal
8 shutdown of the computer, it will shut off processes.
9 And the event processes that were shut down while
10 trying to attempt a normal shutdown of the system, you
11 know, that's the only way that I can explain it.

12 Q Do you know if that's what Lloyd did?

13 A I do not know that.

14 Q Okay, so that wasn't part of the
15 conversation?

16 A Well, the normal routine would be to try to
17 do a sequential shutdown of a normal shutdown of the
18 system. And then, if that fails, then to do a reset
19 button on the hardware.

20 Q So, based on what you were telling us before
21 then, your understanding is that what those first three
22 pages that were on the ^{OLY 01}~~OLEO-1~~, the middle of this
23 event, you feel like they probably were able to see on
24 the screen but they have to pull that up later?

25 A This information would not be available to

1 them. This is something that I would have to get for
2 them.

3 Q Okay, so even if they're on their own
4 machine, for example, can they pull up on their own
5 machine a listing of the events that have occurred up
6 to that point?

7 A Under normal operations, they can review the
8 last 10,000 events on the system. And under normal
9 operations, that is shadowed back and forth.

10 But, it could happen. And I believe it very
11 likely did happen because the historical stuff shows
12 this, that the shadowing didn't occur when the second
13 machine, when No. 2 came back on after the incident.
14 It probably didn't come up with the data that was
15 available from ^{OLY 1}OLEO-1.

16 Q So your belief is that the controller would
17 just see the information from the ^{OLY 2}OLEO-2 computer with
18 just a gap from -- what did you say? -- 1524 to 1548?

19 A Correct.

20 Q And then you talked about a communications
21 alarm. Did you find those?

22 A Yes, they began right when the No. 2 machine
23 was restarted, I believe at 1544.

24 Q What page is that on?

25 A It's on page 52. That's near the top of the

1 page. Actually, this shows both events. This shows it
2 going off line the first time and then coming back on.
3 And then going off line at 1524.53 and then coming back
4 on line at 1544.30.

5 Q Okay. And then there's a whole nontechnical
6 term, a whole slew of communication errors.

7 A Yes.

8 Q And you're saying that's the result of the
9 computer coming back on line?

10 A Right. The way the communications are set up
11 is they come through modems, through a terminal server.
12 And there's only one terminal server. And both
13 computers are looking at the same terminal server.

14 But, as long as the primary has -- well, as
15 long as the primary is the primary computer, the backup
16 isn't trying to get access to those terminal servers.

17 So everything is fine.

18 On a normal fail-over, the scanning process
19 on the primary machine will stop and the scanning
20 process on the backup machine will start. And then it
21 just starts getting data.

22 This indicates that when the number two
23 machine was brought back on line, that it thought that
24 it was the primary. So it came up in a co-primary
25 situation and then there was a struggle between the two

1 machines over who was going to have access to those
2 terminal servers.

3 And the SCA^DA system doesn't know anything
4 about terminal servers. It just asks for a message
5 from the field. And if it doesn't come back, then it
6 sees it as a communications failure.

7 Q All right, so let's just go down there and
8 see what's the next event that happens in the event log
9 aside from the communications.

10 A After the startup?

11 Q After the restart.

12 A Okay. After -- the next significant one is
13 it shows the high control pressure at Allen returned to
14 within normal bounds. And that's actually, in fact,
15 highlighted here.

16 Q Can you tell from the event log the status of
17 the other facilities on the system?

18 A Not at the point in time. You could read
19 down through it and deduce what the status was
20 previously, you know, as you looked at things.

21 Q That's going to show up on your screen on the
22 system, right?

23 A Anything -- yes, right. Any of these things
24 should be available, you know, as it's occurring. As
25 it is occurring, because the one message, the message

1 is put into the memory file, which is what is displayed
2 on the screen. And a duplicate is put on the disk
3 file.

4 Q I'm trying to remember what it all says.

5 (Perusing documents.)

6 All right, you feel like if somebody pulled
7 up, they could have pulled up the information off of
8 this -- the No. 2 computer? I'm sorry. I've lost my
9 train of thought.

10 If we could go here, there's one highlighted
11 on the next -- and that's page 52. Right? And that
12 talks about the Bay View valve... into the station?

13 A The high-pressure alarm? The highlighted?
14 Right.

15 Q And the Bay View valve begins to travel?

16 A The receiver end. That's what you were
17 calling a block valve.

18 Q Okay, so based on your theory -- or I'm not
19 slighting --

20 A That's all right.

21 Q Based on your belief, then the controller
22 would have been able to access that information. You
23 would have known that that MI valve closed?

24 A Yes, he very possibly would have -- this
25 would have been available. Without actually seeing the

1 memory file, it's hard to say, you know, exactly what
2 they could have seen.

3 But, there's no reason to believe that they
4 wouldn't, that this would not be seen.

5 Q All right, now you've confused me a little
6 bit. Without seeing the memory file? Is that another?

7 A There are two files.

8 Q That's the file that's --

9 A -- displayed on the screen.

10 Q -- displayed that's... but we don't have
11 now?

12 A Right.

13 Q All right. And would it be reasonable to
14 assume if he saw that, that that's what shut down
15 everything else? That's why he couldn't see something
16 going on?

17 A What do you mean shut down everything else?
18 The whole system?

19 Q Right. My understanding is that all the
20 pumps were down, all this, and the computer booted back
21 up. Is that incorrect?

22 A I don't know what they -- no, as a matter of
23 fact, that's not true because in going through this, I
24 believe that the Woodinville No. 1 unit was still
25 running when the No. 2 system came back up.

1 Q All right, but it's your understanding all
2 the other pumps have shut down some length of time?

3 A Yes.

4 Q Would it be reasonable as a controller to
5 assume that if you saw that event, that that's what had
6 happened to the rest of your system in that gap of
7 time?

8 A A person could deduce that the system shut
9 down on high pressure, yes.

10 Q What other assumptions would pop to mind
11 when, all of a sudden, a guy can see all this
12 information again?

13 A Well, again, you would want to review the
14 entire scenario. But, it would not be unreasonable to
15 assume that the station shut down on high pressure.
16 Because, if you go through the event, that's basically
17 what is going on from the beginning of this thing.
18 Look at the entries here of the surge, the flow
19 indication at Bay View would indicate high pressure.

20 You've got high-pressure indications from
21 Allen's 16-inch station. You've got pumps shutting off
22 at Bay View and Allen on high pressure.

23 You've got high pressure upstream of
24 Ferndale. And then you fail over to the other computer
25 and you don't see anything until No. 2 computer comes

1 back up.

2 And the next thing you see is all those
3 things returning to normal with the Woodinville unit
4 continuing to run.

5 It would not be unreasonable to think that
6 the station facilities had shut themselves down with
7 their protective devices.

8 Q And all that information you just read out
9 was off the event log for the ^{OLYDQ}~~OLEO-2~~ computer that you
10 believe they could have accessed?

11 A Yes.

12 Q Now based on that knowledge then, Mr. Smith
13 is controlling the system. What do you do now based on
14 that? You know, the computer comes back up and that's
15 what you see. This is the information you have to go
16 on.

17 Let's assume you don't have those first three
18 pages. Now what do you do next? What's your next
19 step?

20 A Well, this looks to me like everything on the
21 pipeline operated the way that it was supposed to. In
22 other words, it protected itself from high pressure.
23 Everything appears to have shut itself down.

24 I don't see any indication of over-pressure
25 of, you know, beyond the switch, that is.

1 The pipeline has been severely bled down
2 because the Woodinville unit continued to run through
3 this whole thing.

4 So my next step would be to probably get Mr.
5 Brenson involved. Certainly, I'd review everything
6 that I could. And then, if I were to do anything at
7 that point, it would be to repressure the pipeline at a
8 slow rate.

9 Q Okay. Now you mentioned pressures. Is there
10 some indication on the Bay View station of pressure...
11 or is that just on the first three pages?

12 A Do you mean when the system came back up?
13 Well, there are all kinds of pressure indications. No,
14 excluding the first three pages.

15 Q You mentioned that there was no indication of
16 the high pressure in --

17 A Well, there is only indications of high
18 pressure. There are no indications of low pressures.

19 Q Are they pressures to the extent they would
20 cause you a concern about excessively high pressures,
21 for example?

22 A The fact that they alarmed would be an
23 indication that some action would be required. You've
24 reached a maximum operating limit, or something like
25 that.

1 Some of them -- for example, here at 1518.22,
2 you have an alarm from Allen that says 1440, discharge
3 pressure 1444. Typically, our maximum operating
4 pressure would be 1440, so this would be an indication
5 that you have exceeded that and that some action should
6 be taken to control that pressure.

7 Q Is that something that would exceed some
8 reporting requirement that you need to record as an
9 abnormal condition? Is that a surge indication, for
10 example, that --

11 A No, this could be the result of starting a
12 pump, you know, and having it momentarily, you know,
13 overrun the control valve. You know, just typical
14 operations.

15 You know, we run a very tight system
16 pressure-wise. There are many things that can cause a
17 high discharge pressure. For example, a unit shutting
18 off downstream could cause a surge that could come back
19 again, flow through the station faster than a control
20 valve could react to control that.

21 Q I guess I'm asking, if the pressure exceeds
22 your MOP is there some mechanism you need to do to
23 your--

24 A Well, I'm not saying that 1444 is the MOP.
25 I'm just saying that this is the threshold at which

1 they say you need to take action, you know.

2 Q Okay, that's your set point.

3 A The set point.

4 Q Not necessarily bringing it to a maximum.

5 A Right. Right. My understanding is that,
6 unless you exceed 110 percent of the -- is it MOP or
7 MAOP, that's a report of...

8 Typically, to have a station shut down a unit
9 in a high-pressure situation or a low suction situation
10 is not a reportable incident.

11 Q And you mentioned trending, one of the things
12 you would do to be looking at trending. And I gave you
13 a book of some trends that you guys had provided to us
14 previously.

15 Yes, let's just talk about it.

16 MR. MARTIN: Let's just break for one second
17 while I go tell Lloyd...

18 INVESTIGATOR BESHORE: Right.

19 (Record paused.)

20 INVESTIGATOR BESHORE: And, I had given you a
21 book of some trends that you had provided, your company
22 has provided to us. And you mentioned that you might
23 have part development of some of those.

24 Did you have a chance to look through there?

25 MR. SMITH: Yes.

1 BY MR. BESHORE:

2 Q And is there one in particular that you
3 identified as exemplifying what you were talking about
4 in terms of gaps in the data?

5 A Yes. I think this repeats them very well.

6 INVESTIGATOR BESHORE: And for everybody's
7 benefit, this is page 318, originally provided.

8 I'll mark that as Exhibit No. 4.

9 (Whereupon, the previously-
10 identified document, marked as
11 Exhibit T. Smith 4 for
12 identification, was received
13 into evidence.)

14 BY MR. SCHAU:

15 Q Can you tell me what that indicates to you,
16 Todd?

17 A Yes. This is a pressure trend showing Cherry
18 Point, Ferndale discharge pressures. And the Bay
19 View -- a pressure transferring on Bay View 1901.
20 Without a drawing, I can't tell you exactly which that
21 is. Somebody had a note down here:

22 "Bay View discharge..."

23 Q Does it say 1901?

24 A 1901. I'm thinking it's the incoming
25 pressure. Somebody has a note here that says

1 "discharge".

2 Q Ignore the notations. They were made a year
3 ago. Would that be shown on the flow diagram here?

4 A It's not indicated here. It just mainly
5 looks like a...

6 Q Yes, that's a problem. I don't have another
7 drawing that would indicate where the transmitters--

8 A I think that 1901 is the incoming pressure.

9 Q That would be upstream?

10 A Upstream of the receiver.

11 Q Okay.

12 A But the point that I wanted to show is that
13 it's very difficult to see and if you look very closely
14 in these areas here, that that line is actually black.

15 Q By that area, you mean sometime between --
16 oh, okay, you see all three lines go to black. Is that
17 what you're saying?

18 A Yes.

19 Q That's in a time frame between 15, 17 and
20 1602? I'm assuming those are times?

21 A Yes, probably closer to 1525, 1530 and 1602,
22 1545, about the time of the incident.

23 Q And all three of those black lines basically
24 are just flat straight across?

25 A Right.

1 Q All right, what does that indicate?

2 A It shows that there was no data available at
3 that time?

4 And the other thing is that if you look up
5 here in the corner, it very dimly tells you which
6 machine... this is ~~OLEO-2~~^{OLYØ2}.

7 Q All right, so this is only information that
8 was coming off of ~~OLEO-2~~^{OLYØ2}?

9 A Correct.

10 Q Now is this clock number on here going to be
11 the same as the time set on ~~OLEO-2~~^{OLYØ2} to match the event
12 log summary?

13 A It should be, yes. This one should be the
14 same thing. Well, no, because this is the time that
15 this trend was actually produced on 10th of June at
16 1875.

17 Q Okay, I follow you. All right, so --

18 A This is the time. Down here is the time
19 line. The pressure values and the point in time on
20 June 10, 1999.

21 Q Okay, so this trend was generated on June 10,
22 1999 at 1818 and, roughly, and it shows the preceding
23 three hours?

24 A Yes.

25 Q All right, but my question was then the times

1 down here at the bottom that are shown across the
2 bottom time scale, are those times going to be
3 accurate?

4 A They should be.

5 Q Comparable to the event summary?

6 A Yes, they should correspond with events
7 summary.

8 Q The event summary from ^{OLY 2}~~OLEO 2~~ you mentioned?

9 A Yes, because this is off of the ^{OLY 2}~~OLEO 2~~
10 machine. The events are the disk file off of ^{OLY 2}~~OLEO 2~~.

11 Q So they're basically coming off the same --

12 A Same sheet.

13 Q -- of data. All right, so let's go back then
14 after that gap in time frame. Oh, I'm sorry. This is
15 actually going to be Exhibit 5. I'll label the
16 excerpts from the event log as Exhibit 4.

17 So this is going to be Exhibit 5.

18 (Whereupon, the previously-
19 identified document, marked as
20 Exhibit T. Smith 5 for
21 identification, was received
22 into the record.)

23 BY MR. BESHORE:

24 Q What's the significance of the Woodinville
25 across the bottom?

1 A The bottom two lines, those are the RTU tags.
2 Whenever there is an alarm from a facility, it's
3 displayed on the alarm event. The page is also
4 displayed on the alarm file.

5 And then the RTU tag is posted down at the
6 bottom of each screen... but you're going to have a
7 problem with that in that particular facility.

8 Q Okay, so this trend was actually pulled up on
9 a screen and it went "print screen"?

10 A Right. And there was, apparently, some alarm
11 activity in Woodinville when this was produced. So
12 that would not have anything to do with events on June
13 10th.

14 Q What was the significance then, what would it
15 tell you then from once this data started returning?
16 You had the pressures were not the same as the
17 pressures to start with.

18 Does that tell you anything?

19 A Well, if you were walking in the room and
20 just were going to do a review of the pressures and you
21 didn't look really close, you would see that, well,
22 there was no real rise in pressure here. It just, you
23 know, kind of went up and leveled off and everything
24 was kind of shut off.

25 It doesn't really show you the true picture

1 of what was going on, on the system.

2 The other thing is this is from only one at
3 the same period. And if you superimpose these, you can
4 see that this spike fills in that space there.

5 This would not be available to them on line.

6 INVESTIGATOR BESHORE: All right, and this is
7 going to be Exhibit No. 6. And this is identified as
8 page 3-1-8-A as originally provided to us from Olympic.

9 And there's a 30-minute trend prior to 1545
10 on June 10.

11 (Whereupon, the previously-
12 identified document, marked as
13 Exhibit T. Smith 6 for
14 identification, was received
15 into record.)

16 MR. SMITH: Right. And if you look very
17 close on this one, you can see the same black line
18 here, this area right here. And for some reason, there
19 was no data from that point.

20 BY INVESTIGATOR BESHORE:

21 Q All right, and that's beginning the upswing
22 on the red line spike, as you can see depicted there.
23 There's a little flat black portion rather than a
24 straight continuing rise.

25 A The point to all this is that you asked me

1 what is my opinion. You know, looking back on the
2 incident and the point of bringing this all out is that
3 walking into the control center, this is not available
4 to me. This is what I see.

5 I don't have all the information so,
6 therefore, it's really hard for me without a lot of
7 hindsight to go and formulate an opinion of what was
8 the right thing or the wrong thing to do at that time.

9 INVESTIGATOR BESHORE: All right, this will
10 be Exhibit 6. I think I identified it as 3-18-A. Let
11 me go ahead and mark those.

12 Okay, can I see back that book, if I could?

13 (A pause.)

14 BY INVESTIGATOR BESHORE:

15 Q Okay. What other data would be available,
16 assuming you just had this information... you saw a gap
17 in this data, and you're wondering what happened to
18 your line sight... you know, what other data might be
19 available to you that you can go and look at, if you're
20 still uncomfortable, you don't understand what's
21 happening?

22 A Well, as far as the gap goes, because I don't
23 know how things -- I'm, you know, currently head
24 operations controller right now. And I don't know how
25 things work underneath the sheets on the SCADA^D system.

1 I would have no reason to suspect that I
2 didn't have everything available to me through the
3 whole sequence of events.

4 So, in the first place, I would possibly be
5 misled into believing that that is all the information
6 that is available for the trends and for the alarms and
7 for the nets.

8 That is about all of the information that is
9 available. Plus, on top of that, there's the valves
10 that, when the pipeline is designed, it is designed,
11 you know, to be self-protecting.

12 You know, first, there were pipelines and
13 then eventually automation and then SCADA^D came sometime
14 after that. In every pipeline facility that we have at
15 Olympic anyway it is designed to be self-protecting.
16 It has pressure switches that are designed to shut
17 facilities down and, you know, close them in at levels
18 far below the ratings for those systems.

19 So, knowing that, you know, one would assume
20 that -- very reasonably -- that the facilities did what
21 they were supposed to do and protected themselves and
22 shut down.

23 Q Can you tell anything from static pressures
24 out there that you're seeing? Because you could look
25 at real time pressures.

1 A Right. But, at that point, as you remember,
2 Woodinville No. 1 had continued to run through this
3 whole thing and basically pulled the line down to way
4 below the elevations of the hills.

5 It was completely -- it would be a totally
6 void system at that point.

7 Q Okay, so you know you're not full of product
8 so your elevation head pressures are not going to look
9 the same as you might expect for a line full?

10 A Right.

11 Q Given the various changes.

12 A Right. Now, if you didn't have that
13 scenario, if the system came up and you saw that all
14 the pumps were shut down, that might be different.

15 But, in this particular situation, having
16 that pump continue to run would lead you to believe
17 that that's why there's no pressure in the line,
18 because this pump, you know, continued to pump it all
19 out.

20 Q Could you tell how long that pump had run?

21 A It had been on from -- looking at the events,
22 it was on before this sequence started. And it was
23 shut off -- I wanted to find the exact time, if I could
24 just take a minute to look through here.

25 Q Certainly.

1 (Perusing documents.)

2 A Do you see it?

3 Q It's ^{OLYØ1} ~~OLEO-1~~-1530.

4 A Right, there is where it was transmitted. It
5 never shows indication of the actual shutdown though.
6 There it is at 1531, yeah.

7 Q Okay, so that was a command issued by the
8 control center; correct?

9 A Right.

10 Q In other words, controller action shut down
11 at Woodinville at 1530?

12 A Right.

13 Q Which was?

14 A While it was on ^{OLYØ1} ~~OLEO-1~~.

15 Q While it was on ^{OLYØ1} ~~OLEO-1~~.

16 So, if some command came back or something
17 came back that said the pump had to be checked out, it
18 may have come back during that gap.

19 A It could have, but the point is that the unit
20 continued to run and that that would be a justification
21 for why that system --

22 Q Actually, how long would it have to run to, I
23 mean, we're just talking a couple of minutes
24 potentially?

25 A I don't know. I probably could study that.

1 An engineer could probably tell you what that would
2 take.

3 Q I mean, obviously, the longer it runs, the
4 more we're getting into the scenario. I'm just trying
5 to get, you know, how long is a long time.

6 A Right.

7 Q Is just a couple of minutes going to cause
8 the effect you're --

9 A Right, but if this is on ^{OLEO-1}~~OLEO-1~~ and I can't
10 go back and see what time it shut down and you ask me,
11 well, how long did it run, I might not be off the top
12 of my head able to say, you know, this is how long it
13 ran.

14 All I know is that it was running when, you
15 know, when the... light went on.

16 Q Okay, let me use hindsight because that's
17 part of our role here. What additional information
18 could be provided to the controllers to help them in
19 this particular scenario make these decisions?

20 A In the control center, all that there is is
21 what you can see right now, what you observed as you
22 were going through the events, what you can display in
23 the event history and what you can trend in the
24 pressure history.

25 Outside of the control center, if you have

1 people in the field, you could maybe ask them what
2 they're seeing on their trends. You know, what the
3 condition of their facilities are.

4 Q So do you have manned facilities you could
5 contact people on?

6 A Our facilities aren't normally manned. I'm
7 just thinking if per chance someone were at the
8 facility.

9 Q Do you know whether or not there were patrol
10 pilots out flying at the time from the control center?
11 Are you guys informed of those patrols?

12 A Not typically, no.

13 Q So you wouldn't know if there was a pilot out
14 there or not?

15 A No. No.

16 Q Okay, based on hindsight again, you're
17 looking back at the day, would you have done anything
18 differently?

19 A Well, with hindsight, there are other things
20 that could be done. You could have assumed the worst,
21 I suppose. Called people out, walked the line. Flown
22 the line. You know, things like that.

23 Q But, you did mention for certain that you
24 would end up getting Mr. Brenson involved before you
25 started the line.

1 Is that a correct understanding?

2 A Yes, I'm sure that I would because this is a
3 major event.

4 Q The loss of the computer, would that be
5 considered an abnormal operation in terms of your going
6 into the manual?

7 A Yes. Oh, in terms of the manual? It
8 doesn't, or it didn't at the time really address
9 communication or, you know, that type of an incident.
10 It did address communications but not computer outages.

11 Q It does now?

12 A Yes, it does now.

13 Q Have you ever experienced any computer
14 downtime or anything similar to that in your
15 operational history of the controls?

16 A Nothing ever like this, no.

17 Q Do you -- is there any guidance provided on
18 when you use the drag-reducing agent? Or when you
19 don't use the drag-reducing agent?

20 A The only hard thing about drag-reducing is
21 what the maximum haggard hit ppm is. It's up to the
22 dispatcher's discretion to decide when to inject it and
23 what volumes at the end of the drill locations.

24 Q And they do that based on the pressure
25 profile they're seeing?

1 A Based on the pressure profile they're seeing
2 now and the anticipated activity in the future.

3 Q If you were swinging from Renton to Seattle,
4 would there be a reason to inject in the drag-reducing
5 agent? Would that be something you would do?

6 A It would depend on the profile just prior to
7 that. If I were going to -- allowed to do rates higher
8 than what is capable without DRA, then I would probably
9 want to even add more DRA. Maybe, switch from putting
10 it in at Allen to putting more in at Woodinville, for
11 example, to try and move the pressure profile down,
12 downstream.

13 Q Is that a general, or do you just use that
14 only when you need to use that?

15 A DRA? Yes.

16 Q Because of cost?

17 A We use DRA to increase throughput.

18 Q So, as long as you can meet your throughput
19 requirements without it, you don't use it? Is that
20 fair?

21 A That's fair. But, we try to anticipate
22 future events because it takes -- in order for DRA to
23 work, you have to preload. You may have to preload
24 those lists, the system with it, so that when it comes
25 to the point where you need to have the rates, that

1 you've got the DRA in the right segment at that point
2 in time.

3 So there is some preloading of DRA.

4 Q When you quit injecting in DRA, would you see
5 any kind of a reaction?

6 A When you stop it?

7 Q Yes.

8 A Sure. You'll see an increase of pressure at
9 points upstream of the injection and corresponding
10 decrease downstream. And you can see almost
11 immediately.

12 Q Does it happen fairly quickly?

13 A Right, but there's a slope to it.

14 Q And let me see if I understand you. So you
15 see the pressure increase at points upstream?

16 A Right.

17 Q And decrease at points on downstream with the
18 injection?

19 A Right, as the friction increases.

20 Q So your profile basically becomes more
21 pronounced --

22 A Steep.

23 Q Or more steep.

24 A Uh-huh.

25 Q Okay. When did Frank ^{Hopf} ~~Huff~~ get there? Do you

1 recall?

2 A That day?

3 Q Oh, no. I'm sorry.

4 A Or in his career?

5 Q In his career. When did Frank become general
6 manager there?

7 A He came with Shell, I believe. I don't know
8 what the year was when that occurred.

9 Q Had he been there several years?

10 A Yes. He was with Shell. Then --

11 A More than five?

12 A Yes. He was with Shell and then went with
13 Texaco and then continued with Equilon.

14 Q I may have asked this. How was Ron to work
15 for -- Ron Bren^hson?

16 A Ron Bren^hson? He was good to work for. He
17 was fair.

18 Q Was he receptive to ideas from people?

19 A Yes.

20 Q Was he the kind of guy that as long as there
21 wasn't any problems, you know, could handle it kind of
22 a guy? Or was he more hands -- I guess I'm trying to
23 get a little more of a feel for his management style.

24 A I wouldn't say that he was a -- did any kind
25 of micromanaging. He was receptive to ideas. Always

1 there to help, you know. He'd be the first to throw on
2 the boots and jump in the mud, you know, if that would
3 help the operation.

4 Very hard-working person. Very fair, I
5 thought. I think that he listened to people when they
6 had concerns.

7 Q Was he knowledgeable?

8 A Very knowledgeable.

9 Q Do you think when you guys had all your --
10 I'm characterizing -- this general concern about
11 operational issues, do you think Ron probably
12 represented that strongly to the other parties, that,
13 "Hey, this is a problem. These things need to be
14 resolved"?

15 A I would suppose so. I think that he shared
16 the same concerns of these types of issues. Certainly,
17 because they affected operations, to resolve them would
18 have, you know, smoothed the operation considerably.

19 Q So you think he would stand up for the cause?

20 A I think that he would work to resolve the
21 issue.

22 Q How was morale?

23 A Morale has been up and down. With Bay View,
24 it was probably mostly down, I think.

25 Q Because of frustrations people had?

1 A I think that it increased the level of work
2 in the control center. And then of course there was a
3 level of frustration with getting it on line,
4 understanding how it was supposed to work, things like
5 that.

6 Q Was there a general sense of frustration that
7 things weren't being taken care of quick enough?

8 A I think you could say that.

9 Q All right, did you have any knowledge of
10 intelligent pig runs, or smart pig runs that were
11 conducted in the last few years on Olympic pipeline?

12 A I know only that they had done them.

13 Q And you just knew they'd done them because
14 you guys were informed as controllers that that was
15 happening?

16 A That would be the case, right, because it
17 would require special operations.

18 Q Or just they're checked, I guess?

19 A Well, it was basically I think a new
20 technology for us.

21 Q You have any results of any of those
22 inspections?

23 A I don't know the details.

24 Q Do you have any reason to be involved in
25 evaluation, explanations?

1 A No.

2 Q How about had you ever been to the Bellingham
3 water treatment plant?

4 A Never.

5 Q Have you since the accident?

6 A No.

7 Q But, you'd heard of the plant?

8 A Yes, I've heard about the plant.

9 Q Prior to the accident?

10 A Prior to the accident.

11 Q Were you aware of any excavation activities
12 that were done in the past through there, just in that
13 area?

14 A No, I've only heard stories of the
15 relationship between Olympic pipeline and the water
16 treatment plant.

17 Q What was that? What were the stories, I
18 guess?

19 A Well, the one story is that the line was laid
20 through there. And we hadn't been there for more than,
21 you know, just a very short time. And the water
22 department said, "Oh, guess what? You guys need to
23 move your line. We're going to expand our facility
24 here."

25 And the general feeling was that, well, they

1 should have known that prior to the pipeline
2 construction when the pipeline could have been rerouted
3 at that time.

4 Q Is that the only thing that comes to mind
5 when you're talking about the water treatment plant?

6 A Yes.

7 Q Do you remember who told you these stories?

8 A No, they're just old folklore.

9 Q Okay, pipeline stories.

10 A Folklore.

11 INVESTIGATOR BESHORE: All right. I think
12 that I'm going to go ahead and ask Cliff if he has any
13 questions he can follow up on. Cliff?

14 MR. ZIMMERMAN: Good morning, Tod.

15 MR. SMITH: Hi.

16 MR. ZIMMERMAN: What's left of it.

17 I'd like to ask you a few questions about a
18 number of different subjects, so we're going to jump
19 around a little bit here.

20 BY MR. ZIMMERMAN:

21 Q You started up when?

22 A The Anacortes part I believe was commissioned
23 in December and the Ferndale side was commissioned in
24 February.

25 Q You mentioned that you became aware of some

1 unscheduled shutdowns. When did that information start
2 to come in?

3 A I believe it was almost immediately.

4 Q Were there problems on the Anacortes side as
5 well as the Ferndale?

6 A Yes.

7 Q When you heard about these unscheduled
8 shutdowns, what types of things did you do when you
9 became aware of them?

10 A I didn't do anything specifically.

11 Q Did you look at any data perhaps to review
12 whether the programming was correct or anything like
13 that? Were you concerned about: Did we do things
14 right?

15 A No, I wouldn't have any responsibility for
16 that.

17 Q Did you talk to anyone about the problems?

18 A I'm sure that I did, but I don't recall any
19 specific conversations. It was talked about a lot.

20 Q Do you recall any with your supervisor?

21 A No, no particular indicator conversation with
22 him.

23 Q Let me rephrase that. Do you recall whether
24 you talked to him at all, even if you don't recall any
25 specific conversations?

1 A No, I don't.

2 Q As time went on, were there any changes or
3 adjustments made to the instrumentation at the station?

4 A Well, because of the work that I've done
5 since then, my recollection is kind of tainted along
6 there.

7 I know that there have been adjustments. I
8 don't know where in the time... they exactly occurred.

9 Q But you weren't aware of any of them that
10 went on before the accident occurred?

11 A I don't have any details on that.

12 Q Before the accident, changes were made at the
13 station, who would be the person that would be in
14 charge of authorizing those changes? Set point
15 changes, for instance? Set point changes in pressure
16 transmitters?

17 A I don't know who would have the ultimate
18 authority to make the decision of what they should be
19 set at.

20 Q Before the accident on June 10, I'm thinking
21 about this in regard to Olympic's procedures, the
22 written procedures, was activation of a pressure relief
23 valve considered an abnormal condition?

24 A I don't believe so.

25 Q Even if we've covered this territory before,

1 be specific again. The closing of the inlet valve,
2 would that be considered an abnormal condition for
3 Olympic's procedures?

4 A I don't believe so. I would have to review
5 those procedures.

6 Q When you were talking to Allen previously,
7 you mentioned Portland being a similar type of
8 receiving station. Is there a pressure valve at
9 Portland?

10 A A relief valve?

11 Q Yes, a pressure -- yes, I'm sorry. A
12 pressure relief valve?

13 A Yes, there is.

14 Q Okay, and is it located downstream of the
15 inlet valve?

16 A Yes, it is.

17 Q Why is there a pressure relief valve at that
18 station?

19 A It's the end of the pipeline system. It's
20 there to protect that system, that delivery facility.

21 Q Do you know what the pressure rating or...
22 rating with the pipe is?

23 A No, I'd have to review it, the drives and
24 things like that. But I just don't know what it is off
25 the top of my head.

1 Q I'm wondering if it's just a backup system,
2 or because it is the end of the line and there's
3 pressure relief there? Or if they have a specific need
4 to protect piping. And are you aware?

5 A I know that downstream of our manifold, which
6 becomes part of the ownership of the terminals, their
7 piping is typically 150 series. So we would be
8 protecting that as well.

9 Q Okay. Where are the procedures for abnormal
10 condition report located in the Olympic manuals?

11 A Abnormal operations?

12 Q Yes, abnormal operating conditions.

13 A In the General Operating Procedures Manual.

14 Q In what?

15 A They're in the Operations and Procedures
16 Manual.

17 Q Okay. Can you recall at least some, if not
18 all, of the types of abnormal conditions out of the
19 manual before the accident?

20 A I haven't reviewed the manual. You know, I
21 haven't looked at it for years.

22 Q Okay, I understand that. That's why I said
23 can you recall any of them, you know, as an operator of
24 a system, you're probably familiar with some of them
25 even if you can't recall them all right now.

1 A I would have to review the manual.

2 Q So you can't recall any of the ones then
3 right now? You can't recall any of them?

4 A Right.

5 Q As an operator of a system, is that something
6 that you'd normally have committed to memory?

7 A Yes.

8 Q And when abnormal conditions arise, would you
9 normally look at the book to see if that was one that
10 you needed to recognize? Or would you just recognize
11 it as part of your normal operations in the system?

12 A Well, if I were to go back into Operations, I
13 would certainly refresh my memory and review that
14 material and have it, you know, available.

15 At this time, it's been quite a while since
16 I've been, you know, hands on with that stuff. So I'm
17 not able to call it up right now.

18 Q Okay.

19 A If you're trying to use me as a typical
20 operations controller, you would probably be better to
21 get that from an active operations controller.

22 Q What is the -- or what was, not what is in
23 there -- what was the operating policy regarding
24 whether controllers should assume there's a possible
25 leak and shutdown pipeline before the accident?

1 What was the general?

2 A If there's any question at all, shut down,
3 block in, monitor pressures.

4 Q And after you did that and you blocked in,
5 what would be the next step in determining whether you
6 could -- whether there was a leak or you could restart
7 a system?

8 A Well, if you had any suspicion at all, you
9 would consult the supervisor, Ron Brenson, or Will Hood
10 prior to that.

11 Q In regard to stopping DRA injection that you
12 just talked about, does the pressure precipitously when
13 the DRA is -- when DRA injection is stopped? Or is it
14 more a linear function over time until the DRA exits
15 the pipeline?

16 A It's -- there is a slope to it. It's more a
17 linear function over time and you turn it off. It
18 gradually -- its effect gradually wears off.

19 Q Have you been asked to be a part of an
20 accident investigation for the June 10, 1999 accident
21 in Olympic?

22 A By?

23 Q By anyone?

24 A Well, I've assisted the reviewing of the
25 alarm and events and those types of things.

1 Q And who asked you to do that?

2 A I worked with Office of Pipeline Safety on
3 that.

4 Q Internally?

5 A No, they came to our facility, and we went
6 through it line by line.

7 Q Okay. Was anybody else with you from Olympic
8 at the time you went through that with them?

9 A Yeah, there were probably some attorneys
10 there. I think ^{RITA JACQUES} ~~Ouida Ezak~~ was probably there.

11 Q I'm sorry? What's?

12 A ^{RITA JACQUES} ~~Ouida Ezak~~. She was a paralegal I think
13 with...

14 Q Aside from attorneys and the operating
15 people?

16 A Olympic Pipeline operators? No.

17 Q Ed Long?

18 A I don't recall.

19 Q Any other people besides attorneys that were
20 with you that were in Operations related to Olympic?

21 A Not that I recall.

22 I've also done a lot of, you know, to provide
23 data to Office of Pipeline Safety and the City of
24 Bellingham, and so forth.

25 Q I'll ask just a little bit more generally

1 now. Do you know if there are others that are involved
2 in the terminal investigation of the accident?

3 A No, not that I can think of. Early on, there
4 was an internal investigation. I think ARCO was
5 involved in that.

6 Q Do you get any feedback on what they found?

7 A No.

8 Q Or did they ask you any questions about what
9 you saw from a review of the system?

10 A No. I answered lots of questions. I don't
11 recall any of them specifically.

12 Q People did talk to you but didn't identify it
13 as an investigation at the time? Just asked you
14 questions?

15 A I knew what they were there for.

16 MR. ZIMMERMAN: Okay. That's all I've got
17 for right now. Thank you.

18 INVESTIGATOR BESHORE: Gerry?

19 MR. SCHAU: I just have a couple of questions
20 about clarifying.

21 MR. SMITH: Okay.

22 BY MR. SCHAU:

23 Q You were talking earlier about the design of
24 Bay View being similar to all other facilities on
25 Olympic. Just correct me if I'm wrong.

1 Is the difference between Bay View that it's
2 both a receiving facility and a delivery facility?

3 If you just take the receipt part of Bay
4 View, is it a local, like a delivery point like at
5 Portland, for example? The basic design is the same?

6 A Very similar. It's got a receiver, a meter
7 run, no prover. And then it goes to a manifold that
8 goes to tankage.

9 Q Same kind of instrumentation typically?

10 A Typically, yes.

11 Q So there's not a real big difference between
12 the receipt side of Bay View and what you would see in
13 the normal delivery facility?

14 A No, I wouldn't classify it as a huge
15 difference, no.

16 Q What about the pumping side, except for the
17 fact obviously that you've got booster pump versus
18 mainline units.

19 Is it similarly designed sort of like a
20 booster station, or an origin location?

21 A It's designed as an origin location.

22 Q Okay, so it looks like a Ferndale, for
23 example?

24 A Right, uh-huh.

25 Q Again, same thing, similar instrumentation?

1 A Right.

2 Q Similar operation?

3 A Meter run, control valve, discharge control
4 valve.

5 Q Except it comes out of tanks versus coming
6 from customer?

7 A Right. But, even at that level, in a lot of
8 cases, we come right out of the tanks at the customers.

9 The big difference with Bay View is to be
10 able to do both at the same time.

11 Q But, the way you were describing it, I was
12 isolating in my mind, saying, okay, I'm receiving and
13 I'm delivering. It's no different than receiving in
14 Portland.

15 A Right.

16 Q And originating out of Van...

17 A Right. The design theory of Bay View was
18 exactly that, that they were separate. You know, you
19 could be only delivering into facility and have nothing
20 going out the other side, or you could just be coming
21 out with nothing coming in.

22 Or, you could be doing both simultaneously.
23 You could be coming in from both sides into one tank
24 and coming out at both sides out of the same tank. I
25 mean it's...

1 Q What I was really trying to get at is how
2 much different does this look like? How much different
3 does Bay View look like from all your other facilities?

4 A Operationally and it's instrumented very much
5 the same.

6 Q So we heard a lot in the last couple of days
7 about "Bay View is just like all of our other
8 facilities." And I just wanted to make sure why it is
9 except for the fact that geographically they're both
10 together.

11 A Correct.

12 Q I'm not clear about this cable log gap
13 information. You said that 02 was running, ^{FAIL} swell over
14 to 01, came back to 02. But you also talked about in
15 different ways a timing gap in the log.

16 A Right.

17 Q Do you know about how much time that was?

18 A I think it's about ten minutes, something
19 like that.

20 Q And about what time that was. Can you tell
21 from that?

22 A I can tell from this. The last entry on 0A01
23 was at 1534.17. And the first entry of 02 was 1544 and
24 some change. 1544 and 30 seconds.

25 Q Okay, so your understanding is the data that

1 you have in that review is that we don't know what
2 logged during that ten minutes, at least from the logs?

3 A Right. And then further than that because
4 there's two separate files. It could be possible that
5 all the information that was on the run machine may not
6 have been available and they went back to the number
7 two machine.

8 Q Would you just repeat that? I didn't
9 understand that.

10 A When they failed, they failed from No. 2 to
11 No. 1.

12 Q Yes.

13 A The incident occurred and then they did a
14 hard failure back to No. 2, or they started No. 2 back
15 up and it came up co-primary.

16 And the fact that it came up co-primary tells
17 me that it probably didn't do any file transferring or
18 anything from the 01 machine.

19 Q So it's not clear what came over to 02 when
20 it came back up?

21 A Correct.

22 Q Entirely.

23 A Correct.

24 Q Okay. Did we do any kind of memory dump
25 right after the incident? This file, the same issue?

1 But, you're writing to two different places. You're
2 writing to memory and you're writing to disk all the
3 time. That's your archive. Your disk is your archive.

4 We didn't try to dump memory? Did you or
5 anybody trying to dump the memory records that we had
6 that gap?

7 A No. This is something that, in fact, only
8 dawned on me the beginning of the grand jury
9 investigation, in there, that this would be a
10 possibility.

11 Q That we could have dumped the data?

12 A Right. And it could be that the data is
13 available.

14 Q But, we didn't do it, to your knowledge?

15 A No, it's never been done.

16 Q Ultimately, there's no --

17 A Yes, but there could be parts of the backup
18 on the following day.

19 Q Well, it's lost now at this point.

20 A Well, I don't have access to the tapes.

21 Q Okay, so it may be on tape.

22 A Could be.

23 Q You were talking about the shutdown, the
24 command shutdown of Woodinville?

25 A Uh-huh.

1 Q Could you look at that log and tell me if you
2 ever got a confirmation from Woodinville?

3 A Yes, there was a confirmation from
4 Woodinville.

5 Q That the unit went down?

6 A At 1531 and four seconds.

7 Q That's when the unit actually confirmed
8 though?

9 A Right. And that was on the ^{only 01} ~~OLEO~~-1 log.

10 Q Okay. I thought the command went out at
11 1531.

12 A Well, command went out at 1530 and 34
13 seconds.

14 Q Yesterday, you were talking to Sandy about
15 procedures, and she said that she and you were the only
16 two that can write, update the procedures on the
17 Internet.

18 Is that accurate?

19 A That's how it is now, yes.

20 Q And I think I understood her to say that you
21 update the ^DSCA/A stuff?

22 A Yes.

23 Q So can you tell me what that looks like?
24 What kind of updates are you doing? Are you doing
25 things like changing screen prints, or changing screen

1 layouts? What do you update in those procedures?

2 A On the procedures manuals, we have taken an
3 initiative to go through and make sure that the alarms
4 that are displayed coincide with the, you know, exactly
5 what's going on in the field, and to get some
6 consistency between stations.

7 Q But it's really to operate a machine with
8 this kind of information?

9 A Right.

10 Q As opposed to procedural is what I'm really
11 driving at.

12 A Right. Well, you know, we have, since the
13 incident, we, you know, reviewed our manuals and
14 they've been updated. And they continue to be updated.
15 And we have collaborated on making many of those
16 changes.

17 But, typically, it isn't any one person going
18 off on their own and, you know, saying, "Oh, I think
19 this sounds better. I'm going to wordsmith this like
20 this."

21 It's typically a collaborative effort.

22 Q Yes, I was looking for the control. And the
23 control really rests with you and Sandy because you
24 have to actually put the updates in?

25 A I wouldn't say control. We more or less

1 would drive the process. We would rely on the
2 engineering and, you know, the supervisory level to
3 "yea", "nay" or whatever.

4 Q Was that true before the incident involved?
5 Was that the system that you had then?

6 A Up to that point, there really weren't a
7 whole lot of modifications being done to it. I think
8 that's what the problem is here. Things were being
9 done in the field that weren't being reflected in the
10 manual.

11 MR. SCHAU: All right, that's all I have.

12 MR. SMITH: There wasn't at that time a
13 formal process of, you know, "This is what I want to
14 do. I want to change this feature," or we'd go through
15 some paper trail to get signed off by everybody and the
16 final step to get it installed and get it in the
17 manual. There was no formal procedure.

18 MR. SCHAU: Instruction.

19 MR. SMITH: So things were being done in the
20 field that weren't being reflected in the manual.

21 INVESTIGATOR BESHORE: Johnny?

22 MR. PARRISH: I have nothing.

23 INVESTIGATOR BESHORE: Dione?

24 MS. MAZZOLINI: I just have one question.

25 BY MS. MAZZOLINI:

1 Q Were you involved at all in doing any
2 calculations for the amount of product that was
3 released?

4 A No.

5 INVESTIGATOR BESHORE: Peter.

6 MR. KATCHMARE: Todd, I just have a couple of
7 things.

8 BY MR. KATCHMARE:

9 Q Was Ron Bren[†]son around a lot in your -- after
10 he took over from Mr. Hood as your supervisor? Was he
11 around a lot during the day when you were on duty?

12 A He was at work a lot. His attendance record
13 I'm sure is exemplary.

14 Q Okay, and the next question is was he around
15 a lot in the last six months from December through June
16 of '99?

17 A He was in the office on a daily, you know,
18 every day.

19 Q Okay. Could you tell me the circumstances
20 that would require a field operator to reopen the valve
21 at the Bay View terminal? The isolation, upstream
22 isolation valve in the Brinnell system?

23 A My understanding is that the only thing that
24 would require a field operator intervention would be a
25 lockout of the facility.

1 In other words, if it was just a shutdown,
2 that could be reset from the control center without
3 operator intervention.

4 Q And one of the things that would cause a
5 shutdown of the station? Or a lockout, I guess you
6 called it.

7 A A lockout could be caused by overflowing a
8 tank, something that would, you know, threaten to put
9 product on the ground, those types of issues.

10 Q Do you know specifically what things, like
11 fire "eyes" going off, I think is one?

12 A Yes. They're enumerated and described in the
13 manual.

14 Q That's the only time that you would have to
15 go out and physically reset something at the station to
16 reopen that valve?

17 A My understanding is only a walkout would
18 require that.

19 Q And once it sees 700 pounds and tells that
20 valve to close, that's not a station lockout?

21 A My understanding is it is a shutdown only.

22 Just thinking on that, that shutdown is to
23 protect the low-pressure piping inside of the system,
24 not the piping outside of the system.

25 So, once the pressure has been relieved

1 upstream of the facility, there's no reason to not
2 allow realigning the facility and starting it back up.

3 Q But, how would that pressure dissipate
4 upstream if the block valve is closed?

5 A Close the control valve and open the block
6 valve.

7 Q And you can do that from the control center?

8 A Yes.

9 MR. KATCHMARE: Okay. I'm done -- for now.

10 INVESTIGATOR BESHORE: Geoff.

11 MR. SMYTH: I just have one question. I'll
12 let all the experts here talk.

13 BY MR. SMYTH:

14 Q On redesigned water systems, or a facility
15 like a water pump station or something, we have an
16 outside firm do the work, rebuild it. There's a
17 maintenance period. You know, there's a contractual
18 obligation that they have.

19 Do you know of anything that existed with
20 Jacobs Engineering on the Bay View Station for some
21 length of time after the service was brought on line
22 that they had some responsibility to be involved with
23 these problems that might have come up?

24 A No, I don't know any of those details.

25 Q So, from your history with the company, has

1 there been any other involvement that they have had at
2 any other station, or any other facility that they
3 might have been involved designing over the years?

4 A Not that I can think of.

5 Q And do you remember any of them coming on
6 site at all?

7 A Jacobs' people?

8 Q Yes.

9 A They were at Renton regularly.

10 Q And did you figure that that was unusual for
11 them to be there? I mean, if this was a normal station
12 that you had, you know, maybe you had a pump and it
13 got--

14 A Oh, after the capture, the partitioning off?

15 Q Yes.

16 A Oh, I thought you were talking about prior to
17 the commissioning.

18 Q No. After.

19 A I don't -- I can't recall any specific Jacobs
20 activity. That's not my area of responsibility.

21 MR. SMYTH: Okay, that's all I have.

22 MR. SMYTH: Okay, that's all I have.

23 INVESTIGATOR BESHORE: Linda.

24 MS. PILKE-JARVIS: Thank you.

25 BY MS. PILKE-

1 JARVIS: Q Before the June 10th event, what was the
2 last upgrade to the SCA^DA system that you can recall?
3 An upgrade either to the software or the hardware?

4 A I upgraded prior to June 10. The SCA^DA
5 software was upgraded in the third and fourth quarter
6 of 1998. The operating system software was upgraded at
7 that time.

8 From that period throughout, we had its
9 memory and some disks, and things like that on the hard
10 drive.

11 Q I'm sorry?

12 A We had some memory and a disk, hardware.

13 Q Upgraded?

14 A Uh-huh.

15 Q Okay, I'm assuming that to upgrading of the
16 software or the hardware would have resulted in a cost
17 to the company. So what would be the process of
18 getting approval to make that kind of a change to the
19 system?

20 A The cost was relatively insignificant, so it
21 was just a matter of going and asking for it, saying
22 this is what I want to do and writing a PO and going
23 and doing it.

24 Q Writing a what?

25 A A PO, purchase order.

- 1 Q So who would you go to to ask?
- 2 A Ron Brenson.^f
A
- 3 Q Tell me about the memory upgrade?
- 4 A We went from 94 megabytes to 256.
- 5 Q And that was in the third and fourth quarter
6 of 1998?
- 7 A It was over a period of time. I don't have
8 the details with me today, but they are available.
- 9 Q Do you work on other computers at Olympic, or
10 just the SCATA?^D
- 11 A Primarily SCATA.^D
- 12 Q So you do work on other computers?
- 13 A Well, more like a help desk situation, yeah.
- 14 Q Do most people, let's say in the Renton
15 office, have a computer on their desk?
- 16 A Yes, they do.
- 17 Q And are those computers linked, meaning that
18 they're -- it's a link system where people can --
19 they're not stand-alones? They're --?
- 20 A Networked?
- 21 Q Networked, that's the word.
- 22 A Yes. The computers, we do have a network at
23 Olympic pipeline. The business computers are on the
24 network and SCATA^D is on the network, but they're
25 abridged.

1 In other words, the corporate network could
2 go away and the SCATA^D stuff would still continue to
3 operate.

4 Q Would you know what -- the computers that are
5 on people's desk, what would be the average memory
6 capacity of those computers?

7 A I wouldn't know that. I'm not on that level
8 with those computers.

9 Q Do you have a personal computer?

10 A Yes, I do.

11 Q Do you know what the memory capacity of that
12 is?

13 A My current one is 128 megabytes, running
14 Windows 2000.

15 Q Do you recall, aside from this memory upgrade
16 and whatever software upgrade in that third and fourth
17 quarter, do you recall asking for permission for other
18 kinds of upgrades and -- I guess let me say that again.

19 Have you ever been denied permission to spend
20 money to upgrade either software or hardware?

21 A No, I have not.

22 Q Thanks.

23 All right, let me ask you a question on a
24 different topic. And could you get the event log and
25 look at it again?

1 A Okay.

2 Q This would be 02 at around 1617. So this is
3 a series of events where the system is being restarted?

4 A Right.

5 Q And, presumably, the rupture has already
6 occurred. So I'm kind of confused about if the system
7 would be restarted but the rupture had already
8 occurred, it seems that product would not have been
9 flowing past the rupture point and arriving at the next
10 station down the line from the rupture point.

11 Could you tell me a little bit about what
12 methods would have been available for the controller
13 for the controller to reach that understanding?

14 A A knowledge of the geography, the elevation
15 differences, an estimation of what it would take to
16 fill the voided pipeline.

17 Q So there's kind of a 15-minute period there
18 when it appears that he sort of recognizes that there's
19 a problem and he shuts down the control valves.

20 So, for that 15-minute period of time, you
21 know, would that have been enough time for the system
22 to refill, for him to be able to understand that the
23 line's refilling, yet product is not reaching?

24 A And this would be 15 minutes starting from
25 what, from when?

1 Q At 1617.

2 A Okay. And you said there's a place where
3 control valves are closing?

4 Q At 1632.

5 A Okay. And you wanted to know if that would
6 be enough time to realize that there was problems?

7 Q Yes. Maybe, since you're not in the control
8 room, that's not a fair question to ask you. But...

9 A It could be.

10 INVESTIGATOR BESHORE: I don't mean to
11 interject but it's Linda's train of thought that I'm
12 going to.

13 MS. PILKE-JARVIS: Okay.

14 INVESTIGATOR BESHORE: Because I was going to
15 add another exhibit that may just go to what you're
16 currently asking. And I'm going to label it as exhibit
17 -- I think I'm up to 7 here. And it would be page 325.
18 Another trend chart is what it is.

19 (Whereupon, the previously-
20 identified document, marked as
21 Exhibit T.Smith 7 for
22 identification, was received
23 into evidence.)

24 INVESTIGATOR BESHORE: I was just going to
25 ask a couple of questions, and it may kind of help with

1 what you're looking at, Linda.

2 BY MR. BESHORE:

3 Q I guess, if you could kind of review the
4 different trend lines there and tell us what you see.
5 Specifically, I guess the Bay View incoming pressure is
6 shown on that trend line.

7 A In blue.

8 Q So I think what -- not to put words in
9 Linda's mouth, but what she might be asking there is
10 does it look -- based on that trend line -- if there's
11 any increase at all in the incoming pressure into Bay
12 View? Would that be something that you would expect to
13 see if you were in the process and the lines start
14 there, I guess?

15 A Right. Like I said, you would want to have
16 an idea of how much volume it would take to voided
17 pipeline because you would have to fill the voided
18 pipeline before you would see a rise at Bay View.

19 In other words, just starting a pump at Bay
20 View, a voided pipeline is not going to give you a
21 wave, that you're going to see it.

22 Starting with the pump at Ferndale is not
23 going to give you a transient wave that you're going to
24 see at Bay View unless you have a full system.

25 So you have to kind of calculate I think what

1 that anticipated volume is. You know, then you start
2 your pump and start thinking about when should I start
3 seeing something down at the other end. It's forty
4 miles of pipeline, too.

5 It can take quite a while, depending on how
6 empty it is, to fill it up.

7 INVESTIGATOR BESHORE: Okay...

8 MS. PILKE-JARVIS: That's okay. Thank you.
9 I think I understand it a little bit better.

10 MR. SMITH: Well, the amount of time to fill
11 that void up is directly related to how empty, you
12 know, what the volume you have to put in it, and how
13 fast you're doing it.

14 BY MS. PILKE:

15 Q You said from a question that Allen asked
16 you, you made the statement that you had never had that
17 type of computer outage that occurred on June 10 happen
18 before. And I just wanted to kind of get some
19 clarification on that.

20 Have you ever known both computers to fail at
21 the same time prior to June 10th?

22 A Not that I can think of, no.

23 Q Have you ever had people tell you that the
24 ~~SCATA~~ system appeared to be slow or unresponsive prior
25 to June 10?

1 A There were some reports of slowdowns at
2 around the midnight hour. Typically, they were
3 discussions in passing that went sort of like:

4 "Well, you know, Al, when I was working the
5 other night, it seemed like at midnight my screens
6 weren't updating the way that they normally would."

7 Q What kind of time frame prior to June 10?

8 A Pretty much through the whole thing from the
9 upgrade of the software.

10 Q Did you ever attempt to troubleshoot that?

11 A Well, the problem was that it was always like
12 the day or two after. Nobody ever called me up and
13 said, you know, Todd, it looks like we're having a
14 problem here with the computers. Could you take a look
15 and see what's going on?

16 And, you know, I would just add that working
17 there during the day through all that period of time, I
18 never got one phone call. I've never had anybody ever
19 come in to me and ask me to look at a problem like
20 that.

21 So it was something that wasn't reported by
22 everybody, not experienced by everybody, so I couldn't
23 trap it. I did try to look at it but, you know, it was
24 the hit and miss type of a thing.

25 Q I also wondered if you could clarify the

1 conversation you had with Lloyd on June 10 when he
2 called you.

3 It kind of went over that so fast I didn't
4 understand it.

5 A Sure.

6 Q What I caught was that he called you but at
7 that time he felt that the problem had been resolved.

8 A He called me after the No. 2 machine was back
9 on line and communications had been restored. He gave
10 me a brief recap of what had occurred. There was, in
11 the error log, there was a reoccurring error that was
12 being caused by a process that was not currently being
13 used, but hadn't been removed from the system.

14 And what I had been doing as an interim was
15 to just manually stop that process. I got to a point
16 where I could actually take it out of, you know,
17 generate it out of the system.

18 So I told them, you know, what the problem
19 was. We stopped the process and the problem was fixed.

20 Q Okay, so you're saying that you had seen that
21 kind of error before and you had a way that you would
22 address it. But Lloyd didn't necessarily know about
23 that, and that's the conversation that you had? You
24 told him what to do to fix that error?

25 A To fix that error, yes.

1 Q And what was the purpose of Lloyd calling
2 you?

3 A To find out if I could help him to stop that
4 one error that was being generated. And to give me,
5 you know, to tell me what had happened previously to
6 that.

7 Q Since the two of you worked on this together,
8 did he report to you in any way? Or you guys were co-
9 workers?

10 A We just worked together.

11 MS. PILKE-JARVIS: I think that's all my
12 questions. Thank you.

13 INVESTIGATOR BESHORE: Patti.

14 BY MS. IMHOF:

15 Q Todd, I'd like to understand a little bit
16 better the communication that went on between the
17 controllers and the field. Can you help me with like
18 what your structured relationship was?

19 Did you have the same supervisor? Was Ron
20 Brenson⁺ their sup, the field people's personnel
21 supervisor, as well as yours?

22 A No. Ron was just a supervisor of the control
23 center, probably with accounting and scheduling. And
24 then each area -- north, central and south, or north
25 and south -- had a supervisor that oversaw their own

1 employees.

2 So, for example, David Justice would be the
3 supervisor of the north area people. And Don Gregory
4 is the supervisor of the south.

5 Q So where did the communication occur? At
6 what level of personnel did the communication occur
7 when excavating was happening out in the field and
8 things going on that maybe needed some control room
9 participation?

10 A Typically, we would go through Ron Brenstson,
11 then we'd come to the control center. A lot of times,
12 if special procedures would be written by the
13 engineering department, what their needs were, Ron
14 would be aware of what they were and they were just
15 passed to the control center to be followed through.

16 Q So, like when Dick and you, the work was
17 being done at the water treatment plant in Bellingham,
18 the Day View project, how involved would the
19 controllers be in the fact that we have the pipeline
20 exposed, working in that area?

21 A I don't know what the relationship was at
22 that time. I don't know what anybody knew about what
23 was going on at that time.

24 Q So, to your knowledge, the controllers --

25 A I never heard about it, no.

1 MS. IMHOF: Thank you.

2 INVESTIGATOR BESHORE: I think it would
3 probably be a good time to take a break. I think that
4 Todd could probably use it... so let's take a 10-minute
5 break and start back up at quarter after.

6 (Recess.)

7 INVESTIGATOR BESHORE: Let's just go ahead
8 and get started. Jim, do you have some questions?

9 MR. CASH: Good morning. Jim Cash is my
10 name.

11 BY MR. CASH:

12 Q Most of my questions will be related to the
13 hardware or software systems. So, if I ask something
14 that doesn't make any sense, kind of humor me and bear
15 with me.

16 The Monday morning fallback -- I think you do
17 it on Monday morning -- is when you change from ^{OLY#1}~~OLEO-1~~,
18 ^{OLY#2}~~OLEO-2~~ or 2 to 1, how do you normally do that?

19 A Well, it starts with the image backup of the
20 operating system disk and the application disk on the
21 backup computer. And then --

22 Q That takes a -- do you take it down to stand
23 alone backup?

24 A Yes. I do. Yes. I do a shutdown, do the
25 backup. And then stop the SCATA^D software on the

1 primary, and the secondary will pick up from that
2 point.

3 Q So you do the SCATA^D shutdown? You don't
4 necessarily crash the machine?

5 A No.

6 Q You actually do an orderly shutdown of the
7 SCATA^D?

8 A Yes.

9 Q So, basically, each machine gets rebooted
10 every other week?

11 A No, because after failing over, then we'll go
12 ahead and do an image backup of what was the primary
13 machine, just --

14 Q Oh, so just reboot it every --

15 A Sure.

16 Q As far as the screen development, I think you
17 -- the screens that controllers use, is Lloyd pretty
18 much the main man in that? Or do you --?

19 A Currently? Or, in general? Can you narrow
20 that down a little bit?

21 Q I mean who does most of the screen... I
22 guess?

23 A Right, now Lloyd Tieken is the person that is
24 doing that.

25 Q Was that true before? Like when Bay View

1 came on line, did he do most of the screen --

2 A Yes. Lloyd Tieken did the screen... for Bay
3 View.

4 Q So you're not really involved, so hold those
5 questions for him?

6 A We give him input, you know. And he tries to
7 get input from the end user, the other operators to,
8 you know, "How can I improve this? How can this be
9 better?" type of stuff.

10 Q Is there any way to kind of test the screens
11 before they are put into service? I mean is there a
12 way to simulate data to see if it is doing what you
13 think it should be doing?

14 A No, there really isn't. The SCATA^D system was
15 designed to be maintained on line, more or less. There
16 are debugging features in the screen development. For
17 example, if you misspell a tag name for a point, it
18 will put an arrow on it, the error line we talked
19 about.

20 Or, if the point doesn't exist in the field
21 or there should be numbers, there will be question
22 marks. You know, things like that.

23 The way that it works is that the first time
24 that a screen is requested from a console, the file is
25 uploaded from the SCATA^D host. From that point on,

1 whenever that screen is requested, the host is checked
2 for a newer version. If there is no newer version,
3 then it uses that copy that resides on the local
4 workstation.

5 And then, after that, the only data that is
6 transferred is the live data from the SCA^DTA, which cuts
7 down a lot of overhead.

8 Q Yes, I was mostly interested in the
9 development. You know, if there's a way of checking
10 that things are actually -- I assume you have, like
11 when a new system comes on board, you cycle through all
12 the control features.

13 A Yes.

14 Q Somebody's out there to actually see that it
15 does do what you --

16 A Right.

17 Q And then they can tunnel switches open and
18 put things into a wire to make sure that the screen
19 reacts the way it's supposed to?

20 A Uh-huh, that is done.

21 Q So it's kind of an on line?

22 A But, once the initial facility is brought on
23 line, then from that point, you know, you develop
24 screens and you just basically turn them on and verify
25 the data that is displayed on other screens in the

1 general -- what they call parameter displays, which are
2 lists of all of the points for that facility, where you
3 can see the stain or the ... values.

4 Q In general, does that go pretty smoothly? I
5 mean do you guys make many mistakes that have to be --
6 I mean there's got to be mistakes as people find out
7 when they start operating.

8 A Well, yeah, but the way that it is done, the
9 correct way to do it is to edit a little bit of the
10 screen and then check the error log to see if you've
11 made any, you know, fact-fingered any tags or anything,
12 those types of errors.

13 And then to verify that the data on the
14 screen jibes with what the analog or the SCADA^D device
15 is from the field.

16 Q Is that kind of a full-time job to maintain
17 screens for making changes that come along?

18 A No, it's not a full-time job. Lloyd's been
19 doing it, you know, on special assignment. When we
20 have extra people in the control center, you know, we
21 like to get them involved with doing other things. You
22 know, they have to come to work so we might as well
23 utilize that extra time to get them involved in other
24 aspects.

25 Q Do you get involved in the batch processing?

1 I assume you must have some VMS batch jobs that are
2 running?

3 A Yes, I've written many of those.

4 Q What kind of batch jobs would be running on a
5 normal day?

6 A Every day, there is a batch job that prints
7 out communication statistics for each RTU for the day
8 before.

9 We do a backup of the daily historical files
10 and the daily event files are done from a batch file.

11 Q What time does that run?

12 A Pardon me?

13 Q Do you know what time that runs?

14 A I could tell you what it is but I can't tell
15 you how it's done in my head. I typically try to
16 stagger these so that they aren't all happening at the
17 same time.

18 I'm thinking that the R-paddle is about 5:35
19 in the morning. The communication one I think is
20 8:55. There's another one that runs that dumps the
21 ticket information into a text file that can be picked
22 up by the product accountant for billing purposes.

23 There's another one that does a dump of the
24 provings, proving of course meter calibrations from the
25 previous day that can be picked up and put into an

1 accounts spreadsheet or the data base type stuff like
2 that.

3 Q But, no real big, huge jobs that run or
4 anything?

5 A No, these are all -- the biggest one is of
6 course the -- we do it daily -- incremental backup.
7 And that is the one that takes the longest. As we go
8 forward in time, each day there is more to back up. So
9 it takes a little bit longer each day.

10 But they are typically set to a low priority.
11 I don't know if you're familiar with the BMS system but
12 it's based on priorities, our highest priority being 15
13 and the lowest being 4. And all of our batch shops are
14 running in a No. 4 priority.

15 So they're the bottom.

16 Q Do you just leave the same tape in there and
17 let it just pin to the end of that?

18 A Right.

19 Q For incremental?

20 A Well, we start with the image backup. Like
21 we talked about before, which is a complete backup of
22 the disk.

23 Q Right.

24 A And then, when I do that, I mark all of the
25 files as being backed up. And then from that point on

1 a daily basis, any files that have been changed or
2 created are backed up.

3 And then on a weekly basis, we will back
4 everything up for that prior week and mark everything
5 as being backed up, so that we don't just keep getting,
6 you know, bigger and bigger and bigger sets.

7 And, yes, except for the image backup,
8 everything is done on the same tape.

9 Q You take files to say -- you go back and do -
10 - what do they call that? You set the flag in the file
11 saying it was was correct?

12 A Yes, actually, it time-stamps the file when
13 it goes back up. And that way, the next backup will...

14 Q Record pass.

15 A Yes, recording pass. It will skip over that
16 file and not do it every day.

17 Q About how long do you think it takes for the
18 VMS to come up from a cold start? Like from when you
19 do a stand-alone backup, can you just reboot it?

20 A It only takes a couple of minutes.

21 Q Even if like if he -- I'm trying to get some
22 feel, like when he -- I think the word that I got
23 anyway was that he just reset the machine, which was a
24 hard crash, during the event.

25 So it probably would have to rebuild some of

1 the image volumes?

2 A Right. Yeah, on that system, you're talking
3 five to seven minutes I think to get the whole thing
4 back up on the operating system under that kind of
5 circumstance.

6 Q And that's due to the rebuilding of the
7 volumes, right?

8 A Rebuilding of the volumes, yes, the processor
9 speed, stuff like that.

10 Q Have you had any formal VMS training?

11 A No, I haven't.

12 Q DEXSKILL, or something similar to that?

13 A No, no DEXSKILL, no.

14 Q How about for the ^DSCATA?

15 A I have had some formal training on that, yes.

16 Q That's through Teledyne?

17 A Teledyne.

18 Q Have you participated in any of their users -
19 - I think they have a Teledyne users conference every
20 year?

21 A Yes, I do. I do. And they also have
22 training seminars going in conjunction with that as
23 well.

24 Q You've been through several of those?

25 A Yes.

1 Q Has there been any thought about
2 transitioning to their, if you want to call it their
3 current system? I think it's an NT based system,
4 instead of VMS based?

5 A Where we're at right now is we're looking
6 at -- not at their NT system because they don't have
7 any large systems that are running on that yet.
8 They're primarily VMS right now.

9 They do have an NT product but, like I said,
10 it doesn't have enough history and they don't have any
11 large systems running on it.

12 The problem with NT is it's not as mature or
13 as stable as VMS. It just has the name familiarity
14 more than anything else.

15 Q Could I talk a little bit about the hardware
16 mostly on the local area network setup that you guys
17 have? I have not been able to get any of this
18 information from anybody else.

19 So, if I exceed what you know, just let me
20 know.

21 A Okay.

22 Q Can you just kind of generally go through
23 what your local area setup is, starting from the batch
24 computers? Are they on thin net segments, or are they
25 twisted pair segments? How is it? A looped pot feed

1 or... start feed?

2 A Well, back then we were on both thin wire and
3 twisted pair. We're currently all on twisted pair now.

4 Q Okay, that's after June 10?

5 A Yes. The only thin wire connection now is
6 between the batch host and the network.

7 Q Okay, well, let's go back to before June 10,
8 I guess, if you remember back then.

9 A Okay.

10 Q The two batches, were they on the same thin
11 wire segment? Or were they on the same loop?

12 A They are on the same network. And ours is
13 more -- is more of a star configuration... they're not
14 doing a token thing or anything like that.

15 And there's thin wire from the batch host to
16 the back plane, which is the network connection.

17 Q Was that a Delving? I think that calls for
18 Delvings?

19 A Pardon?

20 Q A thin net hump arrangement?

21 A It's a repeater something is what it is,
22 actually.

23 Q Okay. So that there's one piece of co-ax
24 from that box to the -- to each batch?

25 A To a reel one. And then there's another one

1 to the other one.

2 Q Okay, and to the I assume the one that runs
3 the leak detection?

4 A Yes.

5 Q And then how are the units in the command
6 center, the individual PC stations?

7 A PCs? Those were DEC PCs. They were on the
8 twisted pair that came in to the same type of a
9 situation on the back plane of the DEC. And then all
10 of that is bridged to the ... network.

11 Q What kind? It's a DEC bridge?

12 A Uh-huh.

13 INVESTIGATOR BESHORE: By "deck" are we
14 referring to digital electric?

15 MR. CASH: Digital Equipment Corporation?

16 MR. SMITH: Yes.

17 INVESTIGATOR BESHORE: So that's an acronym.

18 MR. SMITH: It's a company logo which is now
19 a compact.

20 BY MR. CASH:

21 Q I think your system was set up for 13
22 stations, workstations?

23 A It currently was set for twenty. But, at the
24 time, it was for thirteen.

25 Q Can you go through where those thirteen guys

1 are? Do you remember?

2 A Sure. They were nine dedicated to the
3 control center. And the rest were on -- there was some
4 on the PLC, the leak detection computer in the computer
5 room.

6 Q So they were all in the computer area --

7 A Yes.

8 Q The control center or the --

9 A Yes.

10 Q All thirteen?

11 A They were all in the control center or in the
12 computer room.

13 Q And you talked earlier about being able to
14 dial in?

15 A Yes. At some point, I installed one of those
16 screens on to my laptop. But I can't recall at what
17 point in time when that actually happened.

18 Q Are all the -- before June 10th, were all the
19 PCs using DEC net or were they using PC PIP for
20 communication with...

21 A They were all using DEC net at the time.

22 Q Do you know if the bridge -- does that bridge
23 route DEC net, or does it -

24 A I don't know how that's configured.

25 Q But, you didn't have any PC PIP. All the

1 workstations were DEC net...

2 A Right. They were actually connected to the
3 same back pulling as the hoses.

4 Q Right, through the distribution box.

5 A Whatever, yes.

6 Q Was there any -- so if you were on the
7 corporate network, which I assume this probably was, at
8 least the June 10 time, it was hooked to an Internet?

9 Did they have Internet access through
10 corporate PC structure?

11 A On June 10, I believe that they did on the
12 corporate side.

13 Q So, if you were on the corporate side, could
14 you actually log on to a VAX? Could you get at them?

15 A Yes. Right, with their approval.

16 Q So you were running Path Works? You just had
17 a third party lap protocol installed?

18 A Yes, right. Not Path Works. Reflections.

19 Q Which has the LET.

20 A Right, terminal emanation and lap protocol.

21 Q Was there any other way to -- because I know
22 there's a lot of accounting data and stuff that other
23 people use that SCA^DTA generates?

24 A Yes, there's an accounting file.

25 Q How would people in billing or whatever --

1 A I think we're talking about two different
2 things.

3 Q A lot of the --

4 A Are we talking about systems administration,
5 or are we talking about pipeline account?

6 Q Pipeline accounting.

7 A Okay.

8 Q SCATA^D generates a lot of that data that other
9 people use.

10 A It collects it, yes, it does.

11 Q How do they get at that?

12 A Once a day, a batch file collects that out of
13 the data retrieve RMS data base and is put into a
14 tapped eliminated file, and then they can pick that up
15 off of that. Off of the host and then insert it into
16 their specific software.

17 Q So they do some kind of a file transfer?

18 A Yes.

19 Q But, in general, people aren't necessarily on
20 the -- with access for doing anything?

21 A No. No.

22 Q So they don't interactively run anything.

23 They just go and get a file that's generated by batch?

24 A That's correct.

25 Q Have you ever had any failures or any kind of

1 broadcast arms or anything on the business side that's
2 affected the SCA^D/A?

3 A No. Not to my knowledge, no. The only
4 problem we have had is we had a cable failure one time.
5 It kind of gave us a little bit of a -- it was a
6 nuisance type of a thing because it, you know, it was
7 an intermittent thing. You would never think that a
8 cable would fail.

9 Q Inside? Within that section?

10 A Yes, within that section.

11 Q But, you haven't had anything on the other
12 side of the bridge that is --

13 A No. We've monitored our networks and there
14 isn't a whole lot of traffic going on in either one of
15 those.

16 Q Do most of the PCs in the control room run
17 the Windows version or the DOS version of the SCA^D/A
18 vector?

19 A It was all DOS.

20 Q Is that just easier or more stable? That's
21 what you always had?

22 A Well, that was what was available at the
23 time. It was the technology. Now we're running with
24 Windows version of it.

25 Q What's the password structure that you use

1 for the VAX? I assume you have different levels for
2 different people?

3 A There are only two users on our system.
4 That's the system administrator and then the vector
5 user.

6 Q It's like there's only two passwords?
7 There's logins and two passwords?

8 A That's correct. Some people have, myself,
9 for example, I have an account of my own on the system.
10 But, since I do all my work with vector, I log on under
11 the vector account.

12 That's basically been the standard practice
13 since the beginning.

14 Q Is there any -- you can have individual
15 logins, so everybody would be --

16 A Yes, you can. But, the logicals and symbols,
17 the logical and the symbol table for vector is real
18 extensive and if you get familiar with it, you start to
19 really want to use those little shortcut things.

20 And I guess, over the years, people have just
21 found it easier to, when you log on to vector, it
22 automatically sets you up with those symbols and things
23 rather than, you know, to try to reduplicate that, or
24 duplicate all those symbols in your own login.

25 Q Does that make it difficult sometimes to

1 figure out who did something because everybody is all
2 one user?

3 A Well, it isn't everybody. There's only
4 myself, Lloyd and the accountant that used the system.
5 If we got to the situation where there were more users,
6 then, yes, we would want to set up, you know, more
7 accounts.

8 Q The controllers, they login with --

9 A They don't login to the SCADA system.
10 They are not on a system level.

11 Q I know, but when they bring up a screen, like
12 a PC turns on, is there a login --

13 A You're talking about a logging into these
14 vectors to software layers?

15 Q Yes.

16 A Okay. No, our control center screens, they
17 never log off of those machines. They're always on.
18 You can tell where the command is coming from. The
19 control request tells you what CRT that that command
20 came from.

21 You can cross-check that with a work schedule
22 and know who was on duty. And I guess if they wanted
23 to point fingers at each other, they could certainly do
24 that. But, it basically comes down to two people.

25 Q So that's kind of the corporate setup, is to

1 not use individual logins, and use the same login for--

2 A Negative. That's only in the control center.

3 Now, when I dial in from any location, or even when I

4 sign on when I'm at the corporate location, I have my

5 own user name and password.

6 And you can see where Todd Smith has logged

7 on to the system, or Todd Smith has logged off of the

8 system.

9 Q Your business side, is that Microsoft Network

10 and PA server network?

11 A Yes, it is. At the time, it was Novell.

12 Q Okay, you've changed that?

13 A Yes.

14 Q While you're talking about login in the

15 modem, is that just a terminal part on the back of the

16 vax that you come through with console cord?

17 A Well, I have two or three ways to get in. In

18 case, you know, there's a failure with one, I have

19 alternate ways to get in, including a direct modem

20 attached to the PLBS computer. I've got RAZ running on

21 a PC. We've got the corporate RAX.

22 You know, there's several ways to get in.

23 Q You were saying about that air process, that

24 unused process that was coming up when he rebooted the

25 machine. What specifically was that? Do you know?

1 A It's called DP Dollar Config.

2 Q And what does that do?

3 A There is a feature in vector, which is our
4 SCATA software that, if you wanted to have, you know,
5 lines change color, you know, if this pipeline becomes
6 active, you could make it change color, and things like
7 that, that we never used.

8 And my philosophy has been: If you don't use
9 something, why consume the resources with it?

10 We're under a continuous process of reviewing
11 what our system is configured, what processes we're
12 using, what processes we're not using.

13 And if a process isn't being used, I'd just
14 as soon not load it into -- not use the resources with
15 it.

16 Q So why would it generate an error? Trying to
17 open something that isn't there?

18 A No, it was trying to look at records that
19 didn't exist.

20 Q Okay. So you just cut that out of the
21 startup?

22 A Well, the vector system is a little bit more
23 sophisticated than that. Everything is preconfigured
24 and then you -- what do you call it? It's a utility is
25 called Generate. And you run that utility and it

1 actually goes into the data base and finds out which
2 processes are active, and then it writes a startup
3 script from that data base.

4 So it's something that I typically only like
5 to do, like when I do the failover thing, so that I can
6 make sure that all the changes get over on the other
7 machine.

8 Q Do you know if your VMS and/or SCADA^D is set
9 up to automatically purge files, delete files, remove
10 files on startup or shutdown?

11 A Yes, there is some of that. Yes. Well, on
12 the operating system level areas, a version limit that
13 you can put on files and directories.

14 Q Is that set, do you know?

15 A Pardon me?

16 Q Is that set?

17 A It's set on a case by case basis.

18 Q It's not a global system set?

19 A No. No. We always felt with our backup
20 routine and the limitation of disk space on the
21 proroller systems that it's best to keep things down to
22 a minimum.

23 So, yes. And then there are procedures that
24 run that purge duplicate records, or duplicate files --
25 I'm sorry -- off of the disks on a daily basis. And

1 housekeeping things.

2 Q Have you ever seen a slowdown like was
3 recorded on the screen... as far as I mean I think you
4 talked about at midnight people were complaining.

5 A I have never seen a slowdown of the SCATA^D
6 system.

7 Q Have you ever seen -- I think he was working
8 on some kind of historical program, going in and
9 querying the data base for something he was developing?

10 A Uh-huh.

11 Q Have you ever seen any kind of system
12 development like that that would cause the system
13 to...?

14 A No, I've never seen anything data base-wise.
15 Like I said, I've never seen anything that has caused a
16 SCATA^D slowdown. That type of work, you know, is data
17 base work. The system was designed to be used on line.

18 The way that vector handles data bases is
19 that on startup, you define how much space you want,
20 say, for analogs. You say, okay, I want to have space
21 for 3,000 analogs. You may only have 1,500 analogs
22 but, on startup, vector will allocate space for 3,000.

23 And so when you add a record, you're just
24 filling up that space in there with a new record. If
25 you should fat finger a parameter or something like

1 that, it will put errors in the error log.

2 It's designed to be very robust and, you
3 know, very forgiving of those types of things. It
4 won't typically bring your system down.

5 Q And, in general, you find it very, somewhat
6 robust?

7 A Well, it has to be. The system, like I said,
8 it was designed that way. For example, if you wanted
9 to go -- people say, well, why don't you do that stuff
10 on the off-line. Well, if I go over here and I do it
11 on the off-line machine, then the next thing you know,
12 this guy shadows his data over there and writes over
13 all the stuff that you've done.

14 I mean you have to make those kind of changes
15 on the on-line machine. And so, therefore, it was
16 designed to function that way.

17 Q You mentioned about the memory copy might be
18 on the back-up tapes? I have the back-up tapes. What
19 would I look for? Is there a filing associated with
20 it?

21 A Yes, ^{EVENT}~~Avant~~ LS.dat.

22 MR. CASH: That's it. Thank you.

23 INVESTIGATOR BESHORE: Eric.

24 MR. SAGER: Eric Sager, with the Safety
25 Board.

1 BY MR. SAGER:

2 Q When you learned that Lloyd was working on
3 his project inserting I guess an element of a program
4 to collect historical vibration data, as I remember --
5 is that correct?

6 A He was adding some historical data base
7 points. He wasn't actually doing any programming, or
8 anything like that.

9 Q I was referring back to his deposition. I
10 thought he was actually creating a way to collect the
11 vibration data.

12 A The way that process works is we have what is
13 called the Historical Data Base, and it looks very much
14 like the analog in the discrete data bases.

15 As I was explaining earlier, on startup,
16 Vector allocates a certain amount of space for each
17 type of data base, analog discrete. And when you add a
18 data base record, all you're doing is filling up one of
19 those empty slots. It's already been created in the
20 data base.

21 We're not actually running a program.

22 Q How long should it take him to get started in
23 doing that? To call up the information or the
24 historical portion of the program where he can then
25 make his entries?

1 A Just a few minutes.

2 Q Is this -- are activities like this fairly
3 routine for you and for Lloyd?

4 A Yes, they are.

5 Q Is there any particular reason why you would-
6 - are there any occasions when you notify controllers
7 that you're working on the system?

8 A Yes, there are. For example, if we're going
9 to take the backup system off line, we'll let them know
10 that we're doing that because a message or an alarm
11 would be generated in the control center saying that
12 the backup system is off line, so we want them to be
13 aware that that's going to happen.

14 A lot of our data base work is done at the
15 request of the control center. And a lot of it is done
16 inside the control center rooms.

17 But there is no formal requirement to go in
18 and say I'm going to be accessing the data base right
19 now.

20 Q Has anyone ever complained to you, any of the
21 controllers complained to you that they were in the
22 middle of a critical move and something you or Lloyd
23 did interfered or caused a distraction, or caused a
24 problem?

25 A Not that I can recall prior to June 10, no.

1 Q And what's happened since June 10 in that
2 respect?

3 A I got a piece of software that would allow us
4 to access other computers' tape devices. Right now,
5 you can only access the tape device that's directly
6 attached to a particular machine.

7 I got the software. I installed it according
8 to the documentation. Basically, it has a listener
9 that comes on line and you're supposed to, you know,
10 listen for connection request.

11 And I did it on the backup machine first
12 because, you know, the off-line machine would be -- if
13 there were a problem, you know, I would expect to see
14 it there.

15 Followed the same procedure on the primary
16 machine and when I started up, I knew immediately that
17 there was a problem, but it was enough of an
18 interruption that they did see it in the control
19 center.

20 And it was enough to be reported to the
21 Office of Pipeline Safety. The interruption was maybe
22 a minute long. I stopped the process immediately and
23 corrected the problem.

24 Q I'm a little confused on this, on a different
25 subject. Related, but a different subject. Is there -

1 - was it strictly coincidence that what Lloyd was doing
2 that Lloyd's activities, Lloyd was doing what he was
3 doing when the computers failed?

4 Or, was there a connection between the two?

5 A I think it was a coincidence. It's never
6 been determined through all the studies what exactly
7 was the cause of the computer failure, or the computer
8 overload, or whatever you want to call it.

9 This very well could have been a symptom of
10 the whole, overall picture rather than root cause.

11 Q Could you explain that symptom, the overall
12 picture?

13 A Well, at the beginning, it was suggested that
14 maybe the data base records were corrected in memory.
15 And what I'm thinking is perhaps the failure of the
16 system may have caused the corruption of the data base
17 record and memory, as opposed to Lloyd making a data
18 base error in entering the record to begin with.

19 Q So the problem then was with the data itself?

20 A The original report, or one of the original
21 theories floating was that the records were somehow
22 corrupted in memory and not an operator error.

23 I don't know that that has ever been, you
24 know, proven one way or the other.

25 Q Is that something that your company is still

1 working on?

2 A I believe that that has been going between
3 the City of Bellingham's consultant, ... Engineering
4 and Equilon, passing that report back and forth. And I
5 don't know honestly where it's at right now.

6 I would just add that data base entry errors
7 have occurred in the past and they have not brought the
8 system down.

9 MR. SAGER: That's all I have.

10 INVESTIGATOR BESHORE: Okay, I'm going to
11 have my turn again.

12 MR. SMITH: Okay. I'm going to turn this way
13 and save my neck a little bit.

14 INVESTIGATOR BESHORE: I have a few
15 questions. I don't have too many, but I've come up
16 with a few.

17 BY MS. BESHORE:

18 Q I just want to ask to make sure on the
19 exhibits, these trend lines in particular, the Exhibits
20 5, 6 and 7. A couple of these were generated on June
21 10, which would have been relatively short after the
22 accident.

23 Are you the one that generated these trend
24 plots?

25 A I could have been the one that generated

1 them.

2 Q Okay, because when we were talking about it
3 earlier, I didn't recall whether you remembered
4 actually generating trends on that day.

5 A I very well could have. I could have but I
6 can't say conclusively.

7 Q And I'm a little confused, too, about, you
8 know, we're talking about this potential file that's on
9 the backup.

10 How long a time frame is that going to
11 capture?

12 A It's the last 10,000 records.

13 Q Okay, so that's specifically what we're
14 looking, is the last 10,000 records that were seen on
15 either of the two computers?

16 A Well, prior to -- at intervals, that stuff
17 that's in memory is written to disk. So the last time
18 that that was written to disk would have been the
19 10,000 records at that point in time. And then the
20 tape, the backup was made.

21 So it's only going to be roughly the 10,000
22 records back from the time that the tape was made. So
23 it may have the stuff in it; it may not.

24 Q The first backup was made when? Did you do
25 that?

1 A They're done on a daily basis, automatically.

2 Q What time? So, on June 11th at some point?

3 A Yes, at some point on June 11th.

4 Q In terms of the issues around Bay View that
5 you were experiencing after its commissioning, you and
6 the others in the control room, did people generally
7 attribute those to the design of the system?

8 A Yes, I would say so. Are you talking about
9 did the engineers contribute that to their design, or
10 did the control center point any fingers at the
11 engineers?

12 (Laughter.)

13 Q Well, now that's a good point. But I guess
14 the controllers in the control room, from your
15 perspective, is what I was more interested in.

16 A There were concerns at the beginning of
17 bringing that low pressure system into the high-
18 pressure, you know, pipeline setting, as opposed to
19 having it be stubbed off of the main line.

20 Q And was that a concern that was just amongst
21 the controllers, or was that a concern that others had
22 as well?

23 A It was a concern that others had heard. I
24 mean it had been talked about a lot.

25 Q You talked a little bit about network, and

1 I'm a little unclear. Can anybody in the company call
2 in and access the SCATA^D program and see what's going on
3 on the vector screens?

4 A No.

5 Q Can Ron do that from his office, Ron Brenson^K?

6 A He could.

7 Q So he has an access where he could get in
8 there?

9 A If I gave him the software, you know, to do
10 that. We're all on the same network. The only thing
11 is it's bridged. You have to have the software and,
12 you know, the user -- you have to be set up as a user
13 and have a password and that kind of stuff.

14 Q Was he set up on June 10 to do that?

15 A I don't know. I don't recall.

16 Q But, anyone could be set up to do that from
17 what you just said, right? Given the software and--

18 A Well, there are some things under, you know,
19 that have to be configured on the computer. It's not
20 like I've got this piece of software and now I just
21 have to turn it on. I have to configure you inside of
22 the SCATA^D system.

23 It has to be a new display. We only have,
24 like I said, twenty right now. So, if the twenty are
25 allocated, you know, you can't just go in and set up

1 and take off.

2 Q Okay, so it's not as easy as I was making it
3 out?

4 A No, no. Right, there are procedures.
5 Security is always an issue. And we've got a couple of
6 layers of security.

7 Well, number one, if you call in on Arouse
8 server, you have to be authenticated through that. And
9 then you have to have a user name and password for the
10 ^DSCA/A host and be authenticated in there separately.

11 And there's also an audit trail, things like
12 that.

13 Q I think my question was much more simplistic
14 than all that. Once it was decided that somebody
15 should be on the system, they could be put on the
16 system.

17 A Yes.

18 Q Access it through the PCs on the desk?

19 A Right.

20 Q Up to some twenty unit limitation?

21 A Twenty right now. It could be expandable
22 but, right now, we're at twenty.

23 Q Is that based on a licensing with Teledyne?

24 A No, it's not. It's a matter of resources.

25 Q All right, thanks. You mentioned when we

1 were talking a little bit about starting up and you
2 were talking about the volume of the voided pipeline
3 and how -- is that something that calculations should
4 be done right then, as your pressure in the pipeline to
5 know?

6 Those are very quick calculations, right?
7 That you guys, the controllers, do all the time? So is
8 that something that would be done right then to see how
9 much time am I looking at before I start to see a
10 pressure build downstream?

11 A Well, you could calculate it pretty quickly,
12 I think, by just comparing how much -- what the over
13 the line balance is at the time that the line shut down
14 and then using that as a rough figure for what it
15 should take to fill it back up.

16 Q Okay, so you could look and see how much was
17 metered at point A, how much was metered at point B,
18 have that number readily available and get somebody to
19 do that, how much you needed to refill the pipeline?

20 A Should be able to get it off the green
21 sheets.

22 Q The green sheets would be?

23 A The operation's notes, I guess they call it.
24 It has all the hourly calculations.

25 Q So those numbers are recorded hourly?

1 A Yes, they are.

2 Q And each meter reading at each whatever end
3 of the pipeline segments?

4 A Right.

5 Q Or is it the take point and then the final
6 delivery point?

7 A Basically, the meter is in and the meter is
8 out. And, you know, some calculations back for line
9 fills and things like that. But, the over-short is
10 based on the meters in, the ins and the outs.

11 Q And that goes back to these manual
12 calculations I think we talked about at 8:05 this
13 morning. So, okay. I remember talking about this, so
14 thank you.

15 Are the profiles of the pipelines readily
16 available? Is that something the controllers can pull
17 up and take a look at the profile of the pipeline?

18 A Not electronically. They have profile
19 drawings that are in the control center that are
20 available and accessible.

21 Q You mentioned that the, you know, the
22 whatever happened to the computer had not really been
23 to your knowledge readily determined, what exactly
24 caused the slowdown to occur.

25 Is there any physical evidence that you're

1 aware of that documents that a slowdown did, indeed,
2 occur? I mean other than anecdotal evidence, talking
3 to people, is there any physical evidence?

4 A No, there isn't any evidence. There are ways
5 to monitor the system but they were done more or less
6 ad hoc. We weren't trying to capture data or anything
7 like that.

8 We weren't trying to, I mean, with hindsight,
9 a lot of people have said, "Well, don't you think that
10 that would have been a good idea?"

11 Well, of course, now we're all saying, yeah,
12 everybody would like to have that now. But, we weren't
13 doing anything like that.

14 Q Okay, so there are systems that could have
15 been operational that might have detected this thing
16 but you weren't set up for that?

17 A Well, it's not anything that you could run
18 full-time. There are monitor utilities in the
19 operating system that you can use and you can turn on
20 and you can have it run there.

21 It will show you the statistics of CPU idle
22 time and memory usage and IO. And all sorts of
23 statistics. But, you know, that consumes resources as
24 well.

25 So what I do now is I'll run it through a

1 baseline I would say 11 o'clock at night. And then
2 I'll run it for the same amount of time across
3 midnight. And then I can generate a hard copy report
4 from that.

5 And then I can compare and see, you know,
6 looking for trends, is it getting better? Is it
7 getting worse? Was it worse at midnight than it is at
8 11?

9 So that when people come to me and they say,
10 you know, "Seems like the computer was running slow the
11 other night at midnight, I've got a document on
12 performance history for midnight now, comparing the
13 two, like the 11 o'clock hour.

14 Q Okay, but that didn't exist then?

15 A It didn't exist at that time. Like I said,
16 not everybody was reporting it. It wasn't being
17 reported every day. It was like, you know, "This
18 happened to me, you know, several days ago" type of a
19 scenario.

20 Q And you mentioned when we were talking about
21 reopening the inlet valve to Bay View once it had
22 closed, you said you could open up the control valve --
23 and something or other.

24 I didn't catch that, I guess. You close the
25 control valve and open the block valve? I want to make

1 sure I understand you're closing which control valve
2 and opening what block valve.

3 Just step through that a little more?

4 A Right. The pressure switch is inside. It's
5 downstream of the pressure break, downstream of the
6 control valve. So, once the pressure is brought to
7 within normal bounds at the location of the switch,
8 then you can reset the facility which would allow you
9 to open the receiver inlet valve.

10 But, if you had a whole bunch of pressure
11 outside, it would just, you know, knock you back down
12 again. So what you can do is close the control valve
13 and then gradually let the product come into the
14 facility and control the repressuring that way.

15 Q Okay, on the flip side of that, that valve
16 would not reopen if you had pressure trapped within the
17 facility; right?

18 A Correct. You would not be allowed to reset
19 the facility.

20 Q So that would --

21 A Prevent you from opening the valve.

22 Q And that would require maybe a physical
23 person to go out and do something at the scene?

24 A Yes, the pressure would have to be manually
25 relieved from inside the facility.

1 INVESTIGATOR BESHORE: That's all I have.
2 Does anybody else have any follow-up questions? We'll
3 start with Patti.

4 MS. IMHOF: Okay. I seem to be the only
5 nontechnical person in the room, you can tell by the
6 questions I ask.

7 BY MS. IMHOF:

8 Q Did Olympic prior to June 10, 1999 have a
9 crisis management plan?

10 A Regarding, as far as?

11 Q What to do if you had a crisis, or what a
12 crisis was?

13 A Participating, you know, with the -- what do
14 you call it? -- ICS for spill response and ~~HAZLOPERING~~^{HAZWOPER}
15 and those types of issues.

16 Operations regarding earthquakes and storms
17 like that, they have procedures for those things, as
18 well as procedures for operating during periods of
19 communications, outages and all that kind of stuff.

20 Q So who within the Olympic organization had
21 the authority to recognize that you were experiencing
22 an emergency that required notification of local
23 authorities that there was a potentially serious
24 situation?

25 It sounds from listening to the people that

1 we've heard from the last couple of days, it sounds
2 like in the control room, the guys, the people in
3 there, knew that there was a potentially serious
4 problem going on.

5 And Lloyd called you at home and Ron was in
6 and out of the room and the controllers were talking to
7 Lloyd, and there was communication going on.

8 At what point, who would have had the
9 authority to say, "We need to call the field. We need
10 to call the City of Bellingham. We need to call
11 Ferndale." You know?

12 A I can't answer that question. With
13 hindsight, you know, you've got a lot of hindsight
14 going for you. But, without an indication of a threat
15 to the environment or an endangerment to the public,
16 there isn't any real reason to call any of those people
17 at this point.

18 Q Well, you kind of, it seems to me, had
19 identified that you had a potentially serious problem
20 going on because everyone was kind of talking amongst
21 themselves.

22 A We had a serious internal problem going on
23 with the computer hardware, but it was not an
24 indication that there was a release of product to the
25 environment at that point.

1 Q So the first time that you thought that there
2 was a serious problem going on was when you knew that
3 there was an --

4 A I wasn't there so I can't really answer that
5 question as to what point did they feel what. So I
6 can't answer that part of it.

7 INVESTIGATOR BESHORE: Let me try and help
8 out. I think what Patti is really getting at is at
9 what level of authority are people empowered to call
10 for assistance in the event of an emergency.

11 I mean does the controller have the authority
12 to call the local fire department if they feel like a
13 release has occurred?

14 Or is that a supervisory decision?

15 MR. SMITH: I think one of the prime
16 functions of the control center is to protect life and
17 property. So at any time that there is a suspicion
18 that either of those are at jeopardy that the control
19 center has the obligation to notify 911 or whatever.

20 INVESTIGATOR BESHORE: Does that get to the
21 question you were getting to, Patti?

22 MS. IMHOF: Yes.

23 INVESTIGATOR BESHORE: Okay, did you have any
24 further questions?

25 MS. IMHOF: No, I'm done.

1 INVESTIGATOR BESHORE: Let's go back to
2 Cliff. Did you have?

3 MR. ZIMMERMAN: Yes.

4 BY MR. ZIMMERMAN:

5 Q Yes, we've talked about these questions
6 referring to Olympic before the June 10 accident...

7 D
8 Did the SCA^DA system leak detection software
9 comply with API-1130 standard?

10 A 1130 wasn't I don't think in effect at that
11 point.

12 Q That's probably true. Does it comply now?

13 A I haven't done a review of it to see if it
14 does or not.

15 Q Do you work with that document?

16 A No, I have not.

17 Q That document was available before it became
18 a mandatory requirement. So did you have any
19 familiarity with it in the past?

20 A No.

21 Q There is the leak detection system -- not
22 does it now -- did it before then have the capability
23 to declare a leak?

24 A Yes.

25 Q And what type of indication would you get if
it declared a leak?

1 A There's one in here. If it's recorded or
2 not?

3 INVESTIGATOR BESHORE: It was about 1634.

4 MR. SMITH: 1634.

5 INVESTIGATOR BESHORE: If that helps, 1632,
6 right in that time frame.

7 MR. SMITH: You would get, it would say a
8 long PLDS, CHP and FER to BPT Alert. And that occurred
9 at 1629 and 22 seconds.

10 BY MR. ZIMMERMAN:

11 Q I'll probably have to put a time frame around
12 this but, in the past, has it missed any previous leaks
13 on the system?

14 Has there been a leak and the leak detection
15 system didn't declare a leak?

16 A Not to my knowledge, no.

17 Q Has it declared leaks when they don't exist?

18 A Yes.

19 Q Had you made any changes to the system before
20 the accident to make it more effective so it didn't
21 declare those leaks?

22 A Not that I can think of.

23 Q It didn't declare false leaks. Okay.

24 Have there been changes since the accident to
25 try to tune that part of the system?

1 A No.

2 Q Is the use of 300 ANSI rated fittings one of
3 the reasons that Bay View Station is designed like an
4 origin station rather than a booster station?

5 A I couldn't answer that.

6 Q We talked about that before. You mentioned
7 that it looked like an origin station. And that's
8 where my question comes from.

9 What reasons in your mind are there that it
10 is more like an origin station?

11 A Well, I said it's actually dual function. It
12 is a terminating function as being a terminal, and it
13 has an origin function on the discharge side.

14 And the characteristics of an origin is
15 having booster pumps discharge control valve, a meter
16 round and all the instrumentation that would go with
17 our typical pumping facility, origin facility, Cherry
18 Point, for example, Ferndale.

19 Q So, in the operation of this station, are
20 there booster pumps that are used when product is being
21 drawn out of tankage to feed the manual...

22 A The pumps that are at Bay View are considered
23 to be booster pumps. And that is what they're there
24 for, is to boost the product out of the tanks for the
25 mainline station at Allen.

1 Q Okay, so in this case, those pumps are
2 capable of drawing suction from a tank.

3 A Yes.

4 Q As well as taking suction from the main line?

5 A At the same time?

6 Q Not at the same time, no.

7 A Right.

8 Q Or taking suction from the main line if
9 that's where it's being fixed?

10 A Yes.

11 Q Not at the same time.

12 A Right.

13 MR. ZIMMERMAN: Okay. That's all I have.

14 INVESTIGATOR BESHORE: Anybody else? Peter?

15 MR. KATCHMARE: Todd, I've just got a couple
16 of other things.

17 BY MR. KATCHMARE.

18 Q Could you discuss the failure of the second
19 Woodinville pump to start on the SCADA^D event log it had
20 a failure there?

21 A Right.

22 Q Could you discuss that a little bit, what
23 that means?

24 A My understanding of what that means is when
25 the command was issued, for some reason that that data

1 circuit was not available. A conflict with another
2 control or a conflict with a scan coming in.

3 It happens occasionally.

4 Q And would the controller know that that
5 command did not -- wasn't ghost by the computer?

6 A Yes, it would be displayed as an alarm on the
7 alarm summary page.

8 Q If the controller then tried to reinitiate,
9 start that pump again because it didn't start, would
10 there be another net log?

11 A Yes, there would. Acknowledgment of the
12 alarm would make it clear off the alarm summary page.
13 But he would not have to acknowledge the alarm before
14 issuing another command. You would see the same
15 control sequence in events.

16 Q In other words, the controller request and
17 then a transmission or a failure?

18 A No operations is a control request and a
19 transmission followed by an execution of that device to
20 its final state.

21 Q So can we say for sure that he did not try to
22 start that Woodinville pump a second time?

23 A I don't think you can say that for sure.

24 Q Because of the time frame and what was going
25 on with the computers?

1 A Right. Yeah, I think that that is actually
2 the beginning of the sequence of events that occurred.
3 So I don't think you can rely too much on what was
4 going on from that point.

5 Q In your opinion, can we rely on the times of
6 these events on this event log other than perhaps the
7 immediate time when they failed over? You said there
8 could be some discrepancy in those times?

9 A In comparing this with what I've seen on some
10 of the trends, it looks like there could have been some
11 time skewing going on one way or the other.

12 But, it's inconclusive. The only thing that
13 you can say for sure is that the events were processed
14 in the order that they were received.

15 Q In this order.

16 A Yes.

17 Q Okay. How do you normally manually relieve
18 the pressure inside Bay View? How would one normally
19 relieve the pressure inside Bay View? You were just
20 talking to Allen about having to relieve the pressure
21 inside the station prior to opening the --

22 A Typically, I think what we've seen is more of
23 a transient pressure wave go through the facility as
24 opposed to just a build-up of pressure that doesn't go
25 away.

1 Q But you were discussing closing the control
2 valve? You could do that manually. And then you would
3 open the valve and bleed the pressure that's upstream
4 of the valve down?

5 A You would be able to reset the facility once
6 the pressure inside of Bay View where the pressure
7 switch is had decreased to within bounds of the set
8 point for that switch.

9 It's designed to protect Bay View, not the
10 piping upstream of Bay View because the rating of the
11 piping upstream of Bay View is, you know, far out..
12 than it was inside of Bay View.

13 The theory is that once the pressure subsides
14 inside facility, then you can close your control valve
15 and then open the inlet valve and then bleed the
16 pressure off the main line through the facility and get
17 things going again.

18 If you were for some reason to have a build-
19 up of pressure inside of Bay View, then you would have
20 to have somebody come out and, you know, open a drain
21 valve on the receiver, or something like that, I would
22 imagine.

23 I don't think that that's ever occurred
24 though.

25 Q I just know that people have been called out

1 to, you know, we have uncommanded changes of opening
2 this block valve on this SCADA event log.

3 And I was wondering, you know, kind of why
4 they have to physically, a human being had to go out
5 physically and open that valve.

6 A I don't know.

7 Q Do you feel comfortable with walking us
8 through the one graph on page 310? It was one that we
9 had looked at on the 16th I think when we all came
10 down.

11 Could you give him that one right there?

12 The one specific question I have there, Todd,
13 if you feel comfortable about talking about it -- I
14 know you're not a hydraulics engineer.

15 But, why don't you see the pressure that
16 occurred up around the relief valve just downstream of
17 1904 -- that's the red and the yellow there -- why
18 don't you see that at the discharge? The green line.

19 Why isn't it as high? If the pressure surge
20 is coming up from the south, and I understand you also
21 had pressure coming in, or flow coming in from the
22 north at that point?

23 A And you want to know why the pressure isn't
24 the same on one side of the station as it is on the
25 other?

1 Q Yes, why wouldn't you see that high pressure
2 downstream of control valve 1904 that you would see on
3 the green discharge?

4 A Well, if the control valve were to close on
5 the Ferndale inlet, then that would restrict the
6 pressure of coming into the facility while the pumps
7 continue to pump from Ferndale and increase the
8 pressure on that side; whereas, on the other side, if
9 you had pumps running at Allen, they would continue to
10 pull the product down on the downstream side of the
11 station.

12 Q Right. But I think at this point, wasn't the
13 pump at Bay View down? And the pumps at Allen down?

14 A Okay.

15 Q I'm just thinking they are. And I was just
16 wondering, if that's true, the first thing in the event
17 was you couldn't start the second Woodinville pump.
18 And then Bay View pump 201 went off. And then pressure
19 built up and the Allen pumps went off.

20 A Yes. Oh, I see the lines are pumping along
21 at a steady state. And then it looks like -- I can't
22 really tell by the colors here. But, one of them
23 appears to continue to be straight.

24 And then the yellow line and the other green
25 line start to increase. And, at some point, the

1 control valve is going to go closed on the incoming
2 side while the pumps are still running at Ferndale.

3 So that pressure is going to continue to
4 increase regardless of what's going on downstream.

5 So, even when the pumps shut off downstream,
6 you know, you're not putting any more product down
7 there. The only thing that's going to be left is the
8 hill pressure from, you know, whatever the highest hill
9 is south of Bay View.

10 Q Had you sat down with anybody and looked at
11 these pressures in more detail after the NTSB and DOE
12 and I came down and talked to you?

13 A The only ones I've seen in more detail are
14 those--

15 Q The other ones that are in the package?

16 A Right there.

17 Even with this here, we saw that the
18 Woodinville unit shut off at - what? 1530 and some
19 change. And that's down in here somewhere.

20 So there is a continual draw.

21 Q It was drawing away anyway, okay.

22 Todd, one last question. On this data event
23 log, if you look at just only two, it appears that the
24 batch was running from -- the gasoline batch from ARCO
25 delivering to Tosco had been running for some time.

1 A Okay.

2 Q And then they made the flying switch right
3 before this event occurred?

4 A Switching at Renton?

5 Q Yes, from Tosco to Seattle.

6 A Okay.

7 Q But I'm just talking about when they were
8 operating this line and taking the product from ARCO
9 and running it into the tanks across the street from
10 Renton at Tosco.

11 It doesn't appear that there's a whole lot,
12 if any, events logged for that time period from the
13 time they started it through to the time they did the
14 flying switch. Just before they did the flying switch.

15 A Right. That would have been a pretty, you
16 know, pretty stable operation. So not a lot of
17 activity going on.

18 The only thing of course is going to generate
19 events is, you know, pipeline activity.

20 Q Because it is normal -- that was my question.
21 Is it normal to not see really anything going on?

22 A Right. Right. I mean there's a lot of noise
23 going on in terms of events that don't have anything to
24 do with that pipeline segment. There's stuff going on
25 at Seatack. And there's another pipeline system

1 running.

2 And if you can filter out all the noise, I
3 think you would see that it's very difficult on a
4 system that's got a long delivery into one facility and
5 a long delivery coming into the pipeline from another
6 to, you know, pretty much be silent.

7 INVESTIGATOR BESHORE: Geoff.

8 MR. SMYTH: I have one question regarding
9 that then.

10 BY MR. SMYTH:

11 Q When did you actually stop? Have you been a
12 controller? You filled in for people on vacations
13 before June 10th? Is that correct?

14 Have you had the experience of doing this
15 swap, this Renton to Seattle swap when the Bay View
16 station has been on line?

17 A This swap is a routine switch. It's just a
18 routine switch. Hundreds of times.

19 Q Did you experience any more difficulty doing
20 it prior to Bay View coming on? Or after the Bay View
21 came on?

22 A I really don't have the knowledge base to say
23 whether it was harder or as hard. I think that we did
24 a comparison, didn't we, May 16, something like that,
25 of the very same switch.

1 Q Yes, but May 16, '99 was still after Bay
2 View. I mean, if you would have done something like
3 May of '98, then that might have a different --

4 A No, it's a routine switch, and we continue to
5 do the same switch. And it's a routine, routine
6 switch.

7 Q Like I was just kind of interested to know if
8 you or any of the other operators thought, since the
9 Bay View station came on line at that switch, maybe it
10 was routine, but was it any more difficult to handle as
11 an operator?

12 Did it take more intensive doing as from an
13 operator's standpoint, or a controller's?

14 A No, not that I've ever heard because it's
15 basically swing from Tosco to Seattle and turn on the
16 pump at Woodinville, you know. It's a pretty
17 straightforward operation.

18 MR. KATCHMARE: Okay, that's all I have.

19 INVESTIGATOR BESHORE: Linda.

20 MS. IMHOF: It's been real helpful for me to
21 hear your discussion about the reliability of the
22 clock, let's say, in the event log. Because that's
23 something that I've been really struggling with and
24 trying to understand.

25 BY MS. IMHOF:

1 Q One of the last things you said was that -- I
2 mean, if I understand correctly what you're saying, we
3 may not be able to rely exactly on the clocks here.
4 But you said that the events were processed in the
5 order that they were received.

6 A Right.

7 Q So we can rely on the sequence of events.
8 Maybe, they didn't occur exactly at that time, but they
9 occurred in that sequence.

10 A Well, actually, you can't even really rely on
11 that because it's a queue-based system, and so it
12 depends on when that information was first put on the
13 queue.

14 Once it gets on the queue, then it's going to
15 be processed in a specific order.

16 Q I want you to look at the specific sequence
17 of events. I'm wondering what you're thinking about
18 it.

19 But, at 1629, the leak detection alerted.

20 A Right.

21 Q Okay. And then at roughly 1630 there's a
22 controller request to start "phone" down unit three.

23 A Okay, I see that.

24 Q So my question is, is that telling us that
25 that controller started that unit after hearing the

1 leak detection alarm, or can we not rely on that?

2 A I, without talking to the controllers, I
3 would go with this, until I heard otherwise.

4 Q Okay, thanks.

5 A I mean, if we were talking a couple of
6 seconds difference, then, you know, maybe. But, it was
7 a minute.

8 MS. IMHOF: All right, thank you.

9 INVESTIGATOR BESHORE: Any other questions?

10 (A pause.)

11 MR. SMITH: Ah, good. That is an answer.

12 (Laughter.)

13 INVESTIGATOR BESHORE: Geoff.

14 MR. SMYTH: I promise it will be brief. I
15 just want to go back. I marked as page 310 as Exhibit
16 T. Smith No. 8. And I just want to give it back to you
17 because I've got a couple of quick questions on this
18 that I think might clarify a couple of things.

19 BY MR. SMYTH:

20 Q One, is the green line there that's
21 identified as Ferndale discharge, is that -- is that a
22 pressure that's upstream in the Ferndale discharge?

23 Am I correct in that?

24 A Right. Well, first of all, to qualify
25 myself, this is from a Wonderware OMI in the field,

1 which is not anything that I'm really familiar with.
2 But what's giving me the problem is that we seem to
3 have two shades of green going on here.

4 And I can't with my eyes distinguish readily
5 here, you know, which one is which.

6 Q And I was looking at one as being black and
7 the other is green.

8 A Is that what it is?

9 Q That's just my eyes.

10 The other thing I guess I would...

11 INVESTIGATOR BESHORE: Is this the discharge
12 at Ferndale? Is the green the discharge at Ferndale or
13 the discharge at Bay View on the Ferndale line?

14 They told me this was discharge at Bay View
15 on the Ferndale line.

16 MR. SMITH: That's what it should be.

17 INVESTIGATOR BESHORE: Okay, that's the green
18 line.

19 MR. SMITH: It should be the green line.

20 MR. KATCHMARE: Yes, and then the black goes
21 up.

22 MR. BESHORE: All right. And then I just
23 want to note that that's identified as Bay View
24 terminal PLC. So that data is not --

25 MR. SMITH: Right.

1 MR. BESHORE: That data is not necessarily
2 available in the control center; is that correct?

3 MR. SMITH: It is absolutely not available in
4 the control center. And, in fact, this is outside the
5 scope of my expertise, so I would want to talk with the
6 PLC about that, about what these tags actually are.

7 MR. BESHORE: Who would that be?

8 MR. SMITH: Ken Huff.

9 MR. BESHORE: We have him on our list.
10 Then, another question.

11 BY MR. BESHORE:

12 Q You mentioned time-skewing and I just wanted
13 to make sure I understood what you mentioned there.
14 Was that in terms of the times of the events not
15 necessarily being the correct time? Was that because
16 of a difference in clocks between --

17 A I think, number one, the difference in the
18 clocks. But, if you try to lay some of those trends
19 over one another, you'll find that there's a little bit
20 of differences in the times on those as well.

21 So I'm not sure exactly what's going on
22 there.

23 Q Okay, and I think my last question is
24 relatively simple. It's basically is there anything
25 else that we haven't asked you about that you're aware



National Transportation Safety Board

Washington, D.C. 20594

In the Matter of the National Transportation Safety
Board Investigation of the Pipeline Accident Occurring
in Bellingham, Washington, on June 10, 1999.

COMPULSION ORDER

It appearing to the satisfaction of the Chairman of the National Transportation Safety Board:

1. That Todd Smith has been called to testify or provide other information in this matter;
2. That Todd Smith has refused or is likely to refuse to testify or provide other information, on the basis of his privilege against self-incrimination;
3. That in the judgment of the Chairman of the National Transportation Safety Board, the testimony or other information from Todd Smith may be necessary to the public interest; and
4. That this order has been issued with the approval of the Attorney General or her designated representative, pursuant to 18 USC Section 6003 and 28 CFR Section 0.175.

NOW, THEREFORE, IT IS ORDERED, pursuant to 18 USC Section 6002 and 6004, that Todd Smith appear and give testimony or provide other information which he has refused or is likely to refuse to provide or give on the basis of his privilege against self-incrimination as to all matters about which he may be questioned in this matter.

IT IS FURTHER ORDERED that in accordance with the provisions of 18 USC Section 6002, Todd Smith shall forever be immune from the use of such testimony or information or any information directly or indirectly derived from such testimony against him in any prosecution, penalty or forfeiture, either State or Federal or otherwise; but the witness shall not be exempt from prosecution for perjury, giving a false statement or contempt committed while giving testimony or producing evidence under this order.

Dated this 12th day of September, 2000.



Jim Hall
Chairman

Exhibit T. Smith # 1

Lotus cc:Mail for todd smith

Date: 3/2/99
Sender: Ron Brentson
To: Lloyd Tieken; Tracy Greene; #Dispatch
cc: Ken Huff; David Justice; Perry Dalaba; Holly Williamson; Deanna Oien
Priority: Normal
Subject: Re: Bayview Backpressure settings on meter run control valves

Author: Ron Brentson at renton_opl
Date: 3/2/99 2:49:11 PM
Priority: Normal
To: Lloyd Tieken
cc: Ken Huff
cc: David Justice
cc: Perry Dalaba
cc: Holly Williamson
cc: Deanna Oien
To: Tracy Greene
To: Mail List - #Dispatch
Subject: Re: Bayview Backpressure settings on meter run control valves

Ken,
I would like to bring this setpoint back to the control center access and control when/where appropriate. Please work with Todd to set up... Thanks

Reply Separator

Subject: Bayview Backpressure settings on meter run control valves
Author: Lloyd Tieken
Date: 2/23/99 5:23 PM

For your information

Under certain operational profiles while tight lining through Bayview facility (*Max rate-low psi*) the backpressure control valve (*for maintaining meter psi*) has come into play restricting flow and shutting the pipeline down.

I spoke with Ken Huff and he has agreed (*at least temporarily*) to reduce the setpoint from 20 psi to 10 psi.

Your feedback will be appreciated....

Lloyd Tieken

0002649 ACB
CONFIDENTIAL
DO NOT COPY

Exhibit Smith #2

Date: 3/10/99
Sender: Craig Hammett
To: Wally Stevenson
Priority: Normal
Subject: FW: Re[3]:Bayview Backpressure settings on meter run cont...
Subject: FW: Re[3]:Bayview Backpressure settings on meter run control val

Any comments on the need to hold 10# min backpressure on the Bayview incoming meters? I thought I should get your input before I talk to Ron.

-----Original Message-----

From: Ron Brentson
Sent: Wednesday, March 10, 1999 9:30 AM
To: Ken Huff
Cc: Craig Hammett; Todd Smith; Lloyd Tieken
Subject: Re[3]:Bayview Backpressure settings on meter run control val

I am aware that the O/C has never had control of this setpoint. I want control of this setpoint into the control center SCADA for purposes of infrequent scenarios that the only way to achieve a specific hydraulic condition on the system is to reduce this setpoint to zero and basically get it out of the way. The norm is to run with minimum back pressures to achieve line integrity metering capacity without resulting in unstable line conditions. Three control valves on each system within Bayview is about 2 to many in many cases.

I will speak directly to Craig regarding this change but very honestly, this is an operations issue and my responsibility to insure the safe and efficient method to achieve desired flow.

Reply Separator

Subject: Re[2]:Bayview Backpressure settings on meter run control val
Author: Ken Huff
Date: 3/3/99 8:47 AM

O/C never had control of this setpoint. If we can't keep at least 10lbs on the meter why do we have it at all. Also if that 10lbs is a problem now, how are we going to run floating a tank with maybe 3lbs of suction to the units. Before I change the setpoint control I would like you to run it though my boss.

Thanks
Ken

0002653

ACB
CONFIDENTIAL
DO NOT COPY

Exhibit T. Smith #3

8-Jun-1999	08:21:22.03	ALARM	PLDS	PLDS SYSTEM CRASH	ALERT	
8-Jun-1999	08:40:19.04	ALARM	PLDS	PLDS SYSTEM CRASH	NORMAL	
10-Jun-1999	15:27:47.01	ALARM	SYSTEM	Backup CPU Status	OFFLINE	
10-Jun-1999	15:27:48.02	EVENT	SYSTEM	VCS STARTUP		
10-Jun-1999	15:28:00.05	ALARM	SEATAC.2	COMMUNICATIONS	FAIL	
10-Jun-1999	15:28:03.06	ALARM	OLYMPIA.JCT	COMMUNICATIONS	FAIL	
10-Jun-1999	15:28:04.07	ALARM	BAYVIEW	COMMUNICATIONS	FAIL	
10-Jun-1999	15:28:05.08	UNCMDCHG	BAYVIEW	FER-BPT RECEIVER INLET	CLOSE	
10-Jun-1999	15:28:05.09	NORMAL	SEATAC.1	TANK 108	NORMAL	3329
10-Jun-1999	15:28:05.10	NORMAL	SEATAC.1	TANK 109	NORMAL	500
10-Jun-1999	15:28:05.11	NORMAL	SEATAC.1	TANK 111	NORMAL	499
10-Jun-1999	15:28:05.12	UNCMDCHG	BAYVIEW	FER BYPASS TO PUMPS	CLOSE	
10-Jun-1999	15:28:05.13	NORMAL	SEATAC.1	TANK 112	NORMAL	501
10-Jun-1999	15:28:05.14	NORMAL	SEATAC.1	TANK 113	NORMAL	3486
10-Jun-1999	15:28:05.15	NORMAL	SEATAC.1	TANK 114	NORMAL	494
10-Jun-1999	15:28:05.16	NORMAL	SEATAC.1	TANK 115	NORMAL	2311
10-Jun-1999	15:28:05.19	ALARM	BAYVIEW	FER-ALN SCRAPER OUT	OUT	
10-Jun-1999	15:28:06.17	UNCMDCHG	ALLEN.1	16" UNIT 1 STATUS	SHUTDOWN	
10-Jun-1999	15:28:06.18	UNCMDCHG	ALLEN.1	16" UNIT 3 STATUS	SHUTDOWN	
10-Jun-1999	15:28:06.20	NORMAL	ALLEN.1	TANK 101	NORMAL	679
10-Jun-1999	15:28:06.22	NORMAL	OLYMPIA.DF	TANK 104	NORMAL	3753
10-Jun-1999	15:28:06.23	UNCMDCHG	ALLEN.1	16" STATION STATUS	SHUTDOWN	
10-Jun-1999	15:28:10.21	NORMAL	SEATAC.2	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:28:10.24	NORMAL	RENTON.1	TANK 116	NORMAL	794
10-Jun-1999	15:28:12.27	NORMAL	VANCOUVER.DF	TANK 107	NORMAL	2960
10-Jun-1999	15:28:12.29	ALARM	BAYVIEW	FER-BPT METER PSI	LOW	0
10-Jun-1999	15:28:12.30	ALARM	BAYVIEW	FER-BPT METER PSI	LOW LOW	0
10-Jun-1999	15:28:12.31	ALARM	BAYVIEW	FER-BPT UPSTREAM PSI	LOW	0
10-Jun-1999	15:28:13.25	ALARM	MILEPOST.66	UPSTREAM PSI 16	MINUSROC	123
10-Jun-1999	15:28:13.26	ALARM	MILEPOST.66	DOWNSTREAM PSI 16	MINUSROC	122
10-Jun-1999	15:28:14.28	NORMAL	BAYVIEW	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:28:14.32	ALARM	SEATTLE.DF	GROSS FLW RATE SET POINT	HIGH	10000
10-Jun-1999	15:28:16.33	NORMAL	TACOMA.DF	TANK 103	NORMAL	2584
10-Jun-1999	15:28:16.34	NORMAL	SEATTLE.DF	TANK 102	NORMAL	3742
10-Jun-1999	15:28:17.35	NORMAL	OLYMPIA.JCT	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:28:17.36	ALARM	CHERRY.POINT	SUCTION PRESSURE	LOW	0
10-Jun-1999	15:28:17.37	ALARM	CHERRY.POINT	METER PRESSURE	LOW	0
10-Jun-1999	15:28:17.38	NORMAL	PORTLAND.DF	TANK 106	NORMAL	6376
10-Jun-1999	15:28:17.39	NORMAL	PORTLAND.DF	TANK 105	NORMAL	6966
10-Jun-1999	15:28:21.40	ALARM	MILEPOST.46	UPSTREAM PSI 16	MINUSROC	166
10-Jun-1999	15:28:21.41	ALARM	MILEPOST.46	DOWNSTREAM PSI 16	MINUSROC	167
10-Jun-1999	15:28:22.42	ALARM	MILEPOST.56	UPSTREAM PSI 16	MINUSROC	148
10-Jun-1999	15:28:22.43	ALARM	MILEPOST.56	DOWNSTREAM PSI 16	MINUSROC	149
10-Jun-1999	15:28:24.44	CHANGE	SEATAC.2	UNIT 2 STATUS	SHUTDOWN	
10-Jun-1999	15:28:24.45	CLEAR	BAYVIEW	FER-BPT API GRAVITY @ 60	ROC +/-	0.2
10-Jun-1999	15:28:24.46	CLEAR	BAYVIEW	FER-BPT RECEIVER PSI	HI HI	613
10-Jun-1999	15:28:24.47	CLEAR	BAYVIEW	FER-BPT RECEIVER PSI	HIGH	613
10-Jun-1999	15:28:24.48	NORMAL	BAYVIEW	FER-BPT RECEIVER PSI	NORMAL	613
10-Jun-1999	15:28:25.49	ALARM	CHERRY.POINT	LOW SUCTION	ALARM	
10-Jun-1999	15:28:25.50	UNCMDCHG	CHERRY.POINT	UNIT 1 STATUS	SHUTDOWN	
10-Jun-1999	15:28:25.51	CHANGE	CHERRY.POINT	UNIT 1 DISCHARGE	TRAVEL	
10-Jun-1999	15:28:25.52	CLEAR	CHERRY.POINT	SUCTION PRESSURE	LOW	106
10-Jun-1999	15:28:25.53	NORMAL	CHERRY.POINT	SUCTION PRESSURE	NORMAL	106
10-Jun-1999	15:28:25.54	CLEAR	CHERRY.POINT	METER PRESSURE	LOW	106
10-Jun-1999	15:28:25.55	NORMAL	CHERRY.POINT	METER PRESSURE	NORMAL	106
10-Jun-1999	15:28:27.56	ALARM	FERNDALE	LOW SUCTION PRESSURE	ALARM	
10-Jun-1999	15:28:27.57	UNCMDCHG	FERNDALE	UNIT 2 STATUS	SHUTDOWN	
10-Jun-1999	15:28:27.58	UNCMDCHG	FERNDALE	UNIT 3 STATUS	SHUTDOWN	
10-Jun-1999	15:28:27.59	ALARM	FERNDALE	MECHANICAL	ALARM	
10-Jun-1999	15:28:27.60	ALARM	FERNDALE	SUCTION PRESSURE	LOW	0
10-Jun-1999	15:28:27.61	ALARM	FERNDALE	SUCTION PRESSURE	LOW LOW	0
10-Jun-1999	15:28:27.62	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW	13
10-Jun-1999	15:28:27.63	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW	13
10-Jun-1999	15:28:27.64	ALARM	FERNDALE	DRA PUMP INHIBIT	ON	0000001

Exhibit T. Smith # 4

10-Jun-1999	15:28:30.65	CLEAR	MILEPOST.66	UPSTREAM PSI 16	ROC +/-	6
10-Jun-1999	15:28:30.66	CLEAR	MILEPOST.66	DOWNSTREAM PSI 16	ROC +/-	6
10-Jun-1999	15:28:34.67	NORMAL	CHERRY.POINT	LOW SUCTION	RESET	
10-Jun-1999	15:28:35.68	ALARM	FERNDALE	LOW SUCTION PRESSURE	RESET	
10-Jun-1999	15:28:35.69	UNCMDCHG	FERNDALE	UNIT 1 STATUS	SHUTDOWN	
10-Jun-1999	15:28:35.70	ALARM	FERNDALE	MECHANICAL	RESET	
10-Jun-1999	15:28:35.71	ALARM	FERNDALE	CONTROL PRESSURE	LOW	148
10-Jun-1999	15:28:35.72	ALARM	FERNDALE	CONTROL PRESSURE	LOW LOW	148
10-Jun-1999	15:28:35.73	ALARM	FERNDALE	DISCHARGE PRESSURE	LOW	142
10-Jun-1999	15:28:35.74	ALARM	FERNDALE	DISCHARGE PRESSURE	LOW LOW	142
10-Jun-1999	15:28:35.75	CLEAR	FERNDALE	SUCTION PRESSURE	LOW LOW	142
10-Jun-1999	15:28:35.76	CLEAR	FERNDALE	SUCTION PRESSURE	LOW	142
10-Jun-1999	15:28:35.77	NORMAL	FERNDALE	SUCTION PRESSURE	NORMAL	142
10-Jun-1999	15:28:35.78	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW	150
10-Jun-1999	15:28:35.79	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW	150
10-Jun-1999	15:28:35.80	NORMAL	FERNDALE	CHERRY POINT IN PSI	NORMAL	150
10-Jun-1999	15:28:37.81	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	CLOSE	
10-Jun-1999	15:28:42.82	CLEAR	MILEPOST.46	UPSTREAM PSI 16	ROC +/-	8
10-Jun-1999	15:28:42.83	CLEAR	MILEPOST.46	DOWNSTREAM PSI 16	ROC +/-	8
10-Jun-1999	15:28:43.84	CLEAR	MILEPOST.56	UPSTREAM PSI 16	ROC +/-	9
10-Jun-1999	15:28:43.85	CLEAR	MILEPOST.56	DOWNSTREAM PSI 16	ROC +/-	9
10-Jun-1999	15:28:44.86	CHANGE	CHERRY.POINT	UNIT 1 SUCTION	TRAVEL	
10-Jun-1999	15:28:44.87	ALARM	BAYVIEW	FER-BPT API GRAVITY @ 60	PLUSROC	0.4
10-Jun-1999	15:28:51.90	CLEAR	BAYVIEW	FER-BPT API GRAVITY @ 60	ROC +/-	0.0
10-Jun-1999	15:29:03.20	ALARM	FERNDALE	SUCTION PRESSURE	LOW	29
10-Jun-1999	15:29:03.21	ALARM	FERNDALE	SUCTION PRESSURE	LOW LOW	29
10-Jun-1999	15:29:03.30	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW	39
10-Jun-1999	15:29:03.88	ALARM	FERNDALE	LOW SUCTION PRESSURE	ALARM	
10-Jun-1999	15:29:03.92	ALARM	FERNDALE	MECHANICAL	ALARM	
10-Jun-1999	15:29:12.89	CNTL REQ	WOODINVILLE	CONSOLE 11 CAI	STOP	
10-Jun-1999	15:29:18.91	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:21.93	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:23.94	TO FINAL	WOODINVILLE	UNIT 1 STATUS	RUN	
10-Jun-1999	15:29:24.95	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:27.96	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:29.97	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:31.98	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:33.99	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:35	TRANSMIT	WOODINVILLE	UNIT 1 STATUS	SHUTDOWN	
10-Jun-1999	15:29:35.01	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:36.02	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		100
10-Jun-1999	15:29:37.03	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:40.04	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:41.05	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:45.06	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		150
10-Jun-1999	15:29:46.07	CNTL REQ	SEATTLE.DF	CONSOLE 11 CAI	INC	
10-Jun-1999	15:29:51.08	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		200
10-Jun-1999	15:29:57.31	ALARM	MILEPOST.89	UPSTREAM PSI 16	MINUSROC	119
10-Jun-1999	15:29:57.32	ALARM	MILEPOST.89	DOWNSTREAM PSI 16	MINUSROC	119
10-Jun-1999	15:29:58.09	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		250
10-Jun-1999	15:30:06.10	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		300
10-Jun-1999	15:30:13.11	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		350
10-Jun-1999	15:30:22.12	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		400
10-Jun-1999	15:30:29.13	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		450
10-Jun-1999	15:30:34.14	CNTL REQ	WOODINVILLE	CONSOLE 11 CAI	STOP	
10-Jun-1999	15:30:35.15	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		500
10-Jun-1999	15:30:35.16	CHANGE	CHERRY.POINT	UNIT 1 SUCTION	CLOSE	
10-Jun-1999	15:30:35.17	CHANGE	CHERRY.POINT	UNIT 1 DISCHARGE	CLOSE	
10-Jun-1999	15:30:35.18	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	OPEN	
10-Jun-1999	15:30:36.19	ALARM	FERNDALE	LOW SUCTION PRESSURE	RESET	
10-Jun-1999	15:30:36.24	ALARM	FERNDALE	MECHANICAL	RESET	
10-Jun-1999	15:30:41.22	TRANSMIT	WOODINVILLE	UNIT 1 STATUS	SHUTDOWN	
10-Jun-1999	15:30:41.23	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		550
10-Jun-1999	15:30:47.33	ALARM	MILEPOST.89	UPSTREAM PSI 16	MINUSROC	127

000000

10-Jun-1999	15:30:48.25	TO FINAL	WOODINVILLE	UNIT 1 STATUS	RUN	
10-Jun-1999	15:30:50.26	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		600
10-Jun-1999	15:30:58.27	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		650
10-Jun-1999	15:31:04.28	UNCMDCHG	WOODINVILLE	UNIT 1 STATUS	SHUTDOWN	
10-Jun-1999	15:31:04.29	ALARM	WOODINVILLE	DRA PUMP INHIBIT	ON	
10-Jun-1999	15:33:45.34	CHANGE	CHERRY.POINT	METER FLOW STATUS	IN PROG.	
10-Jun-1999	15:33:45.35	ALARM	CHERRY.POINT	LOW SUCTION	ALARM	
10-Jun-1999	15:33:51.36	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	CLOSE	
10-Jun-1999	15:34:17.37	CNTL REQ	SEATTLE.DF	CONSOLE 2 CAI		700.00

000000

10-Jun-1999	13:10:23.89	TRANSMIT	TACOMA.JCT	8" PRESSURE SP ENTRY		64
10-Jun-1999	13:10:24.90	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		1830
10-Jun-1999	13:10:25.91	CNTL REQ	TACOMA.DF	CONSOLE 5 CAI	DEC	
10-Jun-1999	13:10:27.92	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		1820
10-Jun-1999	13:10:28.93	CNTL REQ	TACOMA.JCT	CONSOLE 5 CAI	DEC	
10-Jun-1999	13:10:31.94	TRANSMIT	TACOMA.JCT	8" PRESSURE SP ENTRY		62
10-Jun-1999	13:10:39.95	TO FINAL	VANCOUVR.JCT	V-1091 LATERAL LINE IN	TRAVEL	
10-Jun-1999	13:10:42.96	UNCMDCHG	VANCOUVR.JCT	V-1091 LATERAL LINE IN	OPEN	
10-Jun-1999	13:10:48.97	CNTL REQ	VANCOUVR.JCT	CONSOLE 5 CAI	CLOSE	
10-Jun-1999	13:10:50.98	TRANSMIT	VANCOUVR.JCT	V-1091 LATERAL LINE IN	CLOSE	
10-Jun-1999	13:11:16.99	ALARM	CASTLE.ROCK	DISCHARGE PRESSURE	HIGH	1442
10-Jun-1999	13:11:18	TRANSMIT	OLYMPIA.JCT	DRA SET POINT - GPH		6
10-Jun-1999	13:11:18.01	TRANSMIT	RENTON	DRA SET POINT - GPH		8
10-Jun-1999	13:11:19.02	TRANSMIT	CASTLE.ROCK	DRA SET POINT - GPH		5
10-Jun-1999	13:11:23.03	CLEAR	CASTLE.ROCK	DISCHARGE PRESSURE	HIGH	1437
10-Jun-1999	13:11:23.04	NORMAL	CASTLE.ROCK	DISCHARGE PRESSURE	NORMAL	1437
10-Jun-1999	13:11:44.05	TO FINAL	VANCOUVR.JCT	V-1091 LATERAL LINE IN	TRAVEL	
10-Jun-1999	13:11:47.06	UNCMDCHG	VANCOUVR.JCT	V-1091 LATERAL LINE IN	CLOSE	
10-Jun-1999	13:13:52.07	CHANGE	SEATAC.2	UNIT 3 STATUS	RUN	
10-Jun-1999	13:14:18.08	TRANSMIT	RENTON	DRA SET POINT - GPH		8
10-Jun-1999	13:14:51.09	ALARM	OLYMPIA.JCT	CONTROL PRESSURE	HIGH	1727
10-Jun-1999	13:15:07.10	CNTL REQ	TACOMA.STA	CONSOLE 6 CAI		1300.00
10-Jun-1999	13:15:09.11	TRANSMIT	TACOMA.STA	DISCHARGE PSI SP ENTRY		1300
10-Jun-1999	13:15:13.12	CNTL REQ	TACOMA.STA	CONSOLE 5 CAI	DEC	
10-Jun-1999	13:15:15.13	TRANSMIT	TACOMA.STA	DISCHARGE PSI SP ENTRY		1270
10-Jun-1999	13:15:25.14	CNTL REQ	TACOMA.JCT	CONSOLE 5 CAI	INC	
10-Jun-1999	13:15:28.15	TRANSMIT	TACOMA.JCT	8" PRESSURE SP ENTRY		64
10-Jun-1999	13:15:32.16	CLEAR	BAYVIEW	ANA-BPT UPSTREAM PSI	LOW	31
10-Jun-1999	13:15:32.17	NORMAL	BAYVIEW	ANA-BPT UPSTREAM PSI	NORMAL	31
10-Jun-1999	13:15:34.18	CHANGE	SEATAC.2	UNIT 4 STATUS	RUN	
10-Jun-1999	13:16:08.19	CLEAR	OLYMPIA.JCT	CONTROL PRESSURE	HIGH	1719
10-Jun-1999	13:16:08.20	NORMAL	OLYMPIA.JCT	CONTROL PRESSURE	NORMAL	1719
10-Jun-1999	13:16:18.21	TRANSMIT	RENTON	DRA SET POINT - GPH		8
10-Jun-1999	13:22:36.22	CHANGE	SEATAC.2	UNIT 2 STATUS	SHUTDOWN	
10-Jun-1999	13:23:41.23	CHANGE	SEATAC.2	UNIT 1 STATUS	RUN	
10-Jun-1999	13:25:05.24	CNTL REQ	TACOMA.DF	CONSOLE 5 CAI	CHANGE	
10-Jun-1999	13:25:05.25	NOTICE:	TACOMA.DF	TACIBTCHCHNGSTATUS IS CHANGE	CONTINUE...	
10-Jun-1999	13:25:07.26	TRANSMIT	TACOMA.DF	BATCH CHANGE	COMPLETE	
10-Jun-1999	13:25:09.27	EXECUTE	TACOMA.DF	BATCH CHANGE	COMPLETE	
10-Jun-1999	13:25:09.28	ALARM	TACOMA.DF	PRINT SWITCH	IN PROG.	
10-Jun-1999	13:25:09.29	ALARM	TACOMA.DF	BATCH CHANGE	IN PROG.	
10-Jun-1999	13:25:09.30	CHANGE	TACOMA.DF	BTCH BLK-->RTU DOWNLOAD	READY	
10-Jun-1999	13:25:09.31	CNTL REQ	TACOMA.DF	CONSOLE 0	READY	
10-Jun-1999	13:25:10.32	EXECUTE	TACOMA.DF	MASTER --> RTU DOWNLOAD	READY	SUCCESS
10-Jun-1999	13:25:13.33	CHANGE	TACOMA.DF	CALCULATED BATCH	TOTL VOL	10030.3
10-Jun-1999	13:25:13.34	CHANGE	TACOMA.DF	CALCULATED BATCH	WTAVG GR	56.1
10-Jun-1999	13:25:13.35	CHANGE	TACOMA.DF	FLOW COMPUTER BATCH	TOTL VOL	10029.0
10-Jun-1999	13:25:13.36	CHANGE	TACOMA.DF	FLOW COMPUTER BATCH	WTAVG GR	55.0
10-Jun-1999	13:25:14.37	NORMAL	TACOMA.DF	PRINT SWITCH	COMPLETE	
10-Jun-1999	13:25:14.38	CNTL REQ	TACOMA.DF	CONSOLE 0	RESET	
10-Jun-1999	13:25:15.39	CHANGE	TACOMA.DF	FLOW COMPUTER DELIVERY	TOTL VOL	1424.0
10-Jun-1999	13:25:15.40	CHANGE	TACOMA.DF	FLOW COMPUTER DELIVERY	WTAVG GR	55.0
10-Jun-1999	13:25:15.41	CHANGE	TACOMA.DF	CALCULATED DELIVERY	TOTL VOL	1427.7
10-Jun-1999	13:25:15.42	CHANGE	TACOMA.DF	CALCULATED DELIVERY	WTAVG GR	55.9
10-Jun-1999	13:25:17.43	TRANSMIT	TACOMA.DF	RESET ACCUM B PSEUDO	RESET	
10-Jun-1999	13:25:19.44	NORMAL	TACOMA.DF	BATCH CHANGE	COMPLETE	
10-Jun-1999	13:25:19.45	CHANGE	TACOMA.DF	BTCH BLK-->RTU DOWNLOAD	COMPLETE	
10-Jun-1999	13:25:44.46	EXECUTE	TACOMA.DF	RESET ACCUM B PSEUDO	RESET	
10-Jun-1999	13:25:44.47	CHANGE	TACOMA.DF	BATCH REPORT	READY	
10-Jun-1999	13:25:44.48	CNTL REQ	TACOMA.DF	CONSOLE 0	READY	
10-Jun-1999	13:25:44.49	EXECUTE	TACOMA.DF	BATCH REPORT	COMPLETE	
10-Jun-1999	13:25:45.50	EVENT	TACOMA.DF	BATCH REPORT TACDBT09	RECEIVED	
10-Jun-1999	13:25:50.51	CHANGE	TACOMA.DF	BATCH REPORT	COMPLETE	
10-Jun-1999	13:25:57.52	CHANGE	TACOMA.DF	DELIVERY REPORT	READY	

0000046

0-Jun-1999	13:25:58.53	CNTL REQ	TACOMA.DF	CONSOLE 0	READY	
0-Jun-1999	13:25:58.54	EXECUTE	TACOMA.DF	DELIVERY REPORT	COMPLETE	
0-Jun-1999	13:25:59.55	EVENT	TACOMA.DF	DELIVERY REPORT TACDDL04	RECEIVED	
0-Jun-1999	13:26:04.56	CHANGE	TACOMA.DF	DELIVERY REPORT	COMPLETE	
0-Jun-1999	13:26:14.57	CHANGE	SEATAC.2	UNIT 3 STATUS	SHUTDOWN	
0-Jun-1999	13:27:17.58	CHANGE	SEATAC.2	TR POSITION 8 DISABLE	ON	
0-Jun-1999	13:28:25.59	CHANGE	SEATAC.2	UNIT 2 STATUS	RUN	
0-Jun-1999	13:28:34.60	PREV VAL	CASTLE.ROCK	CONSOLE 6 CAI		15.000
0-Jun-1999	13:28:34.61	ENTRY	CASTLE.ROCK	DRA SET POINT - PPM	EU	18
0-Jun-1999	13:29:18.62	CHANGE	SEATAC.2	TR POSITION 4 DISABLE	ON	
0-Jun-1999	13:29:19.63	TRANSMIT	CASTLE.ROCK	DRA SET POINT - GPH		6
0-Jun-1999	13:29:37.64	CHANGE	SEATAC.2	TR POSITION 2 DISABLE	ON	
0-Jun-1999	13:29:37.65	CHANGE	SEATAC.2	TR POSITION 3 DISABLE	ON	
0-Jun-1999	13:29:41.66	CHANGE	SEATAC.2	UNIT 4 STATUS	SHUTDOWN	
0-Jun-1999	13:29:41.67	CHANGE	SEATAC.2	TR POSITION 1 DISABLE	ON	
0-Jun-1999	13:29:48.68	CHANGE	SEATAC.2	UNIT 1 STATUS	SHUTDOWN	
0-Jun-1999	13:29:59.69	CHANGE	SEATAC.2	TR POSITION 7 DISABLE	ON	
0-Jun-1999	13:30:29.70	CHANGE	SEATAC.2	TR POSITION 5 DISABLE	ON	
0-Jun-1999	13:30:37.71	CHANGE	SEATAC.2	TR POSITION 6 DISABLE	ON	
0-Jun-1999	13:31:42.72	CHANGE	SEATAC.2	TR POSITION 1 DISABLE	OFF	
0-Jun-1999	13:31:42.73	CHANGE	SEATAC.2	TR POSITION 2 DISABLE	OFF	
0-Jun-1999	13:31:48.74	CHANGE	SEATAC.2	TR POSITION 3 DISABLE	OFF	
0-Jun-1999	13:31:48.75	CHANGE	SEATAC.2	TR POSITION 4 DISABLE	OFF	
0-Jun-1999	13:32:01.76	CHANGE	SEATAC.2	TR POSITION 1 DISABLE	ON	
0-Jun-1999	13:32:01.77	CHANGE	SEATAC.2	TR POSITION 2 DISABLE	ON	
0-Jun-1999	13:32:01.78	CHANGE	SEATAC.2	TR POSITION 3 DISABLE	ON	
0-Jun-1999	13:32:01.79	CHANGE	SEATAC.2	TR POSITION 4 DISABLE	ON	
0-Jun-1999	13:32:05.80	CHANGE	SEATAC.2	TR POSITION 7 DISABLE	OFF	
0-Jun-1999	13:32:05.81	CHANGE	SEATAC.2	TR POSITION 8 DISABLE	OFF	
0-Jun-1999	13:32:31.82	CNTL REQ	TACOMA.DF	CONSOLE 6 CAI		1755.00
0-Jun-1999	13:32:32.83	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		1755
0-Jun-1999	13:32:50.84	CHANGE	SEATAC.2	UNITED DISABLE	ON	
0-Jun-1999	13:32:50.85	CHANGE	SEATAC.2	TR POSITION 8 DISABLE	ON	
0-Jun-1999	13:33:12.86	CHANGE	SEATAC.2	UNIT 2 STATUS	SHUTDOWN	
0-Jun-1999	13:33:12.87	CHANGE	SEATAC.2	TR POSITION 1 DISABLE	OFF	
0-Jun-1999	13:33:12.88	CHANGE	SEATAC.2	TR POSITION 2 DISABLE	OFF	
0-Jun-1999	13:33:12.89	CHANGE	SEATAC.2	TR POSITION 3 DISABLE	OFF	
0-Jun-1999	13:33:12.90	CHANGE	SEATAC.2	TR POSITION 4 DISABLE	OFF	
0-Jun-1999	13:33:36.91	CHANGE	SEATAC.2	TR POSITION 5 DISABLE	OFF	
0-Jun-1999	13:33:36.92	CHANGE	SEATAC.2	TR POSITION 6 DISABLE	OFF	
0-Jun-1999	13:33:48.93	PREV VAL		CONSOLE 2 CAI		
0-Jun-1999	13:33:48.94	ENTRY		OLLOG (FOR)	PRNT	0
0-Jun-1999	13:34:25.95	CHANGE	SEATAC.2	UNIT 3 STATUS	RUN	
0-Jun-1999	13:35:12.96	CHANGE	SEATAC.2	UNITED DISABLE	OFF	
0-Jun-1999	13:41:09.97	UNCMDCHG	ALLEN.1	TK-101 INLET	OPEN	
0-Jun-1999	13:43:37.98	CHANGE	SEATAC.2	UNIT 4 STATUS	RUN	
0-Jun-1999	13:44:48	CHANGE	SEATAC.2	TR POSITION 7 DISABLE	ON	
0-Jun-1999	13:44:48.99	CHANGE	SEATAC.2	TR POSITION 6 DISABLE	ON	
0-Jun-1999	13:44:53.01	CHANGE	SEATAC.2	TR POSITION 5 DISABLE	ON	
0-Jun-1999	13:45:01.02	CHANGE	SEATAC.2	TR POSITION 1 DISABLE	ON	
0-Jun-1999	13:45:01.03	CHANGE	SEATAC.2	TR POSITION 2 DISABLE	ON	
0-Jun-1999	13:45:05.04	CHANGE	SEATAC.2	UNIT 3 STATUS	SHUTDOWN	
0-Jun-1999	13:45:05.05	CHANGE	SEATAC.2	TR POSITION 3 DISABLE	ON	
0-Jun-1999	13:45:05.06	CHANGE	SEATAC.2	TR POSITION 4 DISABLE	ON	
0-Jun-1999	13:46:48.07	CHANGE	SEATAC.2	TR POSITION 1 DISABLE	OFF	
0-Jun-1999	13:46:48.08	CHANGE	SEATAC.2	TR POSITION 2 DISABLE	OFF	
0-Jun-1999	13:46:48.09	CHANGE	SEATAC.2	TR POSITION 3 DISABLE	OFF	
0-Jun-1999	13:46:48.10	CHANGE	SEATAC.2	TR POSITION 4 DISABLE	OFF	
0-Jun-1999	13:47:12.11	CHANGE	SEATAC.2	TR POSITION 5 DISABLE	OFF	
0-Jun-1999	13:47:12.12	CHANGE	SEATAC.2	TR POSITION 6 DISABLE	OFF	
0-Jun-1999	13:47:12.13	CHANGE	SEATAC.2	TR POSITION 7 DISABLE	OFF	
0-Jun-1999	13:47:12.14	CHANGE	SEATAC.2	TR POSITION 8 DISABLE	OFF	
0-Jun-1999	13:47:48.15	CHANGE	SEATAC.2	UNIT 1 STATUS	RUN	
0-Jun-1999	13:50:17.16	CHANGE	SEATAC.2	TR POSITION 8 DISABLE	ON	

10-Jun-1999	13:51:48.17	CHANGE	SEATAC.2	UNIT 2 STATUS	RUN		
10-Jun-1999	13:54:17.18	CHANGE	SEATAC.2	UNIT 4 STATUS	SHUTDOWN		
10-Jun-1999	13:56:49.19	CNTL REQ	ALLEN.1	CONSOLE 3 CAI	STOP		
10-Jun-1999	13:56:51.20	TRANSMIT	ALLEN	16" DRA PUMP STATUS	SHUTDOWN		
10-Jun-1999	13:56:52.21	CNTL REQ	WOODINVILLE	CONSOLE 3 CAI	STOP		
10-Jun-1999	13:56:55.22	TRANSMIT	WOODINVILLE	DRA PUMP	SHUTDOWN		
10-Jun-1999	13:56:58.23	EXECUTE	WOODINVILLE	DRA PUMP	SHUTDOWN		
10-Jun-1999	13:58:11.24	CHANGE	SEATAC.2	UNIT 3 STATUS	RUN		
10-Jun-1999	14:00:54.25	CNTL REQ	PORTLAND.DF	CONSOLE 5 CAI	CHANGE		
10-Jun-1999	14:00:54.26	NOTICE:	PORTLAND.DF	PORIBTCHCHNGSTATUS IS CHANGE	COMPLETE	CONTINUE...	
10-Jun-1999	14:00:55.27	TRANSMIT	PORTLAND.DF	BATCH CHANGE	COMPLETE		
10-Jun-1999	14:00:59.28	EXECUTE	PORTLAND.DF	BATCH CHANGE	COMPLETE		
10-Jun-1999	14:00:59.29	ALARM	PORTLAND.DF	PRINT SWITCH	IN PROG.		
10-Jun-1999	14:00:59.30	ALARM	PORTLAND.DF	BATCH CHANGE	IN PROG.		
10-Jun-1999	14:00:59.31	CNTL REQ	PORTLAND.DF	CONSOLE 0	RESET		
10-Jun-1999	14:00:59.32	CHANGE	PORTLAND.DF	BTCH BLK-->PLC DOWNLOAD	READY		
10-Jun-1999	14:00:59.33	CNTL REQ	PORTLAND.DF	CONSOLE 0	READY		
10-Jun-1999	14:01:00.34	TRANSMIT	PORTLAND.DF	RESET ACCUM B PSEUDO	RESET		
10-Jun-1999	14:01:01.35	EXECUTE	PORTLAND.DF	MASTER --> PLC DOWNLOAD	READY	SUCCESS	
10-Jun-1999	14:01:03.36	CHANGE	PORTLAND.DF	CALCULATED BATCH	TOTL VOL	16068.2	
10-Jun-1999	14:01:03.37	CHANGE	PORTLAND.DF	CALCULATED BATCH	WTAVG GR	55.9	
10-Jun-1999	14:01:03.38	CHANGE	PORTLAND.DF	FLOW COMPUTER BATCH	TOTL VOL	16067.0	
10-Jun-1999	14:01:03.39	CHANGE	PORTLAND.DF	FLOW COMPUTER BATCH	WTAVG GR	54.1	
10-Jun-1999	14:01:05.40	CHANGE	PORTLAND.DF	CALCULATED DELIVERY	TOTL VOL	16068.2	
10-Jun-1999	14:01:05.41	CHANGE	PORTLAND.DF	CALCULATED DELIVERY	WTAVG GR	55.9	
10-Jun-1999	14:01:05.42	CHANGE	PORTLAND.DF	FLOW COMPUTER DELIVERY	TOTL VOL	16067.0	
10-Jun-1999	14:01:05.43	CHANGE	PORTLAND.DF	FLOW COMPUTER DELIVERY	WTAVG GR	54.1	
10-Jun-1999	14:01:06.44	ALARM	PORTLAND.DF	D2500 /API BATCH 2	LOW	0.0	
10-Jun-1999	14:01:06.45	ALARM	PORTLAND.DF	D2500 /API BATCH 2	LOW LOW	0.0	
10-Jun-1999	14:01:12.46	NORMAL	PORTLAND.DF	PRINT SWITCH	COMPLETE		
10-Jun-1999	14:01:12.47	NORMAL	PORTLAND.DF	BATCH CHANGE	COMPLETE		
10-Jun-1999	14:01:12.48	CHANGE	PORTLAND.DF	BTCH BLK-->PLC DOWNLOAD	COMPLETE		
10-Jun-1999	14:01:22.49	CHANGE	PORTLAND.DF	DELIVERY REPORT	READY		
10-Jun-1999	14:01:22.50	CNTL REQ	PORTLAND.DF	CONSOLE 0	READY		
10-Jun-1999	14:01:22.51	EXECUTE	PORTLAND.DF	DELIVERY REPORT	COMPLETE		
10-Jun-1999	14:01:22.52	CHANGE	PORTLAND.DF	BATCH REPORT	READY		
10-Jun-1999	14:01:23.53	CNTL REQ	PORTLAND.DF	CONSOLE 0	READY		
10-Jun-1999	14:01:23.54	EXECUTE	PORTLAND.DF	BATCH REPORT	COMPLETE		
10-Jun-1999	14:01:25.55	EVENT	PORTLAND.DF	DELIVERY REPORT PORDDL07	RECEIVED		
10-Jun-1999	14:01:28.56	EVENT	PORTLAND.DF	BATCH REPORT PORDBT06	RECEIVED		
10-Jun-1999	14:01:29.57	EXECUTE	PORTLAND.DF	RESET ACCUM B PSEUDO	RESET		
10-Jun-1999	14:01:30.58	CHANGE	PORTLAND.DF	DELIVERY REPORT	COMPLETE		
10-Jun-1999	14:01:30.59	CHANGE	PORTLAND.DF	BATCH REPORT	COMPLETE		
10-Jun-1999	14:01:46.60	CNTL REQ	PORTLAND.DF	CONSOLE 4 CAI	OPEN		
10-Jun-1999	14:01:50.61	TRANSMIT	PORTLAND.DF	V-871 T-106 OUT	OPEN		
10-Jun-1999	14:01:54.62	CLEAR	PORTLAND.DF	D2500 /API BATCH 2	LOW LOW	56.0	
10-Jun-1999	14:01:54.63	CLEAR	PORTLAND.DF	D2500 /API BATCH 2	LOW	56.0	
10-Jun-1999	14:01:54.64	NORMAL	PORTLAND.DF	D2500 /API BATCH 2	NORMAL	56.0	
10-Jun-1999	14:02:38.65	EXECUTE	PORTLAND.DF	V-871 T-106 OUT	OPEN		
10-Jun-1999	14:03:04.66	CHANGE	SEATAC.2	UNIT 1 STATUS	SHUTDOWN		
10-Jun-1999	14:03:23.67	CHANGE	SEATAC.2	UNIT 4 STATUS	RUN		
10-Jun-1999	14:03:34.68	CNTL REQ	PORTLAND.DF	CONSOLE 4 CAI	START		
10-Jun-1999	14:03:36.69	TRANSMIT	PORTLAND.DF	INJECTION PUMP	RUN		
10-Jun-1999	14:04:28.70	EXECUTE	PORTLAND.DF	INJECTION PUMP	RUN		
10-Jun-1999	14:04:44.71	CNTL REQ	TACOMA.DF	CONSOLE 5 CAI	DEC		
10-Jun-1999	14:04:46.72	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		1745	
10-Jun-1999	14:04:47.74	ALARM	RENTON.1	TANK 116	LO [V]		
10-Jun-1999	14:04:48.73	CNTL REQ	TACOMA.DF	CONSOLE 5 CAI	DEC		
10-Jun-1999	14:04:50.75	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		1735	
10-Jun-1999	14:05:19.76	TRANSMIT	OLYMPIA.JCT	DRA SET POINT - GPH		6	
10-Jun-1999	14:05:45.77	CNTL REQ	RENTON.1	CONSOLE 3 CAI	STOP		
10-Jun-1999	14:05:47.78	TRANSMIT	RENTON.1	INJECTION PUMP	SHUTDOWN		
10-Jun-1999	14:05:53.79	EXECUTE	RENTON.1	INJECTION PUMP	SHUTDOWN		
10-Jun-1999	14:05:58.80	CNTL REQ	RENTON.1	CONSOLE 3 CAI	CLOSE		

0000048

10-Jun-1999	14:06:01.81	TRANSMIT RENTON.1	V-674 INJECT TO RENTN DF	CLOSE	
10-Jun-1999	14:06:01.82	CNTL REQ RENTON.1	CONSOLE 3 CAI	CLOSE	
10-Jun-1999	14:06:04.83	TRANSMIT RENTON.1	V-686 T-116 OUT	CLOSE	
10-Jun-1999	14:06:13.84	EXECUTE RENTON.1	V-674 INJECT TO RENTN DF	CLOSE	
10-Jun-1999	14:06:24.85	CHANGE SEATAC.2	UNIT 2 STATUS	SHUTDOWN	
10-Jun-1999	14:07:13.86	EXECUTE RENTON.1	V-686 T-116 OUT	CLOSE	
10-Jun-1999	14:10:00.87	CHANGE SEATAC.2	UNIT 1 STATUS	RUN	
10-Jun-1999	14:10:41.88	CHANGE SEATAC.2	UNIT 3 STATUS	SHUTDOWN	
10-Jun-1999	14:16:50.89	UNCMDCHG ALLEN.2	20" SCRAPER INLET	OPEN	
10-Jun-1999	14:17:05.90	ALARM PORTLAND.DF	SWING PORTLAND JCT -200	ALERT	
10-Jun-1999	14:19:21.91	CNTL REQ PORTLAND.JCT	CONSOLE 5 CAI	OPEN	
10-Jun-1999	14:19:23.92	TRANSMIT PORTLAND.JCT	V-882 UNOCAL GAS	OPEN	
10-Jun-1999	14:19:28.93	NORMAL PORTLAND.DF	SWING PORTLAND JCT -200		
10-Jun-1999	14:19:29.94	UNCMDCHG PORTLAND.JCT	V-878 TEXACO GAS	TRAVEL	
10-Jun-1999	14:19:58.95	EXECUTE PORTLAND.JCT	V-882 UNOCAL GAS	OPEN	
10-Jun-1999	14:20:04.96	UNCMDCHG PORTLAND.JCT	V-878 TEXACO GAS	CLOSE	
10-Jun-1999	14:20:19.97	TRANSMIT OLYMPIA.JCT	DRA SET POINT - GPH		6
10-Jun-1999	14:20:19.98	TRANSMIT CASTLE.ROCK	DRA SET POINT - GPH		6
10-Jun-1999	14:26:49.99	CHANGE SEATAC.2	UNIT 4 STATUS	SHUTDOWN	
10-Jun-08	14:29:08	PREV VAL RENTON.1	CONSOLE 2 CAI	ON	
10-Jun-1999	14:29:08.01	ENTRY RENTON.1	PROVE STATUS	TAG	OFF
10-Jun-1999	14:29:13.02	CNTL REQ RENTON.1	CONSOLE 3 CAI	START	
10-Jun-1999	14:29:16.03	TRANSMIT RENTON.1	PROVE STATUS	IN PROG.	
10-Jun-1999	14:29:28.04	NORMAL RENTON.1	PROVE SEQUENCE		
10-Jun-1999	14:29:28.05	EXECUTE RENTON.1	PROVE STATUS	IN PROG.	
10-Jun-1999	14:30:08.06	CNTL REQ TACOMA.STA	CONSOLE 4 CAI	INC	
10-Jun-1999	14:30:10.07	TRANSMIT TACOMA.STA	DISCHARGE PSI SP ENTRY		1300
10-Jun-1999	14:30:11.08	CNTL REQ TACOMA.STA	CONSOLE 4 CAI	INC	
10-Jun-1999	14:30:13.09	TRANSMIT TACOMA.STA	DISCHARGE PSI SP ENTRY		1330
10-Jun-1999	14:30:14.10	CNTL REQ TACOMA.STA	CONSOLE 4 CAI	INC	
10-Jun-1999	14:30:16.11	TRANSMIT TACOMA.STA	DISCHARGE PSI SP ENTRY		1360
10-Jun-1999	14:30:26.12	CNTL REQ TACOMA.STA	CONSOLE 6 CAI		1435.00
10-Jun-1999	14:30:29.13	TRANSMIT TACOMA.STA	DISCHARGE PSI SP ENTRY		1435
10-Jun-1999	14:31:05.14	CHANGE SEATAC.2	UNIT 2 STATUS	RUN	
10-Jun-1999	14:36:50.15	CHANGE RENTON.1	PROVE REPORT	READY	
10-Jun-1999	14:36:52.16	CNTL REQ RENTON.1	CONSOLE 0	READY	
10-Jun-1999	14:36:52.17	EXECUTE RENTON.1	PROVE REPORT	COMPLETE	
10-Jun-1999	14:37:01.18	EVENT RENTON.1	PROVING REPORT RT1DPR03	RECEIVED	
10-Jun-1999	14:37:05.19	CHANGE RENTON.1	PROVE REPORT	COMPLETE	
10-Jun-1999	14:39:27.20	UNCMDCHG BAYVIEW	FER TK-202 OUTLET HOA	HAND	
10-Jun-1999	14:39:44.21	UNCMDCHG BAYVIEW	FER TK-203 OUTLET HOA	HAND	
10-Jun-1999	14:39:44.22	UNCMDCHG BAYVIEW	FER TK-205 OUTLET HOA	HAND	
10-Jun-1999	14:40:02.23	UNCMDCHG BAYVIEW	FER DONUT TO PUMPS	HAND	
10-Jun-1999	14:40:02.24	UNCMDCHG BAYVIEW	FER TK-204 OUTLET HOA	HAND	
10-Jun-1999	14:40:20.25	UNCMDCHG BAYVIEW	FER TK-206 OUTLET HOA	HAND	
10-Jun-1999	14:41:26.26	UNCMDCHG ALLEN.2	20" SCRAPER BYPASS	CLOSE	
10-Jun-1999	14:43:39.27	CHANGE RENTON.1	PRINT SWITCH	IN PROG.	
10-Jun-1999	14:43:41.28	CHANGE RENTON.1	CALCULATED DELIVERY	TOTL VOL	41053.5
10-Jun-1999	14:43:41.29	CHANGE RENTON.1	CALCULATED DELIVERY	WTAVG GR	60.8
10-Jun-1999	14:43:45.30	UNCMDCHG RENTON.1	PROVE STATUS	COMPLETE	
10-Jun-1999	14:43:50.31	CHANGE RENTON.1	FACTOR TABLE	READY	
10-Jun-1999	14:43:50.34	CHANGE RENTON.1	PRINT SWITCH	COMPLETE	
10-Jun-1999	14:43:52.32	CNTL REQ RENTON.1	CONSOLE 0	READY	
10-Jun-1999	14:43:52.33	EXECUTE RENTON.1	FACTOR TABLE	COMPLETE	
10-Jun-1999	14:43:54.35	EVENT RENTON.1	METER FACTORS RT1DMFCUR	RECEIVED	
10-Jun-1999	14:43:58.36	CHANGE RENTON.1	DELIVERY REPORT	READY	
10-Jun-1999	14:43:58.37	CNTL REQ RENTON.1	CONSOLE 0	READY	
10-Jun-1999	14:43:58.38	EXECUTE RENTON.1	DELIVERY REPORT	COMPLETE	
10-Jun-1999	14:43:58.39	CHANGE RENTON.1	FACTOR TABLE	COMPLETE	
10-Jun-1999	14:44:00.40	EVENT RENTON.1	DELIVERY REPORT RT1DDL02	RECEIVED	
10-Jun-1999	14:44:04.41	CHANGE RENTON.1	DELIVERY REPORT	COMPLETE	
10-Jun-1999	14:44:04.42	CHANGE RENTON.1	PROVE REPORT	READY	
10-Jun-1999	14:44:05.43	CNTL REQ RENTON.1	CONSOLE 0	READY	
10-Jun-1999	14:44:05.44	EXECUTE RENTON.1	PROVE REPORT	COMPLETE	

0000049

10-Jun-1999	14:44:17.45	CHANGE	RENTON.1	PROVE REPORT	COMPLETE	
10-Jun-1999	14:48:54.46	CNTL REQ	TACOMA.DF	CONSOLE 5 CAI	INC	
10-Jun-1999	14:48:55.47	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		1745
10-Jun-1999	14:54:13.48	CNTL REQ	RENTON.1	CONSOLE 3 CAI	START	
10-Jun-1999	14:54:14.49	TRANSMIT	RENTON.1	PROVE STATUS	IN PROG.	
10-Jun-1999	14:54:38.50	EXECUTE	RENTON.1	PROVE STATUS	IN PROG.	
10-Jun-1999	14:56:10.51	UNCMDCHG	BAYVIEW	PRODUCT SUMP DISCHARGE	TRAVEL	
10-Jun-1999	14:56:18.52	UNCMDCHG	BAYVIEW	PRODUCT SUMP DISCHARGE	OPEN	
10-Jun-1999	14:56:18.53	UNCMDCHG	BAYVIEW	P-208 SUMP PUMP STATUS	RUN	
10-Jun-1999	14:56:28.54	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	OPEN	
10-Jun-1999	14:58:52.55	UNCMDCHG	BAYVIEW	PRODUCT SUMP DISCHARGE	TRAVEL	
10-Jun-1999	14:58:52.56	UNCMDCHG	BAYVIEW	P-208 SUMP PUMP STATUS	SHUTDOWN	
10-Jun-1999	14:58:59.57	UNCMDCHG	BAYVIEW	PRODUCT SUMP DISCHARGE	CLOSE	
10-Jun-1999	15:00:10.58	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	CLOSE	
10-Jun-1999	15:01:23.59	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	OPEN	
10-Jun-1999	15:01:33.60	ALARM	RENTON.1	PROVE SEQUENCE	FAIL	
10-Jun-1999	15:01:33.61	UNCMDCHG	RENTON.1	PROVE STATUS	COMPLETE	
10-Jun-1999	15:01:45.62	CHANGE	RENTON.1	PROVE REPORT	READY	
10-Jun-1999	15:01:45.63	CNTL REQ	RENTON.1	CONSOLE 0	READY	
10-Jun-1999	15:01:45.64	EXECUTE	RENTON.1	PROVE REPORT	COMPLETE	
10-Jun-1999	15:01:57.65	CHANGE	RENTON.1	PROVE REPORT	COMPLETE	
10-Jun-1999	15:04:45.66	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	CLOSE	
10-Jun-1999	15:06:57.67	CNTL REQ	RENTON.1	CONSOLE 3 CAI	START	
10-Jun-1999	15:07:00.68	TRANSMIT	RENTON.1	SUMP PUMP	RUN	
10-Jun-1999	15:07:03.69	UNCMDCHG	RENTON.1	SUMP PUMP	RUN	
10-Jun-1999	15:07:04.70	TO FINAL	RENTON.1	SUMP PUMP	RUN	
10-Jun-1999	15:07:18.71	ALARM	CHERRY.POINT	SUCTION PRESSURE	LOW	15
10-Jun-1999	15:07:18.72	ALARM	CHERRY.POINT	METER PRESSURE	LOW	15
10-Jun-1999	15:07:23.73	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	OPEN	
10-Jun-1999	15:07:25.74	CLEAR	CHERRY.POINT	SUCTION PRESSURE	LOW	17
10-Jun-1999	15:07:25.75	NORMAL	CHERRY.POINT	SUCTION PRESSURE	NORMAL	17
10-Jun-1999	15:07:25.76	CLEAR	CHERRY.POINT	METER PRESSURE	LOW	17
10-Jun-1999	15:07:25.77	NORMAL	CHERRY.POINT	METER PRESSURE	NORMAL	17
10-Jun-1999	15:07:34.78	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	CLOSE	
10-Jun-1999	15:09:08.79	UNCMDCHG	RENTON.1	SUMP PUMP	SHUTDOWN	
10-Jun-1999	15:12:34.80	CLEAR	RENTON.1	TANK 116	LO [V]	
10-Jun-1999	15:12:41.81	ALARM	RENTON.1	TANK 116	LO [V]	
10-Jun-1999	15:12:46.82	CLEAR	RENTON.1	TANK 116	LO [V]	
10-Jun-1999	15:12:52.83	ALARM	RENTON.1	TANK 116	LO [V]	
10-Jun-1999	15:13:29.84	CLEAR	RENTON.1	TANK 116	LO [V]	
10-Jun-1999	15:13:34.85	ALARM	RENTON.1	TANK 116	LO [V]	
10-Jun-1999	15:13:42.86	CNTL REQ	SEATTLE.DF	CONSOLE 3 CAI	OPEN	
10-Jun-1999	15:13:45.87	TRANSMIT	SEATTLE.DF	V-702 SCRAPER IN	OPEN	
10-Jun-1999	15:13:49.88	CLEAR	RENTON.1	TANK 116	LO [V]	
10-Jun-1999	15:14:12.89	ALARM	RENTON.1	TANK 116	LO [V]	
10-Jun-1999	15:15:00.90	EXECUTE	SEATTLE.DF	V-702 SCRAPER IN	OPEN	
10-Jun-1999	15:15:29.91	UNCMDCHG	PORTLAND.DF	INJECTION PUMP	SHUTDOWN	
10-Jun-1999	15:15:38.92	CNTL REQ	RENTON.1	CONSOLE 3 CAI	OPEN	
10-Jun-1999	15:15:41.93	TRANSMIT	RENTON.1	V-667 16" SEATTLE MNFLD.	OPEN	
10-Jun-1999	15:16:06.94	CNTL REQ	RENTON	CONSOLE 3 CAI	INC	
10-Jun-1999	15:16:08.95	TRANSMIT	RENTON	INCOMING PSI SP ENTRY		300
10-Jun-1999	15:16:10.96	CNTL REQ	RENTON	CONSOLE 3 CAI	INC	
10-Jun-1999	15:16:12.97	TRANSMIT	RENTON	INCOMING PSI SP ENTRY		400
10-Jun-1999	15:16:14.98	TO FINAL	RENTON.1	V-667 16" SEATTLE MNFLD.	TRAVEL	
10-Jun-1999	15:16:15.99	UNCMDCHG	RENTON.1	V-667 16" SEATTLE MNFLD.	OPEN	
10-Jun-1999	15:16:19	CNTL REQ	RENTON	CONSOLE 3 CAI	INC	
10-Jun-1999	15:16:20.01	TRANSMIT	RENTON	INCOMING PSI SP ENTRY		500
10-Jun-1999	15:16:23.02	CNTL REQ	SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:16:25.03	CNTL REQ	SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:16:26.04	CHANGE	SEATAC.2	UNIT 1 STATUS	SHUTDOWN	
10-Jun-1999	15:16:27.05	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		700
10-Jun-1999	15:16:27.06	CNTL REQ	SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:16:29.07	CNTL REQ	RENTON	CONSOLE 3 CAI	INC	
10-Jun-1999	15:16:29.08	TRANSMIT	SEATTLE.DF	INCOMING PSI SP ENTRY		650

0000050

10-Jun-1999	15:16:31.09	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:16:31.10	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		600
10-Jun-1999	15:16:32.11	TRANSMIT RENTON	INCOMING PSI SP ENTRY		600
10-Jun-1999	15:16:33.12	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:16:34.13	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		550
10-Jun-1999	15:16:36.14	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		500
10-Jun-1999	15:16:36.15	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:16:38.16	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:16:39.17	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		450
10-Jun-1999	15:16:41.18	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		400
10-Jun-1999	15:16:42.19	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:16:45.20	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:16:45.21	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		350
10-Jun-1999	15:16:47.22	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		300
10-Jun-1999	15:16:48.23	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:16:51.24	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		250
10-Jun-1999	15:16:52.25	UNCMDCHG BAYVIEW	PRODUCT SUMP DISCHARGE	OPEN	
10-Jun-1999	15:16:52.26	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:16:55.27	CNTL REQ RENTON	CONSOLE 3 CAI	INC	
10-Jun-1999	15:16:56.28	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		200
10-Jun-1999	15:16:57.29	CNTL REQ RENTON	CONSOLE 3 CAI	INC	
10-Jun-1999	15:16:58.30	TRANSMIT RENTON	INCOMING PSI SP ENTRY		700
10-Jun-1999	15:16:59.31	CNTL REQ RENTON	CONSOLE 3 CAI	INC	
10-Jun-1999	15:16:59.32	TRANSMIT RENTON	INCOMING PSI SP ENTRY		800
10-Jun-1999	15:17:00.33	ALARM BAYVIEW	TK-209 TANK FLOW(SURGE)	OPEN	
10-Jun-1999	15:17:00.34	UNCMDCHG BAYVIEW	P-208 SUMP PUMP STATUS	RUN	
10-Jun-1999	15:17:01.35	TRANSMIT RENTON	INCOMING PSI SP ENTRY		900
10-Jun-1999	15:17:01.36	CNTL REQ RENTON	CONSOLE 3 CAI	INC	
10-Jun-1999	15:17:03.37	TRANSMIT RENTON	INCOMING PSI SP ENTRY		1000
10-Jun-1999	15:17:05.38	CNTL REQ RENTON.1	CONSOLE 3 CAI	CLOSE	
10-Jun-1999	15:17:08.39	TRANSMIT RENTON.1	V-669 16" RENTON DF MFLD	CLOSE	
10-Jun-1999	15:17:10.40	ALARM RENTON	TEMPERATURE SEATTLE TRAP	MINUSROC	2.2
10-Jun-1999	15:17:11.41	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:17:14.42	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		150
10-Jun-1999	15:17:16.43	CLEAR RENTON	TEMPERATURE SEATTLE TRAP	ROC +/-	0.0
10-Jun-1999	15:17:20.44	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:17:23.45	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		100
10-Jun-1999	15:17:23.46	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:17:25.47	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		100
10-Jun-1999	15:17:26.48	CNTL REQ SEATTLE.DF	CONSOLE 3 CAI	DEC	
10-Jun-1999	15:17:29.49	TRANSMIT SEATTLE.DF	INCOMING PSI SP ENTRY		50
10-Jun-1999	15:17:40.50	CHANGE SEATAC.2	UNIT 3 STATUS	RUN	
10-Jun-1999	15:17:43.51	EXECUTE RENTON.1	V-669 16" RENTON DF MFLD	CLOSE	
10-Jun-1999	15:18:22.52	ALARM ALLEN.1	16" DISCHARGE PRESSURE	HIGH	1444
10-Jun-1999	15:18:35.53	CNTL REQ WOODINVILLE	CONSOLE 2 CAI	START	
10-Jun-1999	15:18:58.54	FAILURE WOODINVILLE	UNIT 2 STATUS	RUN	
10-Jun-1999	15:19:04.58	ALARM ALLEN.1	16" CONTROL PRESSURE	HIGH	1539
10-Jun-1999	15:19:05.55	UNCMDCHG BAYVIEW	PRODUCT SUMP DISCHARGE	TRAVEL	
10-Jun-1999	15:19:05.56	UNCMDCHG BAYVIEW	P-208 SUMP PUMP STATUS	SHUTDOWN	
10-Jun-1999	15:20:07.57	UNCMDCHG BAYVIEW	PRODUCT SUMP DISCHARGE	CLOSE	
10-Jun-1999	15:20:35.60	CLEAR ALLEN.1	16" DISCHARGE PRESSURE	HIGH	1440
10-Jun-1999	15:20:35.61	NORMAL ALLEN.1	16" DISCHARGE PRESSURE	NORMAL	1440
10-Jun-1999	15:20:45.59	ALARM BAYVIEW	TK-209 TANK FLOW(SURGE)	CLOSE	
10-Jun-1999	15:22:16.62	NORMAL BAYVIEW	FER-ALN SCRAPER OUT		
10-Jun-1999	15:22:38.63	CHANGE SEATAC.2	UNIT 4 STATUS	RUN	
10-Jun-1999	15:22:59.64	CHANGE BAYVIEW	P-201 SUCTION	TRAVEL	
10-Jun-1999	15:22:59.65	CHANGE BAYVIEW	P-201 DISCHARGE	TRAVEL	
10-Jun-1999	15:22:59.66	UNCMDCHG BAYVIEW	P-201 STATUS	SHUTDOWN	
10-Jun-1999	15:23:16.70	ALARM BAYVIEW	FER-BPT RECEIVER PSI	HIGH	666
10-Jun-1999	15:23:16.71	ALARM BAYVIEW	FER-BPT UPSTREAM PSI	HIGH	622
10-Jun-1999	15:23:34.67	UNCMDCHG ALLEN.1	16" UNIT 2 STATUS	SHUTDOWN	
10-Jun-1999	15:24:16.69	CHANGE BAYVIEW	P-201 SUCTION	CLOSE	
10-Jun-1999	15:24:16.72	CHANGE BAYVIEW	P-201 DISCHARGE	CLOSE	
10-Jun-1999	15:24:16.73	ALARM BAYVIEW	TK-209 TANK FLOW(SURGE)	OPEN	

000051

10-Jun-1999	15:24:21.68	NORMAL	TACOMA.DF	TANK 103	NORMAL	2584
10-Jun-1999	15:24:25.76	CLEAR	ALLEN.1	16" CONTROL PRESSURE	HIGH	1205
10-Jun-1999	15:24:25.77	NORMAL	ALLEN.1	16" CONTROL PRESSURE	NORMAL	1205
10-Jun-1999	15:24:29.78	ALARM	RENTON	API GRAVITY 20 LOCAL	MINUSROC	0.3
10-Jun-1999	15:24:30.79	ALARM	BAYVIEW	FER-BPT API GRAVITY @ 60	MINUSROC	0.3
10-Jun-1999	15:24:53.74	UNCMDCHG	BAYVIEW	FER-BPT STA SDOWN-RESET	SHUTDOWN	
10-Jun-1999	15:24:53.75	UNCMDCHG	BAYVIEW	FER-BPT RECEIVER INLET	TRAVEL	
10-Jun-1999	15:24:53.80	ALARM	BAYVIEW	FER-BPT UPSTRM PSI HI	ALARM	
10-Jun-1999	15:44:30.57	EVENT	SYSTEM	VCS STARTUP		
10-Jun-1999	15:44:43.58	ALARM	SEATAC.2	COMMUNICATIONS	FAIL	
10-Jun-1999	15:44:46.59	ALARM	OLYMPIA.JCT	COMMUNICATIONS	FAIL	
10-Jun-1999	15:44:46.60	ALARM	BAYVIEW	COMMUNICATIONS	FAIL	
10-Jun-1999	15:44:47.61	ALARM	TACOMA.STA	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:44:47.62	ALARM	WOODINVILLE	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:44:47.63	ALARM	RENTON	RENTON PLC COMM STATS	FAIL	
10-Jun-1999	15:44:51.64	ALARM	CASTLE.ROCK	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:44:51.65	ALARM	CHERRY.POINT	COMMUNICATIONS	FAIL	
10-Jun-1999	15:44:53.66	ALARM	ANACORTES.ML	COMMUNICATIONS	FAIL	
10-Jun-1999	15:44:57.67	ALARM	ANA.SHELL	READALL COMMUNICATIONS	FAIL	
10-Jun-1999	15:44:57.68	ALARM	TACOMA.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:44:57.69	ALARM	ANA.TEX	ANA.TEX COMMUNICATIONS	FAIL	
10-Jun-1999	15:44:58.70	ALARM	PORTLAND.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:44:58.71	ALARM	SEATAC.1	COMMUNICATIONS	FAIL	
10-Jun-1999	15:44:59.72	ALARM	SEATTLE.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:03.73	ALARM	ALLEN	ALLEN PLC COMM STATS	FAIL	
10-Jun-1999	15:45:03.74	ALARM	LINNTON.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:03.75	ALARM	RENTON.1	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:03.76	ALARM	SEATTLE.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:03.77	ALARM	TACOMA.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:03.78	LOGON	SYSTEM	CONSOLE 11 CAI	KEYBOARD	11
10-Jun-1999	15:45:04.79	ALARM	OLYMPIA.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:04.80	ALARM	TACOMA.JCT	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:45:04.81	ALARM	FERNDALE	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:05.82	ALARM	VANCOUVR.JCT	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:06.83	ALARM	FERNDALE	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:06.84	ALARM	PORTLAND.JCT	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:07.85	ALARM	VANCOUVER.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:07.86	ALARM	VANCOUVER.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:45:10.87	ALARM	MILEPOST.56	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:45:14.88	LOGON	SYSTEM	CONSOLE 12 CAI	KEYBOARD	12
10-Jun-1999	15:45:15.89	ALARM	MILEPOST.46	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:45:21.90	ALARM	MILEPOST.CDR	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:45:22.91	ALARM	MILEPOST.66	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:45:22.92	ALARM	MILEPOST.89	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:45:29.93	EVENT	SYSTEM	COMMUNICATION STATISTICS	PURGED	
10-Jun-1999	15:47:03.94	ALARM	MILEPOST.LWS	MP 239.5 Comm Statistics	FAIL	
10-Jun-1999	15:47:14.95	ALARM	BAYVIEW	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:20.96	ALARM	SEATAC.2	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:22.97	ALARM	OLYMPIA.JCT	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:22.98	ALARM	RENTON	RENTON PLC COMM STATS	FAIL	
10-Jun-1999	15:47:23	ALARM	TACOMA.STA	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:47:23.99	ALARM	WOODINVILLE	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:47:26.01	ALARM	CASTLE.ROCK	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:47:28.02	ALARM	CHERRY.POINT	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:32.03	ALARM	ANA.SHELL	READALL COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:32.04	ALARM	LINNTON.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:33.05	ALARM	TACOMA.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:33.06	ALARM	ANA.TEX	ANA.TEX COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:35.07	ALARM	ANACORTES.ML	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:35.08	ALARM	PORTLAND.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:36.09	ALARM	FERNDALE	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:39.10	ALARM	RENTON.1	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:39.11	ALARM	ALLEN	ALLEN PLC COMM STATS	FAIL	
10-Jun-1999	15:47:40.12	ALARM	OLYMPIA.DF	COMMUNICATIONS	FAIL	

000052

10-Jun-1999	15:47:40.13	ALARM	TACOMA.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:40.14	ALARM	SEATTLE.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:40.15	ALARM	PORTLAND.JCT	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:40.16	ALARM	SEATTLE.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:40.17	ALARM	VANCOUVR.JCT	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:40.18	ALARM	SEATAC.1	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:41.19	ALARM	VANCOUVER.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:44.20	ALARM	TACOMA.JCT	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:47:44.21	ALARM	VANCOUVER.DF	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:46.22	ALARM	FERNDALE	COMMUNICATIONS	FAIL	
10-Jun-1999	15:47:47.23	ALARM	MILEPOST.89	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:47:52.24	ALARM	MILEPOST.56	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:47:56.25	ALARM	MILEPOST.CDR	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:47:58.26	ALARM	MILEPOST.46	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:47:58.27	ALARM	MILEPOST.66	COMMUNICATIONS VIA CPA	FAIL	
10-Jun-1999	15:48:39.59	CLEAR	ALLEN.1	16" CONTROL PRESSURE	HIGH	239
10-Jun-1999	15:48:39.61	NORMAL	ALLEN.1	16" CONTROL PRESSURE	NORMAL	239
10-Jun-1999	15:48:40.28	NORMAL	MILEPOST.89	COMMUNICATIONS VIA CPA	NORMAL	
10-Jun-1999	15:48:43.29	NORMAL	SEATAC.2	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:48:43.30	ALARM	SEATTLE.DF	GROSS FLW RATE SET POINT	HIGH	10000
10-Jun-1999	15:48:44.31	CHANGE	SEATAC.2	UNIT 1 STATUS	RUN	
10-Jun-1999	15:48:44.32	CHANGE	SEATAC.2	UNIT 2 STATUS	SHUTDOWN	
10-Jun-1999	15:48:44.33	CHANGE	SEATAC.2	UNIT 4 STATUS	RUN	
10-Jun-1999	15:48:48.36	ALARM	WOODINVILLE	DRA PUMP INHIBIT	ON	
10-Jun-1999	15:48:48.40	ALARM	BAYVIEW	FER-BPT METER PSI	LOW	1
10-Jun-1999	15:48:48.41	ALARM	BAYVIEW	FER-BPT METER PSI	LOW LOW	1
10-Jun-1999	15:48:48.43	ALARM	BAYVIEW	FER-ALN METER PSI	LOW	0
10-Jun-1999	15:48:48.44	ALARM	BAYVIEW	FER-ALN METER PSI	LOW LOW	0
10-Jun-1999	15:48:48.47	ALARM	BAYVIEW	FER-ALN PUMP DISC PSI	LOW	0
10-Jun-1999	15:48:48.48	ALARM	BAYVIEW	FER-ALN PUMP DISC PSI	LOW LOW	0
10-Jun-1999	15:48:48.51	ALARM	BAYVIEW	FER-ALN PUMP CASE PSI	LOW	1
10-Jun-1999	15:48:48.52	ALARM	BAYVIEW	FER-ALN PUMP CASE PSI	LOW LOW	1
10-Jun-1999	15:48:48.53	CLEAR	BAYVIEW	FER-BPT RECEIVER PSI	HIGH	258
10-Jun-1999	15:48:48.54	NORMAL	BAYVIEW	FER-BPT RECEIVER PSI	NORMAL	258
10-Jun-1999	15:48:48.55	CLEAR	BAYVIEW	FER-BPT UPSTREAM PSI	HIGH	0
10-Jun-1999	15:48:48.56	ALARM	BAYVIEW	FER-BPT UPSTREAM PSI	LOW	0
10-Jun-1999	15:48:48.57	ALARM	BAYVIEW	FER-ALN STATION DISC PSI	LOW	0
10-Jun-1999	15:48:48.58	ALARM	BAYVIEW	FER-ALN STATION DISC PSI	LOW LOW	0
10-Jun-1999	15:48:49.34	NORMAL	BAYVIEW	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:48:49.35	NORMAL	MILEPOST.56	COMMUNICATIONS VIA CPA	NORMAL	
10-Jun-1999	15:48:50.37	NORMAL	CASTLE.ROCK	COMMUNICATIONS VIA CPA	NORMAL	
10-Jun-1999	15:48:51.38	NORMAL	WOODINVILLE	COMMUNICATIONS VIA CPA	NORMAL	
10-Jun-1999	15:48:52.39	NORMAL	TACOMA.STA	COMMUNICATIONS VIA CPA	NORMAL	
10-Jun-1999	15:48:52.42	NORMAL	ANA.SHELL	READALL COMMUNICATIONS	NORMAL	
10-Jun-1999	15:48:52.45	CHANGE	CHERRY.POINT	METER FLOW STATUS	IN PROG.	
10-Jun-1999	15:48:52.46	NORMAL	RENTON	RENTON PLC COMM STATS	NORMAL	
10-Jun-1999	15:48:52.49	CHANGE	CHERRY.POINT	UNIT 1 SUCTION	CLOSE	
10-Jun-1999	15:48:52.50	CHANGE	CHERRY.POINT	UNIT 1 DISCHARGE	CLOSE	
10-Jun-1999	15:48:52.60	CHANGE	BAYVIEW	P-201 SUCTION	CLOSE	
10-Jun-1999	15:48:52.62	CHANGE	BAYVIEW	P-201 DISCHARGE	CLOSE	
10-Jun-1999	15:48:52.63	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	CLOSE	
10-Jun-1999	15:48:52.89	ALARM	CHERRY.POINT	DISCHARGE PRESSURE	LOW	34
10-Jun-1999	15:48:52.90	ALARM	CHERRY.POINT	DISCHARGE PRESSURE	LOW LOW	34
10-Jun-1999	15:48:53.64	NORMAL	OLYMPIA.JCT	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:48:53.65	NORMAL	MILEPOST.CDR	COMMUNICATIONS VIA CPA	NORMAL	
10-Jun-1999	15:48:55.66	NORMAL	ANA.TEX	ANA.TEX COMMUNICATIONS	NORMAL	
10-Jun-1999	15:48:55.81	ALARM	PORTLAND.DF	ELECTRICAL	ALARM	
10-Jun-1999	15:48:56.67	NORMAL	LINNTON.DF	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:48:57.68	NORMAL	CHERRY.POINT	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:48:58.69	NORMAL	MILEPOST.46	COMMUNICATIONS VIA CPA	NORMAL	
10-Jun-1999	15:48:58.70	NORMAL	SEATTLE.DF	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:48:58.82	ALARM	FERNDALE	LOW SUCTION PRESSURE	ALARM	
10-Jun-1999	15:48:58.83	ALARM	FERNDALE	MECHANICAL	ALARM	
10-Jun-1999	15:48:58.91	ALARM	FERNDALE	CONTROL PRESSURE	LOW	

400053

10-Jun-1999	15:48:58.92	ALARM	FERNDALE	CONTROL PRESSURE	LOW LOW	44
10-Jun-1999	15:48:58.93	ALARM	FERNDALE	DISCHARGE PRESSURE	LOW	45
10-Jun-1999	15:48:58.94	ALARM	FERNDALE	DISCHARGE PRESSURE	LOW LOW	45
10-Jun-1999	15:48:58.95	ALARM	FERNDALE	SUCTION PRESSURE	LOW	23
10-Jun-1999	15:48:58.96	ALARM	FERNDALE	SUCTION PRESSURE	LOW LOW	23
10-Jun-1999	15:48:58.97	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW	31
10-Jun-1999	15:49:01.71	NORMAL	RENTON.1	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:01.72	NORMAL	OLYMPIA.DF	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:01.73	NORMAL	TACOMA.DF	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:01.74	NORMAL	MILEPOST.66	COMMUNICATIONS VIA CPA	NORMAL	
10-Jun-1999	15:49:01.75	NORMAL	SEATTLE.DF	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:01.76	NORMAL	PORTLAND.JCT	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:03.77	NORMAL	TACOMA.DF	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:04.78	NORMAL	VANCOUVER.DF	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:05.79	NORMAL	TACOMA.JCT	COMMUNICATIONS VIA CPA	NORMAL	
10-Jun-1999	15:49:05.80	NORMAL	VANCOUVER.DF	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:08.88	ALARM	FERNDALE	DRA PUMP INHIBIT	ON	
10-Jun-1999	15:49:11.84	NORMAL	VANCOUVR.JCT	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:11.85	NORMAL	ALLEN	ALLEN PLC COMM STATS	NORMAL	
10-Jun-1999	15:49:16.86	NORMAL	SEATAC.1	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:17.87	NORMAL	PORTLAND.DF	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:29.98	NORMAL	ANACORTES.ML	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:32.99	NORMAL	FERNDALE	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:49:33	NORMAL	FERNDALE	COMMUNICATIONS	NORMAL	
10-Jun-1999	15:50:05.01	CNTL REQ	PORTLAND.DF	CONSOLE 4 CAI	CLOSE	
10-Jun-1999	15:50:08.02	TRANSMIT	PORTLAND.DF	V-871 T-106 OUT	CLOSE	
10-Jun-1999	15:50:20.03	ALARM	PORTLAND.DF	ELECTRICAL	RESET	
10-Jun-1999	15:50:54.04	EXECUTE	PORTLAND.DF	V-871 T-106 OUT	CLOSE	
10-Jun-1999	15:55:07.05	EVENT	SYSTEM	COMMUNICATION STATISTICS	PURGED	
10-Jun-1999	15:55:38.06	UNCMDCHG	BAYVIEW	PRODUCT SUMP DISCHARGE	TRAVEL	
10-Jun-1999	15:55:44.07	UNCMDCHG	BAYVIEW	PRODUCT SUMP DISCHARGE	OPEN	
10-Jun-1999	15:55:44.08	UNCMDCHG	BAYVIEW	P-208 SUMP PUMP STATUS	RUN	
10-Jun-1999	15:55:49.09	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	OPEN	
10-Jun-1999	15:56:49.10	UNCMDCHG	BAYVIEW	PRODUCT SUMP DISCHARGE	TRAVEL	
10-Jun-1999	15:56:49.11	UNCMDCHG	BAYVIEW	P-208 SUMP PUMP STATUS	SHUTDOWN	
10-Jun-1999	15:56:55.12	UNCMDCHG	BAYVIEW	PRODUCT SUMP DISCHARGE	CLOSE	
10-Jun-1999	15:58:10.13	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	CLOSE	
10-Jun-1999	15:58:16.14	CHANGE	SEATAC.2	UNIT 4 STATUS	SHUTDOWN	
10-Jun-1999	16:01:01.15	UNCMDCHG	BAYVIEW	TK-206 TANK VALVE	TRAVEL	
10-Jun-1999	16:01:31.16	CNTL REQ	RENTON.1	CONSOLE 3 CAI	CHANGE	
10-Jun-1999	16:01:31.17	NOTICE:	RENTON.1	RT1IBTCHCHNGSTATUS IS CHANGE	CONTINUE...	
10-Jun-1999	16:01:32.18	TRANSMIT	RENTON.1	BATCH CHANGE	COMPLETE	
10-Jun-1999	16:01:36.19	CHANGE	RENTON.1	BATCH CHANGE	IN PROG.	
10-Jun-1999	16:01:36.20	CHANGE	RENTON.1	PRINT SWITCH	IN PROG.	
10-Jun-1999	16:01:36.21	CHANGE	RENTON.1	BTCH BLK-->PLC DOWNLOAD	READY	
10-Jun-1999	16:01:37.22	CNTL REQ	RENTON.1	CONSOLE 0	READY	
10-Jun-1999	16:01:41.23	EXECUTE	RENTON.1	MASTER --> PLC DOWNLOAD	READY	SUCCESS
10-Jun-1999	16:01:41.24	CHANGE	RENTON.1	CALCULATED BATCH	TOTL VOL	45854.1
10-Jun-1999	16:01:41.25	CHANGE	RENTON.1	CALCULATED BATCH	WTAVG GR	60.8
10-Jun-1999	16:01:41.26	CHANGE	RENTON.1	CALCULATED DELIVERY	TOTL VOL	4800.7
10-Jun-1999	16:01:41.27	CHANGE	RENTON.1	CALCULATED DELIVERY	WTAVG GR	60.8
10-Jun-1999	16:01:48.28	CNTL REQ	RENTON.1	CONSOLE 3 CAI	CLOSE	
10-Jun-1999	16:01:56.29	TRANSMIT	RENTON.1	V-644 BP GAS	CLOSE	
10-Jun-1999	16:01:58.30	UNCMDCHG	BAYVIEW	TK-206 TANK VALVE	OPEN	
10-Jun-1999	16:01:59.31	CHANGE	RENTON.1	DELIVERY REPORT	READY	
10-Jun-1999	16:01:59.32	CNTL REQ	RENTON.1	CONSOLE 0	READY	
10-Jun-1999	16:01:59.33	CHANGE	RENTON.1	BATCH REPORT	READY	
10-Jun-1999	16:01:59.34	CNTL REQ	RENTON.1	CONSOLE 0	READY	
10-Jun-1999	16:01:59.35	CHANGE	RENTON.1	BATCH CHANGE	COMPLETE	
10-Jun-1999	16:01:59.36	CHANGE	RENTON.1	PRINT SWITCH	COMPLETE	
10-Jun-1999	16:01:59.37	CHANGE	RENTON.1	BTCH BLK-->PLC DOWNLOAD	COMPLETE	
10-Jun-1999	16:01:59.38	EXECUTE	RENTON.1	DELIVERY REPORT	READY	
10-Jun-1999	16:01:59.39	EXECUTE	RENTON.1	BATCH REPORT	READY	
10-Jun-1999	16:02:02.40	CNTL REQ	RENTON.1	CONSOLE 3 CAI	SHUTDWN	

000054

0-Jun-1999	16:02:04.41	EVENT	RENTON.1	DELIVERY REPORT RT1DDL03	RECEIVED	
0-Jun-1999	16:02:05.42	TRANSMIT	RENTON.1	RENTON D.F. STATUS	SHUTDOWN	
0-Jun-1999	16:02:09.43	TO FINAL	RENTON.1	RENTON D.F. STATUS	RESET	
0-Jun-1999	16:02:10.44	CHANGE	RENTON.1	DELIVERY REPORT	COMPLETE	
0-Jun-1999	16:02:10.45	CHANGE	RENTON.1	BATCH REPORT	COMPLETE	
0-Jun-1999	16:02:10.46	CHANGE	RENTON.1	V-643 GAS DIVIDER	TRAVEL	
0-Jun-1999	16:02:10.47	UNCMDCHG	RENTON.1	RENTON D.F. STATUS	SHUTDOWN	
10-Jun-1999	16:02:24.48	TO FINAL	RENTON.1	V-644 BP GAS	TRAVEL	
10-Jun-1999	16:02:26.49	UNCMDCHG	RENTON.1	V-644 BP GAS	CLOSE	
10-Jun-1999	16:02:34.50	EVENT	RENTON.1	BATCH REPORT RT1DBT05	RECEIVED	
10-Jun-1999	16:02:37.51	CHANGE	RENTON.1	V-643 GAS DIVIDER	CLOSE	
10-Jun-1999	16:03:06.52	CNTL REQ	TACOMA.DF	CONSOLE 6 CAI		2150.00
10-Jun-1999	16:03:08.53	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		2150
10-Jun-1999	16:03:34.54	CHANGE	SEATAC.2	TR POSITION 8 DISABLE	OFF	
10-Jun-1999	16:03:42.55	TRANSMIT	RENTON	DRA SET POINT - GPH		8
10-Jun-1999	16:03:51.56	CHANGE	SYSTEM	Backup CPU Status	ON-LINE	
10-Jun-1999	16:04:31.57	CHANGE	SEATAC.2	UNITED DISABLE	ON	
10-Jun-1999	16:04:34.58	UNCMDCHG	BAYVIEW	FER TK-206 OUTLET	TRAVEL	
10-Jun-1999	16:04:38.59	CNTL REQ	TACOMA.JCT	CONSOLE 6 CAI		70.00
10-Jun-1999	16:04:42.60	TRANSMIT	TACOMA.JCT	8" PRESSURE SP ENTRY		70
10-Jun-1999	16:04:46.61	PREV VAL	TACOMA.DF	CONSOLE 6 CAI		100.000
10-Jun-1999	16:04:46.62	ENTRY	TACOMA.DF	INCOMING PSI SP ENTRY	INCV	50
10-Jun-1999	16:04:57.63	CNTL REQ	ALLEN.1	CONSOLE 6 CAI		928.00
10-Jun-1999	16:04:59.64	TRANSMIT	ALLEN.1	20" DISCHARGE PRESS SPT		928
10-Jun-1999	16:05:06.65	CHANGE	SEATAC.2	TR POSITION 1 DISABLE	ON	
10-Jun-1999	16:05:06.66	CHANGE	SEATAC.2	TR POSITION 2 DISABLE	ON	
10-Jun-1999	16:05:06.67	CHANGE	SEATAC.2	TR POSITION 4 DISABLE	ON	
10-Jun-1999	16:05:11.68	PREV VAL	LINNTON.DF	CONSOLE 6 CAI		100.000
10-Jun-1999	16:05:11.69	ENTRY	LINNTON.DF	INCOMING PSI SET POINT	INCV	50
10-Jun-1999	16:05:13.70	CHANGE	SEATAC.2	TR POSITION 5 DISABLE	ON	
10-Jun-1999	16:05:13.71	CHANGE	SEATAC.2	TR POSITION 7 DISABLE	ON	
10-Jun-1999	16:05:16.72	PREV VAL	PORTLAND.DF	CONSOLE 6 CAI		100.000
10-Jun-1999	16:05:16.73	ENTRY	PORTLAND.DF	INCOMING PSI SET POINT	INCV	50
10-Jun-1999	16:05:25.74	CHANGE	SEATAC.2	TR POSITION 3 DISABLE	ON	
10-Jun-1999	16:05:38.75	CHANGE	SEATAC.2	UNIT 1 STATUS	SHUTDOWN	
10-Jun-1999	16:05:44.76	TRANSMIT	RENTON	DRA SET POINT - GPH		8
10-Jun-1999	16:05:44.77	CHANGE	SEATAC.2	TR POSITION 6 DISABLE	ON	
10-Jun-1999	16:06:26.78	CNTL REQ	TACOMA.DF	CONSOLE 4 CAI	INC	
10-Jun-1999	16:06:28.79	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		2160
10-Jun-1999	16:06:28.80	CNTL REQ	TACOMA.DF	CONSOLE 4 CAI	INC	
10-Jun-1999	16:06:29.81	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		2170
10-Jun-1999	16:06:31.82	CNTL REQ	TACOMA.DF	CONSOLE 4 CAI	INC	
10-Jun-1999	16:06:34.83	CNTL REQ	TACOMA.DF	CONSOLE 4 CAI	INC	
10-Jun-1999	16:06:34.84	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		2180
10-Jun-1999	16:06:35.85	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		2190
10-Jun-1999	16:06:37.86	CNTL REQ	TACOMA.DF	CONSOLE 4 CAI	INC	
10-Jun-1999	16:06:40.87	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		2200
10-Jun-1999	16:07:58.88	CHANGE	SEATAC.2	TR POSITION 1 DISABLE	OFF	
10-Jun-1999	16:07:58.89	CHANGE	SEATAC.2	TR POSITION 2 DISABLE	OFF	
10-Jun-1999	16:07:58.90	CHANGE	SEATAC.2	TR POSITION 3 DISABLE	OFF	
10-Jun-1999	16:07:58.91	CHANGE	SEATAC.2	TR POSITION 4 DISABLE	OFF	
10-Jun-1999	16:08:09.92	CHANGE	SEATAC.2	TR POSITION 7 DISABLE	OFF	
10-Jun-1999	16:08:21.93	CHANGE	SEATAC.2	TR POSITION 5 DISABLE	OFF	
10-Jun-1999	16:08:21.94	CHANGE	SEATAC.2	TR POSITION 6 DISABLE	OFF	
10-Jun-1999	16:08:33.95	CHANGE	SEATAC.2	UNIT 2 STATUS	RUN	
10-Jun-1999	16:10:02.96	CNTL REQ	BAYVIEW	CONSOLE 2 CAI		700.00
10-Jun-1999	16:10:06.97	TRANSMIT	BAYVIEW	FER-ALN SPT PSI		700
10-Jun-1999	16:10:20.98	CNTL REQ	ALLEN.1	CONSOLE 2 CAI	RESET	
10-Jun-1999	16:10:22.99	TRANSMIT	ALLEN.1	16" STATION STATUS	RESET	
10-Jun-1999	16:10:43	CNTL REQ	BAYVIEW	CONSOLE 2 CAI	RESET	
10-Jun-1999	16:10:44.01	TRANSMIT	BAYVIEW	FER-BPT STA SDOWN-RESET	RESET	
10-Jun-1999	16:10:49.02	TO FINAL	BAYVIEW	FER-BPT STA SDOWN-RESET	SHUTDOWN	
10-Jun-1999	16:10:50.03	UNCMDCHG	BAYVIEW	FER-BPT STA SDOWN-RESET	RESET	
10-Jun-1999	16:10:56.04	CNTL REQ	BAYVIEW	CONSOLE 2 CAI	OPEN	

10-Jun-1999	16:11:01.05	TRANSMIT	BAYVIEW	FER BYPASS TO PUMPS	OPEN	
10-Jun-1999	16:11:08.06	PREV VAL	RENTON.1	CONSOLE 9 CAI		08410020H
10-Jun-1999	16:11:08.07	ENTRY	RENTON.1	V-669 16" RENTON DF MFLD	STAT	08410000H
10-Jun-1999	16:11:12.08	CNTL REQ	BAYVIEW	CONSOLE 2 CAI		700.00
10-Jun-1999	16:11:15.09	TRANSMIT	BAYVIEW	FER-ALN SPT PSI		700
10-Jun-1999	16:11:22.10	CNTL REQ	BAYVIEW	CONSOLE 2 CAI	OPEN	
10-Jun-1999	16:11:25.11	TRANSMIT	BAYVIEW	FER-BPT RECEIVER INLET	OPEN	
10-Jun-1999	16:11:34.12	TO INTER	BAYVIEW	FER-BPT RECEIVER INLET	CLOSE	
10-Jun-1999	16:12:04.13	EXECUTE	BAYVIEW	FER BYPASS TO PUMPS	OPEN	
10-Jun-1999	16:12:24.14	CNTL REQ	BAYVIEW	CONSOLE 2 CAI	OPEN	
10-Jun-1999	16:12:26.15	TRANSMIT	BAYVIEW	FER-BPT RECEIVER INLET	OPEN	
10-Jun-1999	16:12:40.16	CLEAR	BAYVIEW	FER-BPT METER PSI	LOW LOW	214
10-Jun-1999	16:12:40.17	CLEAR	BAYVIEW	FER-BPT METER PSI	LOW	214
10-Jun-1999	16:12:40.18	NORMAL	BAYVIEW	FER-BPT METER PSI	NORMAL	214
10-Jun-1999	16:12:40.19	CLEAR	BAYVIEW	FER-BPT UPSTREAM PSI	LOW	213
10-Jun-1999	16:12:40.20	NORMAL	BAYVIEW	FER-BPT UPSTREAM PSI	NORMAL	213
10-Jun-1999	16:12:45.21	CLEAR	BAYVIEW	FER-ALN METER PSI	LOW LOW	66
10-Jun-1999	16:12:45.22	CLEAR	BAYVIEW	FER-ALN METER PSI	LOW	66
10-Jun-1999	16:12:45.23	NORMAL	BAYVIEW	FER-ALN METER PSI	NORMAL	66
10-Jun-1999	16:12:45.24	CLEAR	BAYVIEW	FER-ALN PUMP DISC PSI	LOW LOW	67
10-Jun-1999	16:12:45.25	CLEAR	BAYVIEW	FER-ALN PUMP DISC PSI	LOW	67
10-Jun-1999	16:12:45.26	NORMAL	BAYVIEW	FER-ALN PUMP DISC PSI	NORMAL	67
10-Jun-1999	16:12:45.27	CLEAR	BAYVIEW	FER-ALN PUMP CASE PSI	LOW LOW	68
10-Jun-1999	16:12:45.28	CLEAR	BAYVIEW	FER-ALN PUMP CASE PSI	LOW	68
10-Jun-1999	16:12:45.29	NORMAL	BAYVIEW	FER-ALN PUMP CASE PSI	NORMAL	68
10-Jun-1999	16:12:45.30	CLEAR	BAYVIEW	FER-ALN STATION DISC PSI	LOW LOW	66
10-Jun-1999	16:12:45.31	CLEAR	BAYVIEW	FER-ALN STATION DISC PSI	LOW	66
10-Jun-1999	16:12:45.32	NORMAL	BAYVIEW	FER-ALN STATION DISC PSI	NORMAL	66
10-Jun-1999	16:12:54.33	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	OPEN	
10-Jun-1999	16:13:29.34	TO FINAL	BAYVIEW	FER-BPT RECEIVER INLET	TRAVEL	
10-Jun-1999	16:13:31.35	UNCMDCHG	BAYVIEW	FER-BPT RECEIVER INLET	OPEN	
10-Jun-1999	16:13:40.36	CNTL REQ	TACOMA.DF	CONSOLE 4 CAI	INC	
10-Jun-1999	16:13:41.37	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		2210
10-Jun-1999	16:13:43.38	CNTL REQ	TACOMA.DF	CONSOLE 4 CAI	INC	
10-Jun-1999	16:13:45.39	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		2220
10-Jun-1999	16:13:46.40	PREV VAL	Castle Rock	CONSOLE 9 CAI		1
10-Jun-1999	16:13:46.41	ENTRY	Castle Rock	UnAck Alarm @ RAW		0
10-Jun-1999	16:13:52.42	PREV VAL	Castle Rock	CONSOLE 9 CAI		1024
10-Jun-1999	16:13:52.43	ENTRY	Castle Rock	UnAck Alarm @ STA1		0
10-Jun-1999	16:13:58.44	CNTL REQ	BAYVIEW	CONSOLE 2 CAI		12000.00
10-Jun-1999	16:14:00.45	CNTL REQ	BAYVIEW	CONSOLE 2 CAI		20.00
10-Jun-1999	16:14:02.46	TRANSMIT	BAYVIEW	FER-BPT SPT FLW		12000
10-Jun-1999	16:14:04.47	TRANSMIT	BAYVIEW	FER-BPT SPT PSI		20
10-Jun-1999	16:14:04.48	CNTL REQ	BAYVIEW	CONSOLE 2 CAI		700.00
10-Jun-1999	16:14:06.49	TRANSMIT	BAYVIEW	FER-ALN SPT PSI		700
10-Jun-1999	16:14:08.50	CNTL REQ	BAYVIEW	CONSOLE 2 CAI		12000.00
10-Jun-1999	16:14:11.51	TRANSMIT	BAYVIEW	FER-ALN SPT FLW		12000
10-Jun-1999	16:14:19.52	ALARM	BAYVIEW	TK-209 TANK FLOW(SURGE)	CLOSE	
10-Jun-1999	16:15:12.53	CHANGE	CHERRY.POINT	METER FLOW STATUS	COMPLETE	
10-Jun-1999	16:15:12.54	CLEAR	CHERRY.POINT	DISCHARGE PRESSURE	LOW LOW	65
10-Jun-1999	16:15:19.55	CLEAR	CHERRY.POINT	DISCHARGE PRESSURE	LOW	127
10-Jun-1999	16:15:19.56	NORMAL	CHERRY.POINT	DISCHARGE PRESSURE	NORMAL	127
10-Jun-1999	16:15:25.57	CLEAR	FERNDALE	SUCTION PRESSURE	LOW LOW	36
10-Jun-1999	16:15:32.58	CNTL REQ	CHERRY.POINT	CONSOLE 2 CAI	START	
10-Jun-1999	16:15:35.59	TRANSMIT	CHERRY.POINT	UNIT 1 STATUS	RUN	
10-Jun-1999	16:15:36.60	ALARM	FERNDALE	LOW SUCTION PRESSURE	RESET	
10-Jun-1999	16:15:36.61	ALARM	FERNDALE	MECHANICAL	RESET	
10-Jun-1999	16:15:36.62	CLEAR	FERNDALE	SUCTION PRESSURE	LOW	146
10-Jun-1999	16:15:36.63	NORMAL	FERNDALE	SUCTION PRESSURE	NORMAL	146
10-Jun-1999	16:15:36.64	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW	154
10-Jun-1999	16:15:36.65	NORMAL	FERNDALE	CHERRY POINT IN PSI	NORMAL	154
10-Jun-1999	16:15:39.66	TO INTER	CHERRY.POINT	UNIT 1 STATUS	SHUTDOWN	
10-Jun-1999	16:15:43.67	CHANGE	CHERRY.POINT	UNIT 1 SUCTION	TRAVEL	
10-Jun-1999	16:16:25.68	CHANGE	CHERRY.POINT	UNIT 1 SUCTION	OPEN	

0000056

10-Jun-1999	16:16:25.69	CHANGE	CHERRY.POINT	UNIT 1 DISCHARGE	TRAVEL	
10-Jun-1999	16:16:29.70	EXECUTE	CHERRY.POINT	UNIT 1 STATUS	RUN	
10-Jun-1999	16:16:31.71	ALARM	FERNDALE	SUCTION PRESSURE	LOW	50
10-Jun-1999	16:16:40.72	CLEAR	FERNDALE	SUCTION PRESSURE	LOW	110
10-Jun-1999	16:16:40.73	NORMAL	FERNDALE	SUCTION PRESSURE	NORMAL	110
10-Jun-1999	16:16:43.74	CNTL REQ	FERNDALE	CONSOLE 2 CAI	START	
10-Jun-1999	16:16:47.75	TRANSMIT	FERNDALE	UNIT 1 STATUS	RUN	
10-Jun-1999	16:16:51.76	CLEAR	FERNDALE	CONTROL PRESSURE	LOW LOW	238
10-Jun-1999	16:16:51.77	CLEAR	FERNDALE	DISCHARGE PRESSURE	LOW LOW	236
10-Jun-1999	16:16:51.78	CLEAR	FERNDALE	DISCHARGE PRESSURE	LOW	236
10-Jun-1999	16:16:51.79	NORMAL	FERNDALE	DISCHARGE PRESSURE	NORMAL	236
10-Jun-1999	16:17:10.80	CLEAR	FERNDALE	CONTROL PRESSURE	LOW	253
10-Jun-1999	16:17:10.81	NORMAL	FERNDALE	CONTROL PRESSURE	NORMAL	253
10-Jun-1999	16:17:23.82	CHANGE	CHERRY.POINT	UNIT 1 DISCHARGE	OPEN	
10-Jun-1999	16:17:24.83	CNTL REQ	TACOMA.DF	CONSOLE 4 CAI	INC	
10-Jun-1999	16:17:25.84	TRANSMIT	TACOMA.DF	FLOW RATE SP ENTRY		2230
10-Jun-1999	16:17:26.85	ALARM	FERNDALE	CONTROL PRESSURE	LOW	247
10-Jun-1999	16:17:32.86	ALARM	FERNDALE	DISCHARGE PRESSURE	LOW	214
10-Jun-1999	16:17:33.87	ALARM	FERNDALE	DRA PUMP INHIBIT	OFF	
10-Jun-1999	16:17:34.88	EXECUTE	FERNDALE	UNIT 1 STATUS	RUN	
10-Jun-1999	16:18:00.89	CLEAR	FERNDALE	CONTROL PRESSURE	LOW	266
10-Jun-1999	16:18:00.90	NORMAL	FERNDALE	CONTROL PRESSURE	NORMAL	266
10-Jun-1999	16:18:00.91	CLEAR	FERNDALE	DISCHARGE PRESSURE	LOW	266
10-Jun-1999	16:18:00.92	NORMAL	FERNDALE	DISCHARGE PRESSURE	NORMAL	266
10-Jun-1999	16:20:00.93	CNTL REQ	CHERRY.POINT	CONSOLE 2 CAI	CHANGE	
10-Jun-1999	16:20:00.94	NOTICE:	CHERRY.POINT	CHPIBTCHCHNGSTATUS IS CHANGE	CONTINUE...	
10-Jun-1999	16:20:02.95	TRANSMIT	CHERRY.POINT	BATCH CHANGE	COMPLETE	
10-Jun-1999	16:20:05.96	EXECUTE	CHERRY.POINT	BATCH CHANGE	COMPLETE	
10-Jun-1999	16:20:10	ALARM	CHERRY.POINT	PRINT SWITCH	IN PROG.	
10-Jun-1999	16:20:10.01	CHANGE	CHERRY.POINT	BATCH REPORT	READY	
10-Jun-1999	16:20:10.04	CHANGE	CHERRY.POINT	DELIVERY REPORT	READY	
10-Jun-1999	16:20:10.07	CHANGE	CHERRY.POINT	RESET A	ACTIVE	
10-Jun-1999	16:20:10.08	CHANGE	CHERRY.POINT	RESET B	RESET	
10-Jun-1999	16:20:10.97	CHANGE	CHERRY.POINT	BTCH BLK-->RTU DOWNLOAD	READY	
10-Jun-1999	16:20:10.98	CNTL REQ	CHERRY.POINT	CONSOLE 0	READY	
10-Jun-1999	16:20:10.99	ALARM	CHERRY.POINT	BATCH CHANGE	IN PROG.	
10-Jun-1999	16:20:11.02	CNTL REQ	CHERRY.POINT	CONSOLE 0	READY	
10-Jun-1999	16:20:11.03	EXECUTE	CHERRY.POINT	BATCH REPORT	COMPLETE	
10-Jun-1999	16:20:11.05	CNTL REQ	CHERRY.POINT	CONSOLE 0	READY	
10-Jun-1999	16:20:11.06	EXECUTE	CHERRY.POINT	DELIVERY REPORT	COMPLETE	
10-Jun-1999	16:20:11.09	CNTL REQ	CHERRY.POINT	CONSOLE 0	RESET	
10-Jun-1999	16:20:16.10	CHANGE	CHERRY.POINT	CALCULATED BATCH	TOTL VOL	150429.4
10-Jun-1999	16:20:16.11	CHANGE	CHERRY.POINT	CALCULATED BATCH	WTAVG GR	56.7
10-Jun-1999	16:20:16.12	CHANGE	CHERRY.POINT	CALCULATED DELIVERY	TOTL VOL	108603.6
10-Jun-1999	16:20:16.13	CHANGE	CHERRY.POINT	CALCULATED DELIVERY	WTAVG GR	56.8
10-Jun-1999	16:20:16.14	CHANGE	CHERRY.POINT	FLOW COMPUTER BATCH	TOTL VOL	150429.0
10-Jun-1999	16:20:16.15	CHANGE	CHERRY.POINT	FLOW COMPUTER BATCH	WTAVG GR	55.6
10-Jun-1999	16:20:17.16	CHANGE	CHERRY.POINT	FLOW COMPUTER DELIVERY	TOTL VOL	108628.0
10-Jun-1999	16:20:17.17	CHANGE	CHERRY.POINT	FLOW COMPUTER DELIVERY	WTAVG GR	55.7
10-Jun-1999	16:20:17.18	EXECUTE	CHERRY.POINT	MASTER --> RTU DOWNLOAD	READY	SUCCESS
10-Jun-1999	16:20:20.19	TRANSMIT	CHERRY.POINT	RESET B	RESET	
10-Jun-1999	16:20:21.20	EVENT	CHERRY.POINT	BATCH REPORT CPTDBT08	RECEIVED	
10-Jun-1999	16:20:24.21	EVENT	CHERRY.POINT	DELIVERY REPORT CPTDDL07	RECEIVED	
10-Jun-1999	16:20:28.22	CHANGE	CHERRY.POINT	BTCH BLK-->RTU DOWNLOAD	COMPLETE	
10-Jun-1999	16:20:28.23	NORMAL	CHERRY.POINT	BATCH CHANGE	COMPLETE	
10-Jun-1999	16:20:28.24	NORMAL	CHERRY.POINT	PRINT SWITCH	COMPLETE	
10-Jun-1999	16:20:28.25	CHANGE	CHERRY.POINT	BATCH REPORT	COMPLETE	
10-Jun-1999	16:20:28.26	CHANGE	CHERRY.POINT	DELIVERY REPORT	COMPLETE	
10-Jun-1999	16:20:39.27	CNTL REQ	SEATTLE.DF	CONSOLE 2 CAI	OPEN	
10-Jun-1999	16:20:40.28	EXECUTE	CHERRY.POINT	RESET B	RESET	
10-Jun-1999	16:20:43.29	TRANSMIT	SEATTLE.DF	V-702 SCRAPER IN	OPEN	
10-Jun-1999	16:21:45.30	ALARM	BAYVIEW	ANA-BPT UPSTREAM PSI	LOW	30
10-Jun-1999	16:21:54.31	EXECUTE	SEATTLE.DF	V-702 SCRAPER IN	OPEN	
10-Jun-1999	16:22:45.32	ALARM	BAYVIEW	ANA-BPT METER PSI	LOW	8

.0-Jun-1999	16:23:09.33	PREV VAL ALLEN.1	CONSOLE 6 CAI			20.000
.0-Jun-1999	16:23:09.34	ENTRY ALLEN.1	20" DISCHARGE PRESS SPT	INCV		10
.0-Jun-1999	16:23:21.35	ALARM BAYVIEW	ANA-BPT METER PSI	LOW LOW		5
.0-Jun-1999	16:23:36.36	CNTL REQ BAYVIEW	CONSOLE 4 CAI	DEC		
.0-Jun-1999	16:23:38.37	TRANSMIT BAYVIEW	ANA-BPT SPT PSI			10
.0-Jun-1999	16:23:46.38	ALARM BAYVIEW	P-202 SUCTION PSI	LOW		2
.0-Jun-1999	16:23:54.39	CNTL REQ BAYVIEW	CONSOLE 4 CAI	INC		
.0-Jun-1999	16:23:56.40	TRANSMIT BAYVIEW	ANA-BPT SPT PSI			20
.0-Jun-1999	16:24:00.41	CNTL REQ ALLEN.1	CONSOLE 4 CAI	DEC		
.0-Jun-1999	16:24:03.42	TRANSMIT ALLEN.1	20" DISCHARGE PRESS SPT			918
.0-Jun-1999	16:24:04.43	CNTL REQ ALLEN.1	CONSOLE 4 CAI	DEC		
.0-Jun-1999	16:24:04.44	ALARM BAYVIEW	P-203 SUCTION PSI	LOW		2
.0-Jun-1999	16:24:07.45	TRANSMIT ALLEN.1	20" DISCHARGE PRESS SPT			908
.0-Jun-1999	16:24:08.46	PREV VAL ALLEN.1	CONSOLE 6 CAI			10.000
.0-Jun-1999	16:24:08.47	ENTRY ALLEN.1	20" DISCHARGE PRESS SPT	INCV		5
.0-Jun-1999	16:24:33.48	CLEAR BAYVIEW	P-203 SUCTION PSI	LOW		3
.0-Jun-1999	16:24:33.49	NORMAL BAYVIEW	P-203 SUCTION PSI	NORMAL		3
.0-Jun-1999	16:24:41.50	CLEAR BAYVIEW	ANA-BPT METER PSI	LOW LOW		6
.0-Jun-1999	16:24:41.51	CLEAR BAYVIEW	P-202 SUCTION PSI	LOW		4
.0-Jun-1999	16:24:41.52	NORMAL BAYVIEW	P-202 SUCTION PSI	NORMAL		4
.0-Jun-1999	16:24:51.53	CLEAR BAYVIEW	ANA-BPT METER PSI	LOW		9
.0-Jun-1999	16:24:51.54	NORMAL BAYVIEW	ANA-BPT METER PSI	NORMAL		9
.0-Jun-1999	16:25:01.55	PREV VAL CASTLE.ROCK	CONSOLE 6 CAI			18.000
.0-Jun-1999	16:25:01.56	ENTRY CASTLE.ROCK	DRA SET POINT - PPM	EU		10
.0-Jun-1999	16:25:08.57	PREV VAL OLYMPIC.JCT	CONSOLE 6 CAI			18.000
.0-Jun-1999	16:25:08.58	ENTRY OLYMPIC.JCT	DRA SET POINT - PPM	EU		10
.0-Jun-1999	16:25:34.59	CLEAR BAYVIEW	ANA-BPT UPSTREAM PSI	LOW		31
.0-Jun-1999	16:25:34.60	NORMAL BAYVIEW	ANA-BPT UPSTREAM PSI	NORMAL		31
.0-Jun-1999	16:25:47.61	TRANSMIT OLYMPIA.JCT	DRA SET POINT - GPH			3
.0-Jun-1999	16:25:48.62	TRANSMIT CASTLE.ROCK	DRA SET POINT - GPH			3
.0-Jun-1999	16:26:57.63	ALARM BAYVIEW	ANA-BPT UPSTREAM PSI	LOW		29
.0-Jun-1999	16:27:51.64	ALARM BAYVIEW	ANA-BPT METER PSI	LOW		8
.0-Jun-1999	16:28:09.66	ALARM BAYVIEW	ANA-BPT METER PSI	LOW LOW		5
.0-Jun-1999	16:28:17.67	ALARM BAYVIEW	P-203 SUCTION PSI	LOW		2
.0-Jun-1999	16:28:17.68	ALARM BAYVIEW	P-202 SUCTION PSI	LOW		1
.0-Jun-1999	16:29:22.65	ALARM PLDS	CHP AND FER TO BPT	ALERT		
.0-Jun-1999	16:30:51.69	EVENT PROCESS	ER\$QUEPRC REVIVED			
.0-Jun-1999	16:30:52.70	CNTL REQ FERNDALE	CONSOLE 2 CAI	START		
.0-Jun-1999	16:30:53.71	TRANSMIT FERNDALE	UNIT 3 STATUS	RUN		
.0-Jun-1999	16:30:59.72	CNTL REQ FERNDALE	CONSOLE 2 CAI			300.00
.0-Jun-1999	16:31:02.73	TRANSMIT FERNDALE	DISCHARGE PSI SP ENTRY			300
.0-Jun-1999	16:31:17.74	CLEAR BAYVIEW	ANA-BPT METER PSI	LOW LOW		6
.0-Jun-1999	16:31:21.75	ALARM BAYVIEW	ANA-BPT METER PSI	LOW LOW		5
.0-Jun-1999	16:31:34.76	CLEAR BAYVIEW	ANA-BPT METER PSI	LOW LOW		6
.0-Jun-1999	16:31:39.77	EXECUTE FERNDALE	UNIT 3 STATUS	RUN		
.0-Jun-1999	16:32:01.78	ALARM FERNDALE	SUCTION PRESSURE	LOW		40
.0-Jun-1999	16:32:06.79	ALARM CHERRY.POINT	SUCTION PRESSURE	LOW		2
.0-Jun-1999	16:32:06.80	ALARM CHERRY.POINT	METER PRESSURE	LOW		2
.0-Jun-1999	16:32:07.81	ALARM FERNDALE	LOW SUCTION PRESSURE	ALARM		
.0-Jun-1999	16:32:07.82	UNCMDCHG FERNDALE	UNIT 1 STATUS	SHUTDOWN		
.0-Jun-1999	16:32:07.83	UNCMDCHG FERNDALE	UNIT 3 STATUS	SHUTDOWN		
.0-Jun-1999	16:32:07.84	ALARM FERNDALE	MECHANICAL	ALARM		
.0-Jun-1999	16:32:07.85	ALARM FERNDALE	CONTROL PRESSURE	LOW		243
.0-Jun-1999	16:32:07.86	CLEAR FERNDALE	SUCTION PRESSURE	LOW		242
.0-Jun-1999	16:32:07.87	NORMAL FERNDALE	SUCTION PRESSURE	NORMAL		242
.0-Jun-1999	16:32:08.88	ALARM FERNDALE	DRA PUMP INHIBIT	ON		
.0-Jun-1999	16:32:16.89	ALARM CHERRY.POINT	LOW SUCTION	ALARM		
.0-Jun-1999	16:32:16.90	UNCMDCHG CHERRY.POINT	UNIT 1 STATUS	SHUTDOWN		
.0-Jun-1999	16:32:16.91	CHANGE CHERRY.POINT	UNIT 1 DISCHARGE	TRAVEL		
.0-Jun-1999	16:32:16.92	CLEAR CHERRY.POINT	SUCTION PRESSURE	LOW		265
.0-Jun-1999	16:32:16.93	NORMAL CHERRY.POINT	SUCTION PRESSURE	NORMAL		265
.0-Jun-1999	16:32:16.94	CLEAR CHERRY.POINT	METER PRESSURE	LOW		265
.0-Jun-1999	16:32:16.95	NORMAL CHERRY.POINT	METER PRESSURE	NORMAL		265
.0-Jun-1999	16:32:17.96	CNTL REQ CHERRY.POINT	CONSOLE 2 CAI	STOP		

000005

0-Jun-1999	16:32:17.97	NOTICE:	CHERRY.POINT	CHPIU1	STATUS IS STOP	CONTINUE...	
0-Jun-1999	16:32:18	CLEAR	FERNDALE	CONTROL PRESSURE	LOW		252
0-Jun-1999	16:32:18.01	NORMAL	FERNDALE	CONTROL PRESSURE	NORMAL		252
0-Jun-1999	16:32:18.98	ALARM	FERNDALE	LOW SUCTION PRESSURE	RESET		
0-Jun-1999	16:32:18.99	ALARM	FERNDALE	MECHANICAL	RESET		
0-Jun-1999	16:32:20.02	EXECUTE	CHERRY.POINT	UNIT 1 STATUS	SHUTDOWN		
0-Jun-1999	16:32:21.03	TRANSMIT	CHERRY.POINT	UNIT 1 STATUS	SHUTDOWN		
0-Jun-1999	16:32:23.04	CLEAR	BAYVIEW	ANA-BPT METER PSI	LOW		9
0-Jun-1999	16:32:23.05	NORMAL	BAYVIEW	ANA-BPT METER PSI	NORMAL		9
0-Jun-1999	16:32:26.06	NORMAL	CHERRY.POINT	LOW SUCTION	RESET		
0-Jun-1999	16:32:26.07	CHANGE	CHERRY.POINT	UNIT 1 SUCTION	TRAVEL		
0-Jun-1999	16:32:28.08	ALARM	FERNDALE	CONTROL PRESSURE	LOW		58
0-Jun-1999	16:32:28.09	ALARM	FERNDALE	CONTROL PRESSURE	LOW LOW		58
0-Jun-1999	16:32:28.10	ALARM	FERNDALE	DISCHARGE PRESSURE	LOW		59
0-Jun-1999	16:32:28.11	ALARM	FERNDALE	DISCHARGE PRESSURE	LOW LOW		59
0-Jun-1999	16:32:43.12	ALARM	FERNDALE	SUCTION PRESSURE	LOW		38
0-Jun-1999	16:32:43.13	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW		48
0-Jun-1999	16:32:50.14	ALARM	CHERRY.POINT	SUCTION PRESSURE	LOW		0
0-Jun-1999	16:32:50.15	ALARM	CHERRY.POINT	DISCHARGE PRESSURE	LOW		0
0-Jun-1999	16:32:50.16	ALARM	CHERRY.POINT	DISCHARGE PRESSURE	LOW LOW		0
0-Jun-1999	16:32:50.17	ALARM	CHERRY.POINT	METER PRESSURE	LOW		0
0-Jun-1999	16:32:52.18	ALARM	FERNDALE	SUCTION PRESSURE	LOW LOW		25
0-Jun-1999	16:32:55.19	CNTL REQ	MILEPOST.07	CONSOLE 1 CAI	CLOSE		
0-Jun-1999	16:32:57.20	ALARM	CHERRY.POINT	LOW SUCTION	ALARM		
0-Jun-1999	16:32:58.21	TRANSMIT	MILEPOST.07	V-MP07 BLOCK	CLOSE		
0-Jun-1999	16:32:58.22	CNTL REQ	MILEPOST.16	CONSOLE 1 CAI	CLOSE		
0-Jun-1999	16:32:58.23	ALARM	FERNDALE	LOW SUCTION PRESSURE	ALARM		
0-Jun-1999	16:32:58.24	ALARM	FERNDALE	MECHANICAL	ALARM		
0-Jun-1999	16:32:58.25	CLEAR	FERNDALE	SUCTION PRESSURE	LOW LOW		51
0-Jun-1999	16:32:58.26	CLEAR	FERNDALE	SUCTION PRESSURE	LOW		51
0-Jun-1999	16:32:58.27	NORMAL	FERNDALE	SUCTION PRESSURE	NORMAL		51
0-Jun-1999	16:32:58.28	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW		57
0-Jun-1999	16:32:58.29	NORMAL	FERNDALE	CHERRY POINT IN PSI	NORMAL		57
0-Jun-1999	16:33:01.30	CNTL REQ	MILEPOST.46	CONSOLE 1 CAI	CLOSE		
0-Jun-1999	16:33:02.31	TRANSMIT	MILEPOST.46	V-MP46 16" BLOCK	CLOSE		
0-Jun-1999	16:33:03.32	TRANSMIT	MILEPOST.16	V-MP16 BLOCK	CLOSE		
0-Jun-1999	16:33:05.33	NORMAL	CHERRY.POINT	LOW SUCTION	RESET		
0-Jun-1999	16:33:05.34	CHANGE	CHERRY.POINT	UNIT 1 SUCTION	CLOSE		
0-Jun-1999	16:33:08.35	ALARM	FERNDALE	SUCTION PRESSURE	LOW		26
0-Jun-1999	16:33:08.36	ALARM	FERNDALE	SUCTION PRESSURE	LOW LOW		26
0-Jun-1999	16:33:08.37	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW		33
0-Jun-1999	16:33:13.38	CHANGE	CHERRY.POINT	METER FLOW STATUS	IN PROG.		
0-Jun-1999	16:33:13.39	CHANGE	CHERRY.POINT	UNIT 1 DISCHARGE	CLOSE		
0-Jun-1999	16:33:14.40	CLEAR	FERNDALE	SUCTION PRESSURE	LOW LOW		35
0-Jun-1999	16:33:14.41	TO INTER	MILEPOST.46	V-MP46 16" BLOCK	OPEN		
0-Jun-1999	16:33:25.42	ALARM	FERNDALE	SUCTION PRESSURE	LOW LOW		24
0-Jun-1999	16:33:33.43	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW		30
0-Jun-1999	16:33:44.44	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW		30
0-Jun-1999	16:33:50.45	CLEAR	CHERRY.POINT	DISCHARGE PRESSURE	LOW LOW		57
0-Jun-1999	16:33:53.46	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW		29
0-Jun-1999	16:33:56.47	ALARM	CHERRY.POINT	DISCHARGE PRESSURE	LOW LOW		15
0-Jun-1999	16:33:58.48	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW		33
0-Jun-1999	16:34:09.49	EXECUTE	MILEPOST.46	V-MP46 16" BLOCK	CLOSE		
0-Jun-1999	16:34:10.50	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW		24
0-Jun-1999	16:34:14.51	EXECUTE	MILEPOST.07	V-MP07 BLOCK	CLOSE		
0-Jun-1999	16:34:18.52	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW		30
0-Jun-1999	16:34:23.53	CLEAR	FERNDALE	SUCTION PRESSURE	LOW LOW		31
0-Jun-1999	16:34:28.54	CLEAR	CHERRY.POINT	DISCHARGE PRESSURE	LOW LOW		64
0-Jun-1999	16:34:29.55	ALARM	FERNDALE	SUCTION PRESSURE	LOW LOW		19
0-Jun-1999	16:34:29.56	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW		27
0-Jun-1999	16:34:34.57	ALARM	CHERRY.POINT	DISCHARGE PRESSURE	LOW LOW		30
0-Jun-1999	16:34:34.58	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW		34
0-Jun-1999	16:34:34.59	EXECUTE	MILEPOST.16	V-MP16 BLOCK	CLOSE		
0-Jun-1999	16:34:42.60	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW		21

0-Jun-1999	16:34:48.61	CLEAR	FERNDALE	SUCTION PRESSURE	LOW LOW	33
0-Jun-1999	16:34:48.62	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW	42
0-Jun-1999	16:35:03.63	ALARM	FERNDALE	SUCTION PRESSURE	LOW LOW	17
0-Jun-1999	16:35:03.64	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW	26
0-Jun-1999	16:35:10.65	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW	30
0-Jun-1999	16:35:20.66	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW	25
0-Jun-1999	16:35:28.67	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW	37
0-Jun-1999	16:35:53.68	CLEAR	CHERRY.POINT	SUCTION PRESSURE	LOW	16
0-Jun-1999	16:35:53.69	NORMAL	CHERRY.POINT	SUCTION PRESSURE	NORMAL	16
0-Jun-1999	16:35:53.70	CLEAR	CHERRY.POINT	METER PRESSURE	LOW	16
0-Jun-1999	16:35:53.71	NORMAL	CHERRY.POINT	METER PRESSURE	NORMAL	16
0-Jun-1999	16:35:54.72	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW	28
0-Jun-1999	16:36:02.73	ALARM	CHERRY.POINT	SUCTION PRESSURE	LOW	12
0-Jun-1999	16:36:02.74	ALARM	CHERRY.POINT	METER PRESSURE	LOW	12
0-Jun-1999	16:36:08.75	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW	32
0-Jun-1999	16:36:19.76	CLEAR	CHERRY.POINT	SUCTION PRESSURE	LOW	16
0-Jun-1999	16:36:19.77	NORMAL	CHERRY.POINT	SUCTION PRESSURE	NORMAL	16
0-Jun-1999	16:36:19.78	CLEAR	CHERRY.POINT	METER PRESSURE	LOW	16
0-Jun-1999	16:36:19.79	NORMAL	CHERRY.POINT	METER PRESSURE	NORMAL	16
0-Jun-1999	16:36:25.80	ALARM	CHERRY.POINT	SUCTION PRESSURE	LOW	13
0-Jun-1999	16:36:25.81	ALARM	CHERRY.POINT	METER PRESSURE	LOW	13
0-Jun-1999	16:36:31.82	CLEAR	CHERRY.POINT	SUCTION PRESSURE	LOW	17
0-Jun-1999	16:36:31.83	NORMAL	CHERRY.POINT	SUCTION PRESSURE	NORMAL	17
0-Jun-1999	16:36:31.84	CLEAR	CHERRY.POINT	METER PRESSURE	LOW	17
0-Jun-1999	16:36:31.85	NORMAL	CHERRY.POINT	METER PRESSURE	NORMAL	17
0-Jun-1999	16:36:32.86	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW	28
0-Jun-1999	16:36:40.87	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW	30
0-Jun-1999	16:37:04.88	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW	30
0-Jun-1999	16:37:18.89	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW	31
0-Jun-1999	16:37:29.90	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW	29
0-Jun-1999	16:37:36.91	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW	32
0-Jun-1999	16:37:50.92	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW	29
0-Jun-1999	16:37:55.93	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW	32
0-Jun-1999	16:38:01.94	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW	30
0-Jun-1999	16:38:06.95	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW	32
0-Jun-1999	16:38:21.96	ALARM	FERNDALE	CHERRY POINT IN PSI	LOW LOW	30
0-Jun-1999	16:38:28.97	CLEAR	FERNDALE	CHERRY POINT IN PSI	LOW LOW	30
0-Jun-1999	16:39:20.99	CHANGE	SEATAC.2	UNITED DISABLE	OFF	
0-Jun-1999	16:39:33	UNCMDCHG	SEATAC.2	V-1206 VALVE STATUS	AUTO	
0-Jun-1999	16:39:33.01	CHANGE	SEATAC.1	T-113 TANK STATE	NEXT DEL	
0-Jun-1999	16:39:33.02	CHANGE	SEATAC.1	T-113 TANK SEQ NUM	2	
0-Jun-1999	16:39:52.98	ALARM	PLDS	CHP AND FER TO BPT	NORMAL	
0-Jun-1999	16:40:54.03	CNTL REQ	TACOMA.DF	CONSOLE 4 CAI	CHANGE	
0-Jun-1999	16:40:54.04	NOTICE:	TACOMA.DF	TACIBTCHCHNGSTATUS IS CHANGE	CONTINUE...	
0-Jun-1999	16:40:55.05	EXECUTE	TACOMA.DF	BATCH CHANGE	COMPLETE	
0-Jun-1999	16:40:56.06	TRANSMIT	TACOMA.DF	BATCH CHANGE	COMPLETE	
0-Jun-1999	16:40:58.07	ALARM	TACOMA.DF	PRINT SWITCH	IN PROG.	
0-Jun-1999	16:40:58.08	ALARM	TACOMA.DF	BATCH CHANGE	IN PROG.	
0-Jun-1999	16:40:58.09	CHANGE	TACOMA.DF	BTCH BLK-->RTU DOWNLOAD	READY	
0-Jun-1999	16:40:58.10	CNTL REQ	TACOMA.DF	CONSOLE 0	READY	
0-Jun-1999	16:41:00.11	EXECUTE	TACOMA.DF	MASTER --> RTU DOWNLOAD	READY	SUCCESS
0-Jun-1999	16:41:02.12	CHANGE	TACOMA.DF	CALCULATED BATCH	TOTL VOL	5976.0
0-Jun-1999	16:41:02.13	CHANGE	TACOMA.DF	CALCULATED BATCH	WTAVG GR	56.3
0-Jun-1999	16:41:02.14	CHANGE	TACOMA.DF	FLOW COMPUTER BATCH	TOTL VOL	5988.0
0-Jun-1999	16:41:02.15	CHANGE	TACOMA.DF	FLOW COMPUTER BATCH	WTAVG GR	55.1
0-Jun-1999	16:41:04.16	CHANGE	TACOMA.DF	CALCULATED DELIVERY	TOTL VOL	5987.0
0-Jun-1999	16:41:04.17	CHANGE	TACOMA.DF	CALCULATED DELIVERY	WTAVG GR	56.3
0-Jun-1999	16:41:04.18	CHANGE	TACOMA.DF	FLOW COMPUTER DELIVERY	TOTL VOL	5993.0
0-Jun-1999	16:41:04.19	CHANGE	TACOMA.DF	FLOW COMPUTER DELIVERY	WTAVG GR	55.1
0-Jun-1999	16:41:05.20	NORMAL	TACOMA.DF	PRINT SWITCH	COMPLETE	
0-Jun-1999	16:41:05.21	CNTL REQ	TACOMA.DF	CONSOLE 0	RESET	
0-Jun-1999	16:41:10.22	TRANSMIT	TACOMA.DF	RESET ACCUM A PSEUDO	RESET	
0-Jun-1999	16:41:14.23	NORMAL	TACOMA.DF	BATCH CHANGE	COMPLETE	
0-Jun-1999	16:41:14.24	CHANGE	TACOMA.DF	BTCH BLK-->RTU DOWNLOAD	COMPLETE	

000060

Jun-1999	16:41:27.25	CNTL REQ	BAYVIEW	CONSOLE 4 CAI	STOP	
Jun-1999	16:41:30.26	TRANSMIT	BAYVIEW	P-202 (ANACORTES) STATUS	SHUTDOWN	
Jun-1999	16:41:32.27	CNTL REQ	ANACORTES.ML	CONSOLE 4 CAI	STOP	
Jun-1999	16:41:34.28	CHANGE	BAYVIEW	P-202 ANA DISCHARGE	TRAVEL	
Jun-1999	16:41:34.29	CHANGE	BAYVIEW	P-202 ANA SUCTION	TRAVEL	
Jun-1999	16:41:34.30	CHANGE	BAYVIEW	P-202 STATUS	SHUTDOWN	
Jun-1999	16:41:34.31	UNCMDCHG	BAYVIEW	P-202 (FERNDALE) STATUS	SHUTDOWN	
Jun-1999	16:41:35.32	EXECUTE	TACOMA.DF	RESET ACCUM A PSEUDO	RESET	
Jun-1999	16:41:35.33	EXECUTE	BAYVIEW	P-202 (ANACORTES) STATUS	SHUTDOWN	
Jun-1999	16:41:35.36	CHANGE	TACOMA.DF	BATCH REPORT	READY	
Jun-1999	16:41:36.34	CNTL REQ	ALLEN.2	CONSOLE 4 CAI	STOP	
Jun-1999	16:41:37.35	TRANSMIT	ANACORTES.ML	UNIT 1 STATUS	SHUTDOWN	
Jun-1999	16:41:37.37	CNTL REQ	TACOMA.DF	CONSOLE 0	READY	
Jun-1999	16:41:37.38	EXECUTE	TACOMA.DF	BATCH REPORT	COMPLETE	
Jun-1999	16:41:37.39	CLEAR	BAYVIEW	P-203 SUCTION PSI	LOW	78
Jun-1999	16:41:37.40	NORMAL	BAYVIEW	P-203 SUCTION PSI	NORMAL	78
Jun-1999	16:41:37.41	CLEAR	BAYVIEW	ANA-BPT UPSTREAM PSI	LOW	95
Jun-1999	16:41:37.42	NORMAL	BAYVIEW	ANA-BPT UPSTREAM PSI	NORMAL	95
Jun-1999	16:41:37.43	CLEAR	BAYVIEW	P-202 SUCTION PSI	LOW	77
Jun-1999	16:41:37.44	NORMAL	BAYVIEW	P-202 SUCTION PSI	NORMAL	77
Jun-1999	16:41:39.45	TRANSMIT	ALLEN.2	20" UNIT 1 STATUS	SHUTDOWN	
Jun-1999	16:41:39.46	CNTL REQ	RENTON.2	CONSOLE 4 CAI	STOP	
Jun-1999	16:41:41.47	EVENT	TACOMA.DF	BATCH REPORT TACDBT00	RECEIVED	
Jun-1999	16:41:41.52	ALARM	BAYVIEW	ANA-ALN STATION DISC PSI	LOW	59
Jun-1999	16:41:42.48	TRANSMIT	RENTON.2	UNIT 2 STATUS	SHUTDOWN	
Jun-1999	16:41:44.49	UNCMDCHG	ALLEN.2	20" UNIT 2 STATUS	SHUTDOWN	
Jun-1999	16:41:44.50	EXECUTE	ALLEN.2	20" UNIT 1 STATUS	SHUTDOWN	
Jun-1999	16:41:44.53	UNCMDCHG	ALLEN.2	20" STATION STATUS	SHUTDOWN	
Jun-1999	16:41:45.51	TO FINAL	ANACORTES.ML	UNIT 1 STATUS	RUN	
Jun-1999	16:41:45.54	CHANGE	TACOMA.DF	BATCH REPORT	COMPLETE	
Jun-1999	16:41:46.55	UNCMDCHG	ANACORTES.ML	UNIT 1 STATUS	SHUTDOWN	
Jun-1999	16:41:46.56	CHANGE	ANACORTES.ML	V-449 UNIT 1 SUCTION	TRAVEL	
Jun-1999	16:41:46.57	CHANGE	ANACORTES.ML	V-450 UNIT 1 DISCHARGE	TRAVEL	
Jun-1999	16:41:49.58	CNTL REQ	ANA.SHELL	CONSOLE 4 CAI	STOP	
Jun-1999	16:41:49.59	EXECUTE	RENTON.2	UNIT 2 STATUS	SHUTDOWN	
Jun-1999	16:41:52.60	CNTL REQ	ANA,SHELL	CONSOLE 4 CAI	STOP	
Jun-1999	16:41:52.61	TRANSMIT	ANA.SHELL	UNIT 2 STATUS	SHUTDOWN	
Jun-1999	16:41:53.62	CHANGE	TACOMA.DF	DELIVERY REPORT	READY	
Jun-1999	16:41:53.63	CNTL REQ	TACOMA.DF	CONSOLE 0	READY	
Jun-1999	16:41:53.64	EXECUTE	TACOMA.DF	DELIVERY REPORT	COMPLETE	
Jun-1999	16:41:53.67	CLEAR	BAYVIEW	ANA-ALN STATION DISC PSI	LOW	462
Jun-1999	16:41:53.68	NORMAL	BAYVIEW	ANA-ALN STATION DISC PSI	NORMAL	462
Jun-1999	16:41:54.65	TRANSMIT	ANA.SHELL	UNIT 1 STATUS	SHUTDOWN	
Jun-1999	16:41:54.66	EVENT	TACOMA.DF	DELIVERY REPORT TACDDL05	RECEIVED	
Jun-1999	16:41:55.69	TO FINAL	ANA.SHELL	UNIT 2 STATUS	RUN	
Jun-1999	16:41:55.70	CHANGE	ANA.SHELL	V-410 UNIT 2 DISCHARGE	TRAVEL	
Jun-1999	16:41:55.71	UNCMDCHG	ANA.SHELL	UNIT 2 STATUS	SHUTDOWN	
Jun-1999	16:41:59.72	CNTL REQ	ANACORTES.ML	CONSOLE 4 CAI	STOP	
Jun-1999	16:41:59.73	EXECUTE	ANA.SHELL	UNIT 1 STATUS	SHUTDOWN	
Jun-1999	16:42:00.74	CHANGE	TACOMA.DF	DELIVERY REPORT	COMPLETE	
Jun-1999	16:42:02.75	TRANSMIT	ANACORTES.ML	UNIT 2 STATUS	SHUTDOWN	
Jun-1999	16:42:03.76	CNTL REQ	RENTON	CONSOLE 4 CAI	STOP	
Jun-1999	16:42:06.77	CNTL REQ	TACOMA.STA	CONSOLE 4 CAI	STOP	
Jun-1999	16:42:07.78	TRANSMIT	RENTON.2	UNIT 1 STATUS	SHUTDOWN	
Jun-1999	16:42:09.79	CNTL REQ	OLYMPIA.JCT	CONSOLE 4 CAI	STOP	
Jun-1999	16:42:10.80	TO FINAL	ANACORTES.ML	UNIT 2 STATUS	RUN	
Jun-1999	16:42:10.81	TRANSMIT	TACOMA.STA	UNIT 1 STATUS	SHUTDOWN	
Jun-1999	16:42:11.82	TRANSMIT	OLYMPIA.JCT	UNIT 1 STATUS	SHUTDOWN	
Jun-1999	16:42:11.84	UNCMDCHG	ANACORTES.ML	UNIT 2 STATUS	SHUTDOWN	
Jun-1999	16:42:11.85	CHANGE	ANACORTES.ML	V-478 UNIT 2 DISCHARGE	TRAVEL	
Jun-1999	16:42:12.83	CNTL REQ	CASTLE.ROCK	CONSOLE 4 CAI	STOP	
Jun-1999	16:42:14.86	EXECUTE	RENTON.2	UNIT 1 STATUS	SHUTDOWN	
Jun-1999	16:42:15.87	EXECUTE	TACOMA.STA	UNIT 1 STATUS	SHUTDOWN	
Jun-1999	16:42:15.88	EXECUTE	OLYMPIA.JCT	UNIT 1 STATUS	SHUTDOWN	


0000061

10-JUN-1999 18:17:55
006 007

CONFIDENTIAL
DO NOT COPY

0000318

3 HOUR TREND



Time	Value	Low Limit	High Limit	Trend
15:17	800	70	550	NO TREND
15:47	720	70	550	NO TREND
16:17	640	225	1321	NO TREND
16:47	560	25	620	NO TREND
17:17	480			
17:32	400			
17:47	320			
18:17	240			
18:32	160			
18:47	80			
19:17	0			

--- CURSOR READINGS ---
 CURRENT VALUE 34
 LOW LIMIT 70
 HIGH LIMIT 550
 TREND NO TREND




MILEPOST.46 WOODINVILLE MILEPOST.56

Exhibit T. Smith #5

30 MINUTE TREND

PREVIOUS

$\times 10^1$



1200	1600	1500	1600
1080	1440	1440	1440
960	1280	1280	1280
840	1120	1120	1120
720	960	960	960
600	800	800	800
480	640	640	640
360	480	480	480
240	320	320	320
120	160	160	160
0	0	0	0

10-JUN-1999	15:15	15:22	15:30	15:37	15:45
10-JUN-1999	15:15	15:22	15:30	15:37	15:45
10-JUN-1999	15:15	15:22	15:30	15:37	15:45
10-JUN-1999	15:15	15:22	15:30	15:37	15:45

30 MINUTES	15:15	15:22	15:30	15:37
------------	-------	-------	-------	-------

RECORD ID	CURRENT VALUE	LOW LIMIT	HIGH LIMIT	CURSOR READINGS
INS FERHDISCHRG	6	225	1321	10-JUN-1999 15:24 962
INS FERHCONTROL	20	250	1450	10-JUN-1999 15:24 1031
INS BPTHPT1901	86	25	620	10-JUN-1999 15:24 215
INS FERHNETFLOW	0	-100	12000	10-JUN-1999 15:24 8904

0000318A


Exhibit T.Smith #6

ASB
CONFIDENTIAL
DO NOT COPY

10-JUN-1999 22:59:07
007

ACB

x10¹




TIME	PREVIOUS	CURRENT
10-JUN-1999 15:00	800	1200
10-JUN-1999 15:30	720	1080
10-JUN-1999 16:00	640	960
10-JUN-1999 16:30	560	840
10-JUN-1999 17:00	480	720
10-JUN-1999 17:30	400	600
10-JUN-1999 18:00	320	480
10-JUN-1999 18:30	240	360
10-JUN-1999 19:00	160	240
10-JUN-1999 19:30	80	120
10-JUN-1999 20:00	0	0

RECORD ID	CURRENT VALUE	LOW LIMIT	HIGH LIMIT	CURSOR	READINGS
INS FERHNETFLOW	0	-100	12000	10-JUN-1999 15:40	8682
INS FERHDISCHRG	2	225	1321	10-JUN-1999 15:40	962
INS CHPHDISCHRG	36	70	550	10-JUN-1999 15:40	211
INS BPTHPT1901	109	25	620	10-JUN-1999 15:40	66

0000325

CONFIDENTIAL
DO NOT COPY

Exhibit T. Smith #7



Print Screen

15:17:48 15:23:11 15:23:36 15:33:50 15:39:23

Zoom In 2hr 35s Zoom Out

hour 30 minutes 10 minutes

Per Disch_Press 5 8

Per Inlet_Upstream_Press 0 0

Per Rec_Inlet_Press 1400 1402

UI_Suction_Press 36 38

BAYVIEW TERMINAL PLC

0000310

Exhibit T. Smith #8

ACB
CONFIDENTIAL
DO NOT COPY