

██████████ 05/05/17 05/05/17 ██████████ O/S GAS LEAK COMM 461 Building or structure
weakened or collapsed

Dispatched for the natural gas leak. Situation found was a large truck and trailer carrying a backhoe which had fallen into a sink hole in the street, directly adjacent to the curb. Workers on scene said they'd heard a hissing and had smelled gas. No hissing or roaring were audible by SFFD crews nor was there an odor of natural gas. E08 cordoned off the area with the assistance of PD and denied entry to cars and pedestrians. PG& E was notified and arrived on scene with detector. No gas leak discovered and sink hole determined to be at least 20 feet from any gas lines. DPW was notified to respond to the sink hole and construction crews on scene called their own wrecker to tow their truck out of the sink hole. Safety manager on site directed to keep sidewalk cordoned off until truck removed from sinkhole.

PG&E REQUESTED AT 05:49:12 HOURS

PG&E ON-SCENE AT 06:22:28 HOURS

██████████ 05/19/17 05/19/17 ██████████ O/S GAS LEAK RESD 412 Gas leak (natural gas or
LPG)

Crews hit gas line pg and e requested safe area established pipe fixed

PG&E REQUESTED AT 10:09:39 HOURS

PG&E ON-SCENE AT 10:41:04 HOURS

██████████ 05/25/17 05/25/17 ██████████ O/S GAS LEAK RESD 412 Gas leak (natural gas or
LPG)

Residential gas line located in the street was cut by construction crew. PG& E responded to cap the line.

PG&E REQUESTED AT 11:04:47

PG&E ON-SCENE AT 11:36:47

██████████ 05/30/17 05/30/17 ██████████ O/S GAS LEAK RESD 412 Gas leak (natural gas or LPG)

Gas leak, created safe zone, called for PG & E. leak stopped by PG & E.

PG&E REQUESTED AT 12:16:02 HOURS

PG&E ON-SCENE AT 13:16:57 HOURS

██████████ 06/26/17 06/26/17 ██████████ O/S GAS LEAK RESD 412 Gas leak (natural gas or LPG)

gas leak at multi-family vacant. stood by for PG& E

REQUESTED EXPEDITED PG&E RESPONSE AT 11:59:18 HOURS

PG&E ON-SCENE AT 12:37:34 HOURS

██████████ 02/06/18 02/06/18 ██████████ O/S GAS LEAK COMM 412 Gas leak (natural gas or LPG)

Private contractor's backhoe operator accidentally ruptured 4" high-pressured gas main while digging near sidewalk on the NW corner. Arrived on-scene with E21 and immediately set perimeter with assistance of SFPD. Special called PG& E gas. Had E21 begin evacuating structures in immediate area. Stopped Muni trolley buses from proceeding and instructed Muni driver to have Muni supervisor respond to reroute buses. One Muni driver was transported from Pierce/McAllister on separate medical incident for light-headedness which may have been related to the gas leak. OSHA was notified via landline. PG& E crew arrive and crimped 4" main. Div. 2 Velo and PIO Baxter were also on-scene assisting.

PG&E REQUESTD AT 15:13:09

PG&E SUPERVISOR ON-SCENE AT 15:30:01 (NO EXCAVATION EQUIPMENT)

PG&E EXCAVATION CREW ON-SCENE AT 15:42:13

██████████ 01/04/19 01/04/19 ██████████ O/S GAS LEAK RESD 412 Gas leak (natural gas or LPG)

Used caution tape to keep pedestrians out of area. Summoned PGE gas. Sheltered residents in place.

PG&E REQUESTED AT 10:57:54

PG&E ON-SCENE AT 11:54:30

██████████ 02/18/19 02/18/19 ██████████ O/S UKN GAS ODOR 412 Gas leak (natural gas or LPG)

Arrived on scene to find excavation crews had pierced a 3" gas main with audible hissing. Called for PG& E and monitored scene with ready line in place and 3" supply line to nearest hydrant. Scene resolved by PGE crews without further incident.

REQUESTED PG&E AT 13:56 HOURS

PG&E ON-SCENE AT 15:22:13 WITHOUT TOOLS